



Certification Test Report

Morsø Jernstøberi A/S

**Freestanding Wood Stove
Model: 8140**

Report Number 192-S-07-3

OMNI-Test Laboratories, Inc.
Product Testing & Certification

Mailing: Post Office Box 743
Street: 5465 SW Western Avenue • Suite G
Beaverton, Oregon 97075 USA



Phone: (503) 643-3788
Fax: (503) 643-3799

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

Certification Test Report

Morsø Jernstøberi A/S

Freestanding Wood Stove

Model: 8140

Prepared for: Morsø Jernstøberi A/S
Furvej 6 DK-7900
DENMARK

Prepared by: OMNI-Test Laboratories, Inc.
5465 SW Western Avenue, Suite G
Beaverton, Oregon 97005
(503) 643-3788

Test Period: October 6, 2005 through October 9, 2005

Report Date: October 2005


OMNI-Test Project Number: 192-S-07-3

All data and information contained in this report are confidential and proprietary to Morsø Jernstøberi A/S. Its significance is subject to the adequacy and representative character of the samples and to the comprehensiveness of the tests, examinations, or surveys made. The contents of this report cannot be copied or quoted, except in full, without specific, written authorization from Morsø Jernstøberi A/S and OMNI-Test Laboratories, Inc. No use of the OMNI-Test Laboratories, Inc. (O-TL) name, logo, or registered (O-TL) mark is permitted, except as expressly authorized by OMNI-Test Laboratories, Inc. in writing.


Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

AUTHORIZED SIGNATORIES

This report has been reviewed and approved by the following authorized signatories.


Richard Sparwasser, Vice President
OMNI-Test Laboratories, Inc.


John Voorhees, Director of Technical Services
OMNI-Test Laboratories, Inc.


Bruce Davis, Technician
OMNI-Test Laboratories, Inc.

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

Morsø Jernstøberi A/S
Model: 8140

Test Dates: October 6, 2005 to October 9, 2005



TABLE OF CONTENTS

	PREFACE.....	(4 pages)
1.	SAMPLING PROCEDURES AND TEST RESULTS	1-1 (9 pages)
	Introduction.....	1-2
	<u>Summary Tables</u>	
	Table 1.1 - Particulate Emissions Results.....	1-3
	Table 1.2 - Test Facility Conditions	1-3
	Table 1.3.1 - Fuel Measurements and Crib Descriptions - Pretest	1-4
	Table 1.3.2 - Fuel Measurements and Crib Descriptions - Test	1-4
	Table 1.4 - Dilution Tunnel Gas Measurements and Sampling Data	1-5
	Table 1.5 - Heater Operation	1-5
	Table 1.6 - Pretest Configurations	1-6
	Table 1.7 - Run Data.....	1-6
	Table 1.8 - Test Configurations	1-7
	Test Results and Discussion.....	1-8
	Appliance Description	1-9
2.	TEST DATA BY RUN.....	2-1 (34 pages)
	Run 1	2-3
	Run 2.....	2-11
	Run 3.....	2-19
	Run 4.....	2-27
3.	DRAWINGS AND FUEL PHOTOGRAPHS	3-1 (103 pages)
	Fuel Photographs	3-2
	Firebox Volume Drawings.....	3-4
	Manufacturer Design Drawings.....	3-5
4.	MANUFACTURER OWNER'S MANUAL.....	4-1 (12 pages)
5.	QUALITY ASSURANCE/QUALITY CONTROL	5-1 (40 pages)
	Sample Analysis.....	5-3
	Calibrations – Method 28 and 5G.....	5-10
6.	EXAMPLE CALCULATIONS	6-1 (10 pages)

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

Section 1

Sampling Procedures and Test Results

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

INTRODUCTION

Morsø Jernstøberi A/S retained OMNI-Test Laboratories, Inc. (O-TL) to perform U.S. Environmental Protection Agency (EPA) certification testing on the model 8140 wood stove. The 8140 wood stove is a non-catalytic, freestanding, convection-type room heater. The firebox is constructed of cast iron with several components made of mild and stainless steel. The usable firebox volume was measured to be 1.05 cubic feet. The stove is vented through a 6" diameter flue collar located at the top of the unit.

The testing was performed at the O-TL laboratory in Beaverton, Oregon. The altitude of the laboratory is 204 feet above sea level. The unit was received in good condition and logged in at the O-TL test facility on September 20, 2005; it was assigned and labeled with O-TL ID #786. O-TL representative Bruce Davis conducted the certification testing and completed all testing by October 7, 2005. The EPA was notified of the testing dates in a letter dated September 29, 2005. A testing contract, including provisions for Random Compliance Audit (RCA) testing, has been signed by Karsten Aargard of Morsø Jernstøberi A/S and is on file at O-TL.

The 8140 wood stove was tested in accordance with the U.S. EPA 40 CFR Part 60, Subpart AAA – Standard of Performance for Residential Wood Heaters (Appendix A, Methods 28 and 5G). Particulate emissions were measured using a Method 5G sampling train consisting of two filters (front and back). The weighted average emissions of the four test runs indicate a particulate emission level of 4.5 grams per hour. Test runs were conducted in each of three burn rate categories (0.80-1.25 kg/hr, 1.25-1.90 kg/hr, and maximum). Emissions for each of their individual test runs did not exceed the cap. The 8140 results are within the emission limit of 7.5 grams per hour for non-catalytic affected facilities manufactured on or after July 1, 1990, or sold at retail on or after July 1, 1992.

The wood heater was sealed after completion of testing in compliance with the EPA regulation as follows:

- “DO NOT TAMPER” labels were placed on the door and all other openings;
- Plastic material sealed with “DO NOT TAMPER” labels and tape was wrapped around the unit;
- The unit was sealed in a wood box constructed for the unit and secured with steel banding; and
- “DO NOT TAMPER” labels were placed on all outer surfaces of the box.

This report is organized in accordance with the EPA-recommended outline and is summarized in the Table of Contents immediately preceding this report.

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

Table 1.1 – Particulate Emissions

Run	Burn Rate (kg/hr dry)	Method 5G Emissions (g/hr)
1	0.91	3.68
2	2.10	9.38
3	1.42	4.09
4	1.13	2.43
Weighted particulate emission average of four test runs: 4.5 grams per hour.		

Table 1.2 – Test Facility Conditions

Run	Room Temperature (°F)		Barometric Pressure (in Hg)		Air Velocity (ft/min)	
	Before	After	Before	After	Before	After
1	73	75	29.84	29.83	<50	<50
2	74	72	29.82	29.82	<50	<50
3	67	69	29.84	29.85	<50	<50
4	68	69	29.82	29.83	<50	<50

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

Table 1.3.1 – Fuel Measurement and Crib Description Summary – PRETEST

Run	Pretest Fuel Weight (Starting weight)	Pretest Moisture (Dry basis - %)	Coal Bed Weight (lb)
1	4.6	21.1	1.7
2	11.9	20.6	1.5
3	10.9	23.1	1.7
4	5.8	20.9	1.7

Table 1.3.2 – Fuel Measurement and Crib Description Summary – TEST

Run	Test Fuel Wet Basis (lb)	Firebox Volume (ft ³)	Fuel Loading Density Wet Basis (lb/ft ³)	Fuel Moisture Content Dry (%)	Piece Length (in)	2x4s Used	4x4s Used
1	6.8	1.05	6.48	19.9	12.5	4	0
2	7.5	1.05	7.14	21.3	12.5	4	0
3	6.9	1.05	6.57	19.8	12.5	4	0
4	7.0	1.05	6.67	20.2	12.5	4	0

Model: 8140
 Morsø Jernstøberi A/S
 Furvej 6 DK-7900
 Nykøbing Mors
 DENMARK

Table 1.4 – Dilution Tunnel Gas Measurements and Sampling Data Summary

Run	Length of Test (min)	Average Dilution Tunnel Gas Measurements		
		Velocity (ft/sec)	Flow Rate (dscf/min)	Temp (°F)
1	170	12.79	135.8	98.8
2	80	13.33	135.9	121.5
3	110	13.51	142.3	103.5
4	140	13.52	144.1	96.7

Table 1.5 - Heater Operation Data (Average Temperature Data)

Run	Beginning Surface Temp Average ^a	Ending Surface Temp Average ^a	Surface Delta T ^b
1	345.6	292.0	54
2	526.0	421.4	105
3	446.6	346.8	100
4	382.2	330.0	52

a. All temperatures are in degrees F.
 b. Surface Delta T represents the difference between beginning and ending average surface temperature.

Model: 8140
 Morsø Jernstøberi A/S
 Furvej 6 DK-7900
 Nykøbing Mors
 DENMARK

Table 1.6 – Pretest Configuration

Run	Combustion Air (in)	Fuel Added	Fuel Removed	Time (min)
1	13mm *	4.6 lbs. at start; no addition; coal bed 1.7 lbs.	0	71
2	29mm **	11.9 lbs. at start; no addition; coal bed 1.5 lbs.	0	66
3	23mm *	10.9 lbs. at start; no addition; coal bed 1.7 lbs.	0	76
4	17mm *	5.8 lbs. at start; no addition; coal bed 1.7 lbs.	0.3	68

* Measured from the “fully closed” setting

** 29mm = fully open since additional lever movement does not change air flow

Table 1.7 – Run Data

Run	Average Dry Burn Rate (kg/hr)	Initial (Induced) Draft (in H ₂ O)	Primary Air Setting (in)	Run Time (min)	Average Draft (in H ₂ O)
1	0.91	0	13mm *	170	-0.040
2	2.10	0	Fully Open**	80	-0.064
3	1.42	0	23mm *	110	-0.053
4	1.13	0	17mm *	140	-0.046

* Measured from the “fully closed” setting

** 29mm = fully open since additional lever movement does not change air flow

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

Table 1.8 – Test Configuration

Run	Five-Minute Startup	Combustion Air
1	<u>Bypass</u> : N/A. <u>Fuel Loading</u> : Loaded by 30 seconds. <u>Door</u> : Cracked open until 4:10; then closed. <u>Primary Air</u> : Fully open until 4:15; adjusted to test setting by 5:00. <u>Other</u> : N/A. <u>Secondary</u> : Fixed. <u>Tertiary</u> : N/A. <u>Fan</u> : N/A.	13mm *
2	<u>Bypass</u> : N/A. <u>Fuel Loading</u> : Loaded by 25 seconds. <u>Door</u> : Cracked open until 2:10; then closed. <u>Primary Air</u> : Fully open until 5:00. <u>Other</u> : N/A. <u>Secondary</u> : Fixed. <u>Tertiary</u> : N/A. <u>Fan</u> : N/A.	Fully Open**
3	<u>Bypass</u> : N/A. <u>Fuel Loading</u> : Loaded by 20 seconds. <u>Door</u> : Cracked open until 2:15; then closed. <u>Primary Air</u> : Fully open until 5:00. <u>Other</u> : N/A. <u>Secondary</u> : Fixed. <u>Tertiary</u> : N/A. <u>Fan</u> : N/A.	23mm *
4	<u>Bypass</u> : N/A. <u>Fuel Loading</u> : Loaded by 25 seconds. <u>Door</u> : Cracked open until 4:00; then closed. <u>Primary Air</u> : Fully open until 4:00; adjusted to test setting by 5:00. <u>Other</u> : N/A. <u>Secondary</u> : Fixed. <u>Tertiary</u> : N/A. <u>Fan</u> : N/A.	17mm *

* Measured from the "fully closed" setting

** 29mm = fully open since additional lever movement does not change air flow

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

TEST RESULTS AND DISCUSSION

A total of four test runs were conducted in the following categories: two in the 0.80 to 1.25 kg/hr dry category; one in the 1.26 to 1.90 kg/hr dry category; and one at maximum.

The weighted particulate emission level was measured to be 4.5 grams per hour.

The proportionality results for all four test runs were acceptable. Quality check results for each test run are presented in Section 2 of this report.

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

APPLIANCE DESCRIPTION

Appliance Manufacturer: Morsø Jernstøberi A/S

Wood Stove Model: 8140

Type: Freestanding, convection-type room heater

WOOD HEATER DESCRIPTION:

Materials of Construction: The unit is constructed of cast iron with several components made of mild and stainless steel.

Air Introduction System: Air enters the firebox through an opening located at the front of the appliance above the fuel-loading door. Secondary air enters the appliance through the back and is channeled vertically to two openings supplying one 1" square tube.

Combustion Control Mechanisms: The combustion air inlet is controlled by a handle located below the fuel-loading door in the center of the appliance.

Combustor: N/A.

Internal Baffles: A refractory baffle is mounted in the upper portion of the firebox. The flame path is forced to the front of the firebox where it travels up through the opening between the baffle and primary air manifold.

Other Features: N/A.

Flue Outlet: The 6" diameter flue outlet is located in the top of the unit.

WOOD HEATER OPERATING INSTRUCTIONS

Specific written instructions: See Section 4 of this report. All markings and instruction materials were reviewed for content prior to printing.

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

Section 2

Test Data by Run

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

Run 1

Wood Heater Test Data - EPA Method 5G

Run:	1
Manufacturer:	Morsso
Model:	8100
Tracking No.:	786
Project No.:	192-S-07-3
Test Date:	06-Oct-05
Beginning Clock Time:	13:44
Recording Interval:	10 min.
Total Sampling Time:	170 min.

Velocity Traverse Data								
	PL1	PL2	PL3	PL4	PL5	PL6	PL7	PL8
Initial dP	0.030	0.042	0.038	0.024	0.024	0.040	0.046	0.034
Initial Temp.	100	100	100	100	99	99	99	99

Signature/Date: Bob 11-1-05

Tunnel Velocity: 12.79 ft/sec.

Initial Tunnel Flow: 134.8 scfm

Average Tunnel Flow: 133.8 scfm

Tunnel Area: 0.196 ft²

Post-Test Leak Check: .0094 @ 5 cfm @ .1Hg

Fuel Moisture (dry basis): 19.88 %

Total Particulate: 23.8 mg

Filter Holder No.: A

PM Control Module: 21

Dilution Tunnel MW(dry): 29.00 lb/lb-mole

Dilution Tunnel MW(wet): 28.56 lb/lb-mole

Dilution Tunnel H₂O: 4.00 percent

Dilution Tunnel Static: -0.650 "H₂O

Pitot Tube Cp: 0.99

Meter Box Y Factor: 0.988

Barometric Pressure: 29.84 "Hg

Begin: 29.83 End: 29.83 Average: 29.83

OMNI Equipment Numbers:

Elapsed Time	Particulate Sampling Data										Fuel Weight, lb					Wood Heater Temperature Data, °F					Stack	
	Gas Meter (Cubic Feet)	Sample Rate, cfm	Orifice dH	Meter oF	Meter Vac. In. Hg.	Dilution Tunnel Temp.	Dilution Tunnel dP	Pro. Rate (10%)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Average Surface	Stack	Filter	Impinger exit	Ambient	Draft In. H ₂ O	
0	437.000		0.75	73	0	100	0.035		6.8		396	119	390	413	410	345.6	249	77	70	73	-0.033	
10	442.170	0.52	0.75	85	1	107	0.035	103	5.8	-1	403	119	412	395	392	344.2	311	80	46	72	-0.046	
20	447.360	0.52	0.75	94	1	102	0.035	101	4.9	-0.9	415	116	440	389	388	349.6	320	81	45	74	-0.048	
30	452.570	0.52	0.75	99	1	105	0.035	101	3.8	-1.1	464	115	529	402	424	386.8	366	81	45	74	-0.054	
40	457.820	0.53	0.75	103	1	106	0.035	101	2.7	-1.1	526	113	607	439	478	432.6	388	81	46	76	-0.055	
50	463.070	0.53	0.75	104	1	104	0.035	100	1.7	-1	561	111	625	467	512	453.2	369	81	46	75	-0.050	
60	468.250	0.52	0.75	105	1	101	0.035	99	1.4	-0.3	530	109	556	474	506	435.0	322	81	46	75	-0.047	
70	473.520	0.53	0.75	106	1	99	0.035	100	1.2	-0.2	485	107	492	462	478	404.8	293	81	46	74	-0.042	
80	478.550	0.50	0.75	107	1	98	0.035	95	1.1	-0.1	449	105	452	447	454	381.4	276	80	46	73	-0.040	
90	483.900	0.53	0.75	107	1	97	0.035	101	1.0	-0.1	420	105	423	434	437	363.8	264	80	46	73	-0.037	
100	489.300	0.54	0.75	108	1	96	0.035	102	0.8	-0.2	400	105	403	422	424	350.8	255	80	46	75	-0.036	
110	494.750	0.54	0.75	109	1	96	0.035	103	0.7	-0.1	380	105	384	410	412	338.2	247	80	45	75	-0.035	
120	500.090	0.53	0.75	109	1	96	0.035	101	0.6	-0.1	369	106	373	401	404	330.6	243	80	45	74	-0.034	
130	505.430	0.53	0.75	109	1	95	0.035	100	0.4	-0.2	359	106	364	394	398	324.2	239	80	46	75	-0.034	
140	510.790	0.54	0.75	109	1	95	0.035	101	0.3	-0.1	347	106	351	384	388	315.2	232	80	47	74	-0.033	
150	516.140	0.53	0.75	109	1	94	0.035	101	0.2	-0.1	337	105	340	373	377	306.4	227	80	48	73	-0.032	
160	521.500	0.54	0.75	108	1	94	0.035	101	0.1	-0.1	327	105	330	362	366	298.0	223	79	47	73	-0.031	
170	526.805	0.53	0.75	109	1	94	0.035	100	0.0	-0.1	320	105	323	354	358	292.0	219	79	48	75	-0.031	
Avg/Total	89,805	0.53	0.75	102.94		98.81	0.035	100.45								54	80.06	79	47.44	75	-0.040	

Run 1
24 of 2-34

Wood Heater Test Data - EPA Method 5G

Manufacturer: Morso
 Model: 8100
 Project No.: 786
 Tracking No.: 192-S-07-3
 Run: 1
 Test Date: 10/06/05

Burn Rate	0.91 kg/hr dry
Particulate Concentration (dry-standard) Particulate Emission Rate Adjusted Emissions	0.00029 grams/dscf 2.33 grams/hour 3.68 grams/hour
Average Tunnel Temperature	99 degrees Fahrenheit
Average Delta p	0.035 inches H2O
Total Sample Volume - Vm Average Gas Meter Temperature Average Gas Velocity in Dilution Tunnel - vs Average Gas Flow Rate in Dilution Tunnel - Qsd Total Sample Volume (Standard Conditions) - Vms	89.80 cubic feet 103 degrees Fahrenheit 12.79 feet/second 8147.48 dscf/hour 83.13 dscf
Total Particulates - mn Average Delta H Total Time of Test	23.8 mg 0.75 inches H2O 170 minutes

Final Laboratory Report - Method 5G Dilution Tunnel Particulate Calculations

Client Name: Morso Equipment Numbers: _____ Run #: 1
 Model: 8100 Date: 10/06/05
 Project No.: 192-S-07-3
 Tracking No.: 786

Sample Component	Reagent	Filter # or Volume, ml	Weights			
			Final, mg	Tare, mg	Blank, mg/ml	Particulate, mg
A. Front filter catch	Filter	M832	565.2	547.9		17.3
B. Rear filter catch	Filter	M831	548.8	547.6		1.2
C. Rinse of probe and filter assembly	Acetone	95	109919.8	109914.4	0.0013	5.3

Total Particulate, mg :	23.8
-------------------------	------

Component	Equations:
A. Front filter catch	Final (mg) - Tare (mg) = Particulate, mg
B. Rear filter catch	Final (mg) - Tare (mg) = Particulate, mg
C. Rinse of probe and filter assembly	(Final, mg - Tare, mg) - (Blank, mg/ml x Volume, ml) = Particulate, mg

Analyst: B. D. Date: 10-12-05

STOVE TEMPERATURE TEST DATA - METHOD 5G

Client/Model: Morso Project #: 192-S-07-3 Tracking #: 786 Page 1 of 1
 Date: 10-6-05 Test Crew: BAVUS Run #: 1
 OMNI Equipment ID #: _____

Time	Fuel Weight	Delta Weight	Stack Draft	Coal Bed: _____				Range: <u>1.4-1.7</u>				Actual: _____	
				Ambient	Top	Bottom	Back	Left	Right	Flue	Catalyst		
0	4.6	—	-0.67	72	684	114	802	525	584	513	513	MA	
10	3.5	1.1	-0.52	70	618	121	669	548	589	365	365		
20	2.9	0.6	-0.49	69	592	119	637	534	569	340	340		
30	2.3	0.6	-0.46	68	556	118	577	513	542	312	312		
40	2.1	0.2	-0.41	73	507	120	511	483	499	282	282		
50	1.9	0.2	-0.37	73	459	119	455	451	457	258	258		
60	1.9	0.0	-0.35	72	426	119	420	430	431	244	244		
70	1.7	0.2	-0.32	74	401	119	397	415	413	234	234		
80													
90													
00													
10													
20													
30													
40													
50													
60													
70													
80													
90													
AVG													

Technician signature: BAVUS Date: 10-12-05

2-7 of 2-34

FUEL DATA

Client: Morso

Model: 8100

Project #: 192-S-07-3 Tracking #: 786

Date: 10-6-05 Test Crew: B. Davis

Run #: 1

OMNI Equipment ID #: _____

FUEL LOAD PREPARED BY: B. Davis

FUEL: DOUGLAS-FIR SPECIES, UNTREATED, AIR-DRIED, STANDARD GRADE OR BETTER, DIMENSIONAL LUMBER.

PRE-BURN FUEL					
MOISTURE CONTENT (METER -- DRY BASIS)					
CALIBRATION:	Cal Value (1) = 12%	Actual Reading	<u>12</u>		
	Cal Value (2) = 22%	Actual Reading	<u>22</u>		
Piece	Length	Readings		Type	
1	<u>8</u> ft	<u>19.4</u>	<u>20.4</u>	<u>19.8</u>	<u>2x4</u>
2	<u>8</u> ft	<u>23.0</u>	<u>21.8</u>	<u>22.4</u>	<u>2x4</u>
3	ft				
Length of cut pieces: <u>4 @ 10</u> <u>6 @ 12.5</u> inches					
Pre-Burn Fuel Average Moisture: <u>21.13</u>					
Time (clock): <u>0915</u> Room Temperature (F): <u>68</u> Initials: <u>BD</u>					

TEST FUEL				
FUEL TYPE AND AMOUNT:	<u>2x4</u>	<u>4</u>	<u>4x4</u>	<u>0</u>
CALCULATED LOAD WEIGHT:	<u>7.35</u>			
		ACTUAL LOAD WEIGHT:	<u>6.8</u>	(2x4)
FUEL PIECE LENGTH:	<u>12.5</u>		<u>6.8</u>	(4x4)
			<u>6.8</u>	Total
MOISTURE CONTENT (METER -- DRY BASIS)				
PIECE	READINGS			TYPE
1	<u>20.6</u>	<u>19.7</u>	<u>18.9</u>	<u>2x4</u>
2	<u>19.0</u>	<u>20.2</u>	<u>19.1</u>	<u>2x4</u>
3	<u>20.0</u>	<u>20.2</u>	<u>20.2</u>	<u>2x4</u>
4	<u>20.2</u>	<u>20.0</u>	<u>20.5</u>	<u>2x4</u>
5				
6				
7				
8				
9				
10				
OVERALL TEST FUEL LOAD MOISTURE AVERAGE: <u>19.88</u>				
Time (clock): <u>11:00</u> Room Temperature (F): <u>70</u> Initials: <u>BD</u>				

Technician signature: BD Date: 10-12-05

Run Notes

Client/Model: Morso

Model: 8100

Project #: 192-S-07-3

Tracking Number: 786

Run #: 1 Date: 10-6-05


Test Crew: B. Davis

OMNI Equipment ID Numbers: _____

PREBURN

DESCRIBE OR SKETCH AIR OR THERMOMSTAT SETTINGS BELOW: (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:



SECONDARY: fixed

TERTIARY: NA


FAN: NA

PREBURN SETTINGS AND ACTIVITIES

TIME	AIR (THERMO) CHANGES PRIMARY/SECONDARY/TERTIARY	FAN SETTING CHANGE	ADD FUEL + WT.	ADD FUEL - WT.	RAKE COAL	COMMENT
0	Test setting					
71					X	

TEST

TEST FUEL CONFIGURATION SKETCH
(INDICATE VIEW ANGLE)




START UP PROCEDURES

BYPASS: NA
 FUEL LOADING: By 30 sec
 DOOR: cracked open until 4:10 then closed
 PRIMARY AIR: fully open until 4:15 then slowly set to test setting @ 5:00
 OTHER: NA

DESCRIBE OR SKETCH TEST SETTINGS BELOW: (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:



SECONDARY: NA fixed

TERTIARY: NA

FAN: NA

Technician signature: B. Davis Date: 10-12-05

Supplemental Data EPA 5G/5H

Client: Morso

Model: 8100

Project No.: 192-S-07-3

Tracking No.: 786

Date: 10-6-05

Run No.: 1 Booth: 1

Test Crew: B. Davis

Start Time: 13:44 Stop Time: 16:34

OMNI Equipment #'s: _____

Gas Analyzer Train Leak Check:

Stack:

Initial: NA

Final: _____

Dilution Tunnel (Method 5G Only):

Initial: _____

Final: _____

Calibrations: Span Gas CO₂: _____ O₂: _____ CO: _____ CO₂(DT): _____

Time	N ₂ Span	N ₂ Span	N ₂ Span	N ₂ Span	N ₂ Span	N ₂ Span	N ₂ Span
	<u>NA</u>						
O ₂							
CO ₂							
CO							
CO ₂ (DT)							

Stack Diameter (inches): 6

Air Velocity (ft/min): Initial: 250 ft/min Final: 250 ft/min

Scale Audit (lbs.): Pretest: 10.0 Post Test: 10.0

Induced Draft: 0.0 %Smoke Capture: 100%

Pitot Tube Leak Test: Pre: 0.0 @ 3.0 Post: 0.0 @ 3.1

Flue Pipe Cleaned Prior to First Test in Series: Date: 10-5-05 Initials: BR

	Initial	Middle	Ending
Pb (in. Hg)	<u>29.84</u>	<u>29.83</u>	<u>29.83</u>
Room Temp (°F)	<u>73</u>	<u>73</u>	<u>75</u>

Technician signature: B. Davis Date: 10-12-05

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

Run 2

Wood Heater Test Data - EPA Method 5G

Run: 2

Manufacturer: Moroso
 Model: 8100
 Tracking No.: 786
 Project No.: 192-S-07-3
 Test Date: 06-Oct-05
 Beginning Clock Time: 18:01
 Recording Interval: 10 min.
 Total Sampling Time: 80 min.

Velocity Traverse Data								
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.7	Pt.8
Initial dP	0.038	0.038	0.044	0.036	0.028	0.042	0.036	0.028
Initial Temp	132	132	132	132	131	131	131	131

PM Control Module: 21
 Dilution Tunnel MW(dry): 29.00 lb/lb-mole
 Dilution Tunnel MW(wet): 28.56 lb/lb-mole
 Dilution Tunnel H₂O: 4.00 percent
 Dilution Tunnel Static: -0.700 "H₂O"
 Pitot Tube Cp: 0.99
 Meter Box Y Factor: 0.988
 Barometric Pressure: 29.82 "Hg

Signature/Date: BD 11-1-05
 Tunnel Velocity: 13.33 ft/sec.
 Initial Tunnel Flow: 134.4 scfm
 Average Tunnel Flow: 135.9 scfm
 Tunnel Area: 0.196 ft²
 Post-Test Leak Check: .004@4 cfm@"Hg
 Fuel Moisture (dry basis) 21.27 %
 Total Particulate: 34.6 mg
 Filler Holder No.: A

OMNI Equipment Numbers:

Elapsed Time	Particulate Sampling Data										Fuel Weight, lb										Wood Heater Temperature Data, oF										Stack	
	Gas Meter Cubic Feet	Sample Rate, cfm	Orifice dH	Meter oF	Meter In. Hg.	Dilution Tunnel Temp.	Dilution Tunnel dP	Pro. Rate (10%)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Average Surface	Stack	Filter	Impinger exit	Ambient	Draft In. H ₂ O											
0	527.100		0.75	76	0	132	0.036	7.5			633	134	663	594	606	526.0	458	76	69	74	-0.058											
10	532.280	0.52	0.75	85	1	133	0.036	5.5	-2	653	141	763	552	570	535.8	598	79	43	72	-0.075												
20	537.450	0.52	0.75	93	1	133	0.036	3.1	-2.4	719	142	856	548	613	575.6	607	81	41	72	-0.075												
30	542.680	0.52	0.75	97	1	132	0.036	1.3	-1.8	755	136	894	573	660	603.6	609	82	41	74	-0.074												
40	547.850	0.52	0.75	100	1	122	0.036	0.8	-0.5	700	132	780	596	657	573.0	515	82	42	75	-0.065												
50	553.120	0.53	0.75	102	1	115	0.036	0.6	-0.2	619	128	661	584	607	519.8	458	81	42	74	-0.060												
60	558.500	0.54	0.75	103	1	112	0.036	0.4	-0.2	555	127	591	556	562	478.2	425	81	43	74	-0.057												
70	563.670	0.52	0.75	104	1	109	0.036	0.2	-0.2	506	125	536	529	526	444.4	397	80	44	75	-0.055												
80	568.878	0.52	0.75	105	1	106	0.036	0.0	-0.2	474	125	500	508	500	421.4	380	80	44	72	-0.053												
Avg/Total	41,778	0.52	0.75	96.11		121.50	0.036	100.21							105		80.22	45.44			-0.064											

Run 2
2-12 of 2-31

Wood Heater Test Data - EPA Method 5G

Manufacturer: Morso
 Model: 8100
 Project No.: 786
 Tracking No.: 192-S-07-3
 Run: 2
 Test Date: 10/06/05

Burn Rate	2.10 kg/hr dry
Particulate Concentration (dry-standard) Particulate Emission Rate Adjusted Emissions	0.00088 grams/dscf 7.21 grams/hour 9.38 grams/hour
Average Tunnel Temperature	122 degrees Fahrenheit
Average Delta p	0.036 inches H2O
Total Sample Volume - Vm Average Gas Meter Temperature Average Gas Velocity in Dilution Tunnel - vs Average Gas Flow Rate in Dilution Tunnel - Qsd Total Sample Volume (Standard Conditions) - Vms	41.78 cubic feet 96 degrees Fahrenheit 13.33 feet/second 8155.14 dscf/hour 39.13 dscf
Total Particulates - mn Average Delta H Total Time of Test	34.6 mg 0.75 inches H2O 80 minutes

STOVE TEMPERATURE TEST DATA - METHOD 5G

Page 1 of 1

Client/Model: Morse 8100 Project #: 192-S-07-3 Tracking #: 716
 Date: 10-6-05 Test Crew: B. Davis Run #: 2
 OMNI Equipment ID #: _____

Time	Fuel Weight	Delta Weight	Stack Draft	Coal Bed:					Right	Flue	Catalyst
				Ambient	Top	Bottom	Back	Left			
0	11.9	—	-0.050	76	456	102	528	396	431	383	NR
10	10.9	1.0	-0.068	74	461	104	538	395	412	572	
20	8.3	2.7	-0.075	72	628	108	751	444	480	608	
30	5.9	2.4	-0.083	73	691	111	807	495	542	670	
40	3.5	2.4	-0.081	75	769	114	880	557	611	711	
50	2.2	1.3	-0.075	73	782	120	909	593	649	617	
60	1.7	0.5	-0.065	72	702	127	764	606	638	510	
70	1.5	0.2	-0.062	74	651	132	691	597	612	475	
80											
90											
00											
10											
20											
30											
40											
50											
60											
70											
80											
90											
AVG											

Actual: 7.5
Coal Bed: 1.5

Range: 1.5 - 1.8
TEMPERATURES (oF)

Technician signature: B. Davis Date: 10-12-05

2-15 of 2-34

FUEL DATA

Client: Morso

Model: 8100

Project #: 192-S-07-3 Tracking #: 786

Date: 10-6-05

Test Crew: B. Daus

Run #: 2

OMNI Equipment ID #: _____

FUEL LOAD PREPARED BY: B. Daus

FUEL: DOUGLAS-FIR SPECIES, UNTREATED, AIR-DRIED, STANDARD GRADE OR BETTER, DIMENSIONAL LUMBER.

PRE-BURN FUEL
MOISTURE CONTENT (METER -- DRY BASIS)

CALIBRATION: Cal Value (1) = 12% Actual Reading 12
Cal Value (2) = 22% Actual Reading 22

Piece	Length	Readings		Type
1	<u>8</u> ft	<u>22.4</u>	<u>21.2</u>	<u>2x4</u>
2	<u>8</u> ft	<u>19.1</u>	<u>20.0</u>	<u>2x4</u>
3	<u>4 @ 10</u> ft			<u>2x4</u>

Length of cut pieces: 8 @ 12.5 inches Pre-Burn Fuel Average Moisture: 20.62

Time (clock): 4:15 Room Temperature (F): 75 Initials: BD

TEST FUEL

FUEL TYPE AND AMOUNT: 2x4 7 4x4 0

CALCULATED LOAD WEIGHT: 7.35 ACTUAL LOAD WEIGHT: 7.5 (2x4)
0 (4x4)
7.5 Total

FUEL PIECE LENGTH: 12.5

MOISTURE CONTENT (METER -- DRY BASIS)

PIECE	READINGS			TYPE
1	<u>21.1</u>	<u>21.4</u>	<u>19.3</u>	<u>2x4</u>
2	<u>20.1</u>	<u>18.8</u>	<u>18.8</u>	<u>2x4</u>
3	<u>22.7</u>	<u>23.2</u>	<u>23.8</u>	<u>2x4</u>
4	<u>22.0</u>	<u>22.0</u>	<u>22.0</u>	<u>2x4</u>
5				
6				
7				
8				
9				
10				

OVERALL TEST FUEL LOAD MOISTURE AVERAGE: 21.27

Time (clock): 17:05 Room Temperature (F): 75 Initials: BD

Technician signature: B. Daus Date: 10-12-05

Run Notes

Client/Model: Morso

Model: 8100

Project #: 192-S-07-3

Tracking Number: 786

Run #: 2

Date: 10-6-05


Test Crew: BOA's

OMNI Equipment ID Numbers: _____

PREBURN

DESCRIBE OR SKETCH AIR OR THERMOMSTAT SETTINGS BELOW: (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:



SECONDARY: fixed

TERTIARY: NA


FAN: NA

PREBURN SETTINGS AND ACTIVITIES

TIME	AIR (THERMO) CHANGES PRIMARY/SECONDARY/TERTIARY	FAN SETTING CHANGE	ADD FUEL + WT.	ADD FUEL - WT.	RAKE COAL	COMMENT
0 66	Test setting				x	→

TEST

TEST FUEL CONFIGURATION SKETCH
(INDICATE VIEW ANGLE)



START UP PROCEDURES

BYPASS: NA

FUEL LOADING by 25 sec


DOOR: cracked open until 2:10 then closed

PRIMARY AIR: fully opened full 5:00

OTHER: NA

DESCRIBE OR SKETCH TEST SETTINGS BELOW: (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:



SECONDARY: fixed

TERTIARY: NA

FAN: NA

Technician signature: BOA's

Date: 10-12-05

Supplemental Data EPA 5G/5H

Client: Morso

Model: 8100

Project No.: 192-S-07-3

Tracking No.: 786

Date: 10-6-05 Run No.: 2 Booth: 1

Test Crew: B. Davis Start Time: 18:01 Stop Time: 20:21

OMNI Equipment #'s: _____

Gas Analyzer Train Leak Check:

Stack:

Initial: NA

Final: _____

Dilution Tunnel (Method 5G Only):

Initial: _____

Final: _____

Calibrations: Span Gas CO₂: _____ O₂: _____ CO: _____ CO₂(DT): _____

Time	N ₂ Span	N ₂ Span	N ₂ Span	N ₂ Span	N ₂ Span	N ₂ Span	N ₂ Span
	<u>NA</u>						
O ₂							
CO ₂							
CO							
CO ₂ (DT)							

Stack Diameter (inches): 6"

Air Velocity (ft/min): Initial: 250 ft/min Final: 250 ft/min

Scale Audit (lbs.): Pretest: 10.0 Post Test: 10.0

Induced Draft: 0.0 % Smoke Capture: 100%

Pitot Tube Leak Test: Pre: 0.0 @ 3.2 Post: 0.0 @ 3.1

Flue Pipe Cleaned Prior to First Test in Series: Date: 10-5-05 Initials: BD

	Initial	Middle	Ending
Pb (in. Hg)	<u>29.82</u>	<u>29.82</u>	<u>29.82</u>
Room Temp (°F)	<u>74</u>	<u>74</u>	<u>72</u>

Technician signature: BD

Date: 10-12-05

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

Run 3

Wood Heater Test Data - EPA Method 5G

Manufacturer: Morso
 Model: 8100
 Project No.: 786
 Tracking No.: 192-S-07-3
 Run: 3
 Test Date: 10/07/05

Burn Rate	1.42 kg/hr dry
Particulate Concentration (dry-standard) Particulate Emission Rate Adjusted Emissions	0.00031 grams/dscf 2.66 grams/hour 4.09 grams/hour
Average Tunnel Temperature	104 degrees Fahrenheit
Average Delta p	0.039 inches H2O
Total Sample Volume - Vm Average Gas Meter Temperature Average Gas Velocity in Dilution Tunnel - vs Average Gas Flow Rate in Dilution Tunnel - Qsd Total Sample Volume (Standard Conditions) - Vms	57.38 cubic feet 94 degrees Fahrenheit 13.51 feet/second 8540.94 dscf/hour 54.02 dscf
Total Particulates - mn Average Delta H Total Time of Test	16.8 mg 0.75 inches H2O 110 minutes

FUEL DATA

Client: Morso

Model: 8100

Project #: 192-S-07-3 Tracking #: 786

Date: 10-7-05 Test Crew: B Davis

Run #: 3

OMNI Equipment ID #: _____

FUEL LOAD PREPARED BY: B Davis

FUEL: DOUGLAS-FIR SPECIES, UNTREATED, AIR-DRIED, STANDARD GRADE OR BETTER, DIMENSIONAL LUMBER.

PRE-BURN FUEL
MOISTURE CONTENT (METER -- DRY BASIS)

CALIBRATION: Cal Value (1) = 12% Actual Reading 12
Cal Value (2) = 22% Actual Reading 22

Piece	Length	Readings			Type
1	<u>8</u> ft	<u>23.2</u>	<u>22.4</u>	<u>22.8</u>	<u>2x4</u>
2	<u>8</u> ft	<u>22.4</u>	<u>24.0</u>	<u>23.6</u>	<u>2x4</u>
3	ft				

Length of cut pieces: 4 @ 10 inches
6 @ 12.5 inches

Pre-Burn Fuel Average Moisture: 23.07

Time (clock): 0850 Room Temperature (F): 67 Initials: BD

TEST FUEL

FUEL TYPE AND AMOUNT: 2x4 4 4x4 Ø

CALCULATED LOAD WEIGHT: 735 ACTUAL LOAD WEIGHT: 69 (2x4)
Ø (4x4)
69 Total

FUEL PIECE LENGTH: 12.5

MOISTURE CONTENT (METER -- DRY BASIS)

PIECE	READINGS			TYPE
1	<u>19.1</u>	<u>18.8</u>	<u>20.0</u>	<u>2x4</u>
2	<u>19.5</u>	<u>21.0</u>	<u>20.9</u>	<u>2x4</u>
3	<u>21.4</u>	<u>19.3</u>	<u>20.2</u>	<u>2x4</u>
4	<u>19.5</u>	<u>18.3</u>	<u>19.9</u>	<u>2x4</u>
5				
6				
7				
8				
9				
10				

OVERALL TEST FUEL LOAD MOISTURE AVERAGE: 19.83

Time (clock): 0950 Room Temperature (F): 70 Initials: BD

Technician signature: B Davis

Date: 10/18/05

Run Notes

Client/Model: Morso

Model: 8100

Project #: 192-S-07-3

Tracking Number: 786

Run #: 3 Date: 10-7-05


Test Crew: B. Davis

OMNI Equipment ID Numbers: _____

PREBURN

DESCRIBE OR SKETCH AIR OR THERMOMSTAT SETTINGS BELOW: (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:



SECONDARY: fixed

TERTIARY: NA


FAN: NA

PREBURN SETTINGS AND ACTIVITIES

TIME	AIR (THERMO) CHANGES PRIMARY/SECONDARY/TERTIARY	FAN SETTING CHANGE	ADD FUEL + WT.	ADD FUEL - WT.	RAKE COAL	COMMENT
076	Test setting				X	

TEST

TEST FUEL CONFIGURATION SKETCH
(INDICATE VIEW ANGLE)



START UP PROCEDURES

BYPASS: NA
 FUEL LOADING: by 20 sec
 DOOR: cracked open until 2:15 then closed
 PRIMARY AIR: set test setting full 5:00

OTHER: NA

DESCRIBE OR SKETCH TEST SETTINGS BELOW: (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:
Same as Above

SECONDARY: fixed

TERTIARY: NA

FAN: NA

Technician signature: B. Davis

Date: 10-12-05

Supplemental Data EPA 5G/5H

Client: Morso

Model: 8100

Project No.: 192-S-07-3

Tracking No.: 786

Date: 10-7-05 Run No.: 3 Booth: 1

Test Crew: B. Davis Start Time: 10:32 Stop Time: 12:22

OMNI Equipment #'s: _____

Gas Analyzer Train Leak Check:

Stack:

Dilution Tunnel (Method 5G Only):

Initial: NA

Initial: _____

Final: _____

Final: _____

Calibrations: Span Gas CO₂: _____ O₂: _____ CO: _____ CO₂(DT): _____

Time	N ₂ Span	N ₂ Span	N ₂ Span	N ₂ Span	N ₂ Span	N ₂ Span	N ₂ Span
	<u>NA</u>						
O ₂							
CO ₂							
CO							
CO ₂ (DT)							

Stack Diameter (inches): 6"

Air Velocity (ft/min): Initial: 250 ft/min Final: 250 ft/min

Scale Audit (lbs.): Pretest: 10.0 Post Test: 10.0

Induced Draft: 0.0 %Smoke Capture: 100%

Pitot Tube Leak Test: Pre: 0.0 @ 3.4 Post: 0.0 @ 3.1

Flue Pipe Cleaned Prior to First Test in Series: Date: 10-5-05 Initials: BD

	Initial	Middle	Ending
Pb (in. Hg)	<u>29.84</u>	<u>29.84</u>	<u>29.85</u>
Room Temp (°F)	<u>84</u>	<u>71</u>	<u>69</u>

Technician signature: B. Davis

Date: 10-12-05

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

Run 4

Wood Heater Test Data - EPA Method 5G

Run:	4
Manufacturer:	Morso
Model:	8100
Tracking No.:	786
Project No.:	192-S-07-3
Test Date:	07-Oct-05
Beginning Clock Time:	15:40
Recording Interval:	10 min.
Total Sampling Time:	140 min.

Velocity Traverse Data							
	Pt.1	Pt.2	Pt.3	Pt.4	Pt.5	Pt.6	Pt.8
Initial dP	0.030	0.050	0.042	0.032	0.028	0.046	0.034
Initial Temp.	93	93	93	93	93	93	93

Signature/Date:	BD	11-1-05
Tunnel Velocity:	13.52	ft/sec.
Initial Tunnel Flow:	143.7	scfm
Average Tunnel Flow:	144.1	scfm
Tunnel Area:	0.196	ft ²
Post-Test Leak Check:	0.004@5	cfm@%Hg
Fuel Moisture (dry basis)	20.16	%
Total Particulate:	11.2	mg
Filter Holder No.:	A	

PM Control Module:	21			
Dilution Tunnel MW(dry):	29.00	lb/lb-mole		
Dilution Tunnel MW(wet):	28.56	lb/lb-mole		
Dilution Tunnel H ₂ O:	4.00	percent		
Dilution Tunnel Static:	-0.700	"H ₂ O		
Pitot Tube Cp:	0.99			
Meter Box Y Factor:	0.988			
Barometric Pressure:	Begin	Middle	End	Average
	29.83	29.83	29.83	29.83

OMNI Equipment Numbers:

Elapsed Time	Particulate Sampling Data										Fuel Weight, lb				Wood Heater Temperature Data, oF						Stack	
	Gas Meter Cubic Feet	Sample Rate, cfm	Orifice dH	Meter oF	Meter In. Hg.	Dilution Tunnel Temp.	Dilution Tunnel dP	Pro. Rate (10%)	Scale Reading	Weight Change	Firebox Top	Firebox Bottom	Firebox Back	Firebox Left	Firebox Right	Average Surface	Stack	Filter	Impinger exit	Ambient	Draft In. H ₂ O	
0	626.900		0.75	77	0	93	0.039	7.0			442	109	446	461	453	382.2	292	71	66	68	-0.045	
10	632.090	0.52	0.75	82	1	113	0.039	5.4	-1.6	483	108	547	443	439	404.0	425	76	49	68	68	-0.057	
20	637.250	0.52	0.75	90	1	104	0.039	4.3	-1.1	511	107	607	444	463	426.4	412	76	47	69	69	-0.058	
30	642.510	0.53	0.75	95	1	105	0.039	3.0	-1.3	558	106	670	461	502	459.4	433	76	47	70	70	-0.058	
40	647.630	0.51	0.75	98	1	105	0.039	1.9	-1.1	594	105	706	484	534	484.6	439	77	47	71	71	-0.058	
50	652.900	0.53	0.75	100	1	103	0.039	1.3	-0.6	483	104	644	503	547	456.2	385	77	48	72	72	-0.052	
60	658.120	0.52	0.75	102	1	98	0.039	1.2	-0.1	530	103	555	502	522	442.4	340	77	49	71	71	-0.048	
70	663.370	0.53	0.75	102	1	96	0.039	1.0	-0.2	489	103	504	485	494	415.0	318	77	49	71	71	-0.045	
80	668.570	0.52	0.75	103	1	95	0.039	0.8	-0.2	455	103	468	467	469	392.4	303	76	50	71	71	-0.042	
90	673.830	0.53	0.75	103	1	93	0.039	0.7	-0.1	429	102	443	452	451	375.4	292	76	49	70	70	-0.040	
100	679.200	0.54	0.75	104	1	91	0.039	0.5	-0.2	408	103	423	439	437	362.0	283	76	50	72	72	-0.038	
110	684.330	0.51	0.75	103	1	90	0.039	0.4	-0.1	394	103	410	430	428	353.0	277	76	50	70	70	-0.038	
120	689.610	0.53	0.75	103	1	89	0.039	0.3	-0.1	382	102	399	422	418	344.6	271	75	50	68	68	-0.037	
130	694.820	0.52	0.75	103	1	88	0.039	0.1	-0.2	373	102	390	415	411	338.2	266	74	50	70	70	-0.037	
140	700.060	0.52	0.75	102	1	88	0.039	0.0	-0.1	363	101	378	406	402	330.0	261	74	50	69	69	-0.036	
Avg/Total	73.160	0.52	0.75	97.80		96.73	0.039	100.53							52	75.60	50.07				-0.046	

Run 4
2-28 of 2-29

Wood Heater Test Data - EPA Method 5G

Manufacturer: Morso
 Model: 8100
 Project No.: 786
 Tracking No.: 192-S-07-3
 Run: 4
 Test Date: 10/07/05

Burn Rate	1.13 kg/hr dry
Particulate Concentration (dry-standard) Particulate Emission Rate Adjusted Emissions	0.00016 grams/dscf 1.42 grams/hour 2.43 grams/hour
Average Tunnel Temperature	97 degrees Fahrenheit
Average Delta p	0.039 inches H2O
Total Sample Volume - Vm Average Gas Meter Temperature Average Gas Velocity in Dilution Tunnel - vs Average Gas Flow Rate in Dilution Tunnel - Qsd Total Sample Volume (Standard Conditions) - Vms	73.16 cubic feet 98 degrees Fahrenheit 13.52 feet/second 8645.89 dscf/hour 68.33 dscf
Total Particulates - mn Average Delta H Total Time of Test	11.2 mg 0.75 inches H2O 140 minutes

STOVE TEMPERATURE TEST DATA - METHOD 5G

Page 1 of 1

Client/Model: Morsco Project #: 192-S-07-3 Tracking #: 786
 Date: 10-7-05 Test Crew: B. Davis Run #: 4
 OMNI Equipment ID #: _____

Time	Fuel Weight	Delta Weight	Stack Draft	Coal Bed:					Actual:		
				Ambient	Top	Bottom	Back	Left		Right	Flue
0	5.8		-0.80	71	728	107	882	542	598	648	
10	4.3	1.5	-0.63	70	684	109	766	565	607	456	
20	3.2	1.1	-0.60	69	634	111	703	559	590	408	
30	2.6	0.6	-0.53	68	601	110	656	549	576	367	
40	2.3	0.3	-0.47	67	556	109	590	528	545	332	
50	2.2	0.1	-0.44	67	513	109	532	506	514	305	
60	1.8	0.4	-0.40	69	471	109	482	480	477	285	
70	1.7	0.1	-0.38	68	448	109	456	463	456	275	
80											
90											
00											
10											
20											
30											
40											
50											
60											
70											
80											
90											
AVG:											

Technician signature: B. Davis Date: 10-12-05

7-31 of 7-34

FUEL DATA

Client: Morso

Model: 8100

Project #: 192-S-07-3 Tracking #: 786

Date: 10-7-05 Test Crew: B. Davis Run #: 4

OMNI Equipment ID #: _____

FUEL LOAD PREPARED BY: B. Davis

FUEL: DOUGLAS-FIR SPECIES, UNTREATED, AIR-DRIED, STANDARD GRADE OR BETTER, DIMENSIONAL LUMBER.

PRE-BURN FUEL					
MOISTURE CONTENT (METER -- DRY BASIS)					
CALIBRATION:	Cal Value (1) = 12%	Actual Reading	<u>12</u>		
	Cal Value (2) = 22%	Actual Reading	<u>22</u>		
Piece	Length	Readings		Type	
1	<u>8</u> ft	<u>23.3</u>	<u>23.2</u>	<u>21.0</u>	<u>2x4</u>
2	<u>8</u> ft	<u>18.5</u>	<u>20.1</u>	<u>19.4</u>	<u>2x4</u>
3	<u>4</u> ft				
Length of cut pieces: <u>6</u> or <u>10</u> inches					
Pre-Burn Fuel Average Moisture: <u>20.92</u>					
Time (clock): <u>12:55</u> Room Temperature (F): <u>71</u> Initials: <u>BA</u>					

TEST FUEL					
FUEL TYPE AND AMOUNT: <u>2x4</u> <u>4</u> <u>4x4</u> <u>0</u>					
CALCULATED LOAD WEIGHT: <u>7.35</u>		ACTUAL LOAD WEIGHT: <u>7.0</u> (2x4)			
		<u>0</u> (4x4)			
FUEL PIECE LENGTH: <u>12.5</u>		<u>7.0</u> Total			
MOISTURE CONTENT (METER -- DRY BASIS)					
PIECE	READINGS			TYPE	
1	<u>18.8</u>	<u>19.2</u>	<u>19.3</u>	<u>2x4</u>	
2	<u>19.5</u>	<u>19.7</u>	<u>18.6</u>	<u>2x4</u>	
3	<u>21.9</u>	<u>22.0</u>	<u>23.0</u>	<u>2x4</u>	
4	<u>20.1</u>	<u>20.1</u>	<u>19.7</u>	<u>2x4</u>	
5					
6					
7					
8					
9					
10					
OVERALL TEST FUEL LOAD MOISTURE AVERAGE: <u>20.16</u>					
Time (clock): <u>15:10</u> Room Temperature (F): <u>72</u> Initials: <u>BA</u>					

Technician signature: B. Davis Date: 10-20-05

Run Notes

Client/Model: Morso

Model: 8100

Project #: 192-S-07-3

Tracking Number: 786

Run #: 4 Date: 10-7-05


Test Crew: BDAWS

OMNI Equipment ID Numbers: _____

PREBURN

DESCRIBE OR SKETCH AIR OR THERMOMSTAT SETTINGS BELOW: (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:



SECONDARY: fixed

TERTIARY: NA


FAN: NA

PREBURN SETTINGS AND ACTIVITIES

TIME	AIR (THERMO) CHANGES PRIMARY/SECONDARY/TERTIARY	FAN SETTING CHANGE	ADD FUEL + WT.	ADD FUEL - WT.	RAKE COAL	COMMENT
0	<u>Test setting</u>					
51				<u>.3</u>		
68					<u>X</u>	

TEST

TEST FUEL CONFIGURATION SKETCH
(INDICATE VIEW ANGLE)




START UP PROCEDURES

BYPASS: NA
 FUEL LOADING: by 25 sec
 DOOR: cracked open until 4:00 then closed
 PRIMARY AIR: fully open until 4:00 then slowly set to test setting by 5:00
 OTHER: NA

DESCRIBE OR SKETCH TEST SETTINGS BELOW: (SETTINGS MUST BE ACCURATE AND REPRODUCIBLE)

PRIMARY:



SECONDARY: fixed

TERTIARY: NA

FAN: NA

Technician signature: BDAWS Date: 10-12-05

Supplemental Data EPA 5G/5H

Client: Morso

Model: 8100

Project No.: 192-S-07-3

Tracking No.: 786

Date: 10-7-05 Run No.: 4 Booth: 1

Test Crew: B. Davis Start Time: 15:40 Stop Time: 18:00

OMNI Equipment #'s: _____

Gas Analyzer Train Leak Check:

Stack:

Dilution Tunnel (Method 5G Only):

Initial: NA

Initial: _____

Final: _____

Final: _____

Calibrations: Span Gas CO₂: _____ O₂: _____ CO: _____ CO₂(DT): _____

Time	N ₂ Span	N ₂ Span	N ₂ Span	N ₂ Span	N ₂ Span	N ₂ Span	N ₂ Span
	<u>NA</u>						
O ₂							
CO ₂							
CO							
CO ₂ (DT)							

Stack Diameter (inches): 6"

Air Velocity (ft/min): Initial: < 50 ft/min Final: < 50 ft/min

Scale Audit (lbs.): Pretest: 10.0 Post Test: 10.0

Induced Draft: 0.0 %Smoke Capture: 100%

Pitot Tube Leak Test: Pre: 0.0 @ 3.0 Post: 0.0 @ 3.2

Flue Pipe Cleaned Prior to First Test in Series: Date: 10-5-05 Initials: ML

	Initial	Middle	Ending
Pb (in. Hg)	<u>29.82</u>	<u>29.83</u>	<u>29.83</u>
Room Temp (°F)	<u>68</u>	<u>71</u>	<u>69</u>

Technician signature: B. Davis

Date: 10-12-05

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

Section 3

Drawings and Fuel Photographs

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

Morsø Jernstøberi A/S
Model: 8140


Run 1 - Fuel



Run 1 - Newly Loaded Stove



Run 2 - Fuel



Run 2 - Newly Loaded Stove



Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

Morsø Jernstøberi A/S
Model: 8140

Run 3 - Fuel



Run 3 – Newly Loaded Stove



Run 4 - Fuel




Run 4 – Newly Loaded Stove



Firebox Volume

Moroso 8100 series



	H	W	D	ft ³
$V_1 =$	10.25	13.75	10.25	= .836
$V_2 =$	5.25	13.75	10.25	.214
	2			1.05 ft ³

Fuel load = 7.35 lbs
 $\pm 10\%$ 6.7 - 8.1

Project Number: 192-S-07-3

Technician Initialed: BR

Date: 11-1-05

OMNI ID: 786

Morsø 8100 series NA - Drawings and data

Nykøbing Mors d. 27.10.2005

PARTS:	DRAWINGS:	DATE:
Base plate, inside	8100-01	22.11.04
Top frame	8100-02	22.11.04
Door	8100-03	18.11.04
Side plate, inside	8100-04	16.11.04
Rear plate, inside	8100-05	16.11.04
Top plate, inside	8100-06	17.11.04
Top frame	8100-07	26.10.05
Side plate, outside	8100-08	24.11.04
Rear plate, outside	8100-09	24.11.04
Top plate, outside	8100-10	11.11.04
Socle, high	8100-11	22.11.04
Base plate, outside	8100-12	22.11.04
Intermediate frame	8100-13	23.11.04
Air canal, front	8100-15	23.11.04
Air canal, rear	8100-16	18.11.04
Air canal, top	8100-17	18.11.04
Leg	8100-18	24.11.04
Drawer, front	8100-19	25.11.04
Cover	8100-20	25.11.04
Cover plate, rear, for leg	8100-21	24.11.04
Ceramic glass	8100-24	29.09.04
Brick, back	8100-26	25.01.05
Brick, side, right	8100-27	12.09.05
Brick, side, left	8100-28	07.09.05
Fitting f. hinge pin	8100-30	13.01.05
Distance tube	8100-31	18.01.05
Distance tube	8100-32	18.01.05
Radiant shielding, bottom	8100-33	19.01.05
Closing plate f. sek. draught control	8100-37	18.01.05
Handle f. sek. draught control	8100-38	21.12.04
Tertiary box	8100-41	18.01.05
Baffle plate, bottom	8100-42	07.09.05
Baffle plate, top	8100-43	19.09.05
Fitting plate f. baffle	8100-50	18.01.05
Ash tray	8100-52	24.01.05
Cover plate f. drawer section	8100-60	20.01.05
Fitting f. closing plate	8100-63	25.02.05
Drawer, box	8100-64	21.01.05
Radiant shielding, rear	8100-65	19.01.05
Mounting plate, drawer section	8100-66	21.01.05
Bush	8100-71	31.01.05
Fitting f. cover	8100-73	02.02.05
Soap stone top	8100-74	16.03.05
Soap stone side 8150	8100-75	14.03.05
Mouting plate f. soap stone	8100-76	14.03.05
Flat bar f. soap stone	8100-77	10.03.05
Soap stone side 8151	8100-78	15.03.05
Handle f. sek. draught control soap stone	8100-79	11.03.05
Back plate steel f. 8150	8100-80	11.03.05
Flat bar f. soap stone brick	8100-81	11.03.05
Back plate steel f. 8151	8100-83	11.03.05
App. drawing 8140	8100-102	24.10.05
App. drawing 8142	8100-103	24.10.05
App. drawing 8150	8100-105	25.10.05
App. drawing 8151	8100-106	25.10.05
App. drawing 8147	8100-120	25.10.05
Fitting f. airtight	8100-126	03.10.05
Pipe grate	8100-127	24.10.05
Sek. draught control	8100-128	24.10.05
Tightening tape	8100-130	27.10.05
Air flow	8100-129	26.10.05
Parts drawing	8100-501	26.10.05
Glass fitting	1124-29	23.02.93
Cover	1126-16	12.05.87
Knob f. riddling bar	1126-26	10.08.99
Bush	1126-27	02.07.01
Riddling handle	1126-42	30.06.87
Distance tube	1126-71	21.11.03
Air adaptor	1400-87	24.08.04
Distance tube	1400-300	13.01.97
Hinge pin	2000-186	11.05.05
Riddling grate	2100-66	22.03.99
Stainless Steel Handle	2100-158	29.05.01
Stainless Steel Handle	2100-159	26.01.01
Hinge pin	2100-174	26.01.04
Flue collar	3400-97	13.03.02
Ball barrel	4500-51	16.09.05
Flat bar	5000-63	05.09.05
Distance tube	5000-64	14.02.97
Hinge pin	5000-85	31.07.03
Round plate	5000-91	02.02.05
Stop fitting, left	7100-39	27.01.05
Stop fitting, right	7100-40	27.01.05
Riddling bar	Steel-15	23.09.02

V-1100 (600) Vermiculite insulating slabs- Technical datas
 Glas fiber products - Technical datas
 Glass ceramics - Technical datas
 Installation and Operating Instructions
 Parts list 8140, 8142

3-5 of 3-103

V-1100 (600) Vermiculite insulating slabs
for hot-face and back-up insulation - up to 1100°C (2012°F)



Skamol A/S
Østergade 58-60
DK-7900 Nykøbing Mors
Denmark
Tel: 45 9772 1533
Fax: 45 9772 4975
insulation@skamol.dk

Sales offices

Skamol Europe GmbH
Promenadensstrasse 1
D-41460 Neuss
Germany
Postfach 10 14 37
D-41414 Neuss
Tel: +49 (0) 2131-10640
Fax: +49 (0) 2131-106464

Skamol Americas, Inc.
8318 Pineville-Matthews Road
Suite 267
Charlotte, NC 28226
USA
Tel: +1 (704) 544-1015
Fax: +1 (704) 544-1239

www.skamol.com

Maximum service temperature		
	°C	1100
	°F	2012
Bulk density, dry		
	kg/m ³	600
	lbs/cu.ft.	37.5
Compressive strength (EN 1094-5:1995)		
@ room temperature	MPa	4.2
	lbs/sq.in.	609
Modulus of rupture (EN 993-6:1995)		
	MPa	1.6
	lbs/sq.in.	232
Total porosity (EN 1094-4:1995)		
	%	76
Specific heat		
	kJ/(kg×K)	0.94
	BTU/(lb×°F)	0.224
Coefficient of reversible thermal expansion (BS 1902: section 5.3: 1990)		
@ 20°C-750°C (68°F-1382°F)	K ⁻¹	11×10 ⁻⁶
	°F ⁻¹	6.1×10 ⁻⁶
Resistance to thermal shock (EN 993-11:1998)		
heating to 950°C (1742°F)	cycles	>10
Linear reheat shrinkage (EN 1094-6:1999)		
@ 1000°C	%	1.0
@ 1100°C	%	
Pyrometric cone equivalent (ASTM C24-89 ORTON cones)		
	°C	1300
	°F	2372
Thermal conductivity (ASTM C-182)		
mean temp. @ 200°C	W/(m×K)	0.15
mean temp. @ 400°C	W/(m×K)	0.16
mean temp. @ 600°C	W/(m×K)	0.19
mean temp. @ 800°C	W/(m×K)	-
mean temp. @ 392°F	BTU/(sq.ft.×h×°F/in.)	1.04
mean temp. @ 752°F	BTU/(sq.ft.×h×°F/in.)	1.11
mean temp. @ 1112°F	BTU/(sq.ft.×h×°F/in.)	1.32
mean temp. @ 1472°F	BTU/(sq.ft.×h×°F/in.)	-
Chemical analysis, typical	%	
Silica	SiO ₂	47
Titanium dioxide	TiO ₂	0.5
Ferric oxide	Fe ₂ O ₃	4
Alumina	Al ₂ O ₃	7
Magnesium oxide	MgO	21
Calcium oxide	CaO	2
Sodium oxide	Na ₂ O	0.5
Potassium oxide	K ₂ O	11
Loss on ignition 1025°C (1877°F)	LOI	7
Colour		sand

Data are average results of tests conducted under standard procedures and are subject to variation. Data contained in this data sheet are supplied in good faith as a technical service and are subject to change without notice. Misprint and errors excepted.

Skamol A/S is DS/EN ISO 9001 certified.

March 2004

3-6 of 3-103

GLASFIBERPRODUKTER TEKNISKE DATA

Basismaterialet i STEFFCA glasfiberprodukter består af 6 - 9 mikron "E" glasfibertråde som kan volumineres, tekstureres, tvindes, forstærkes med ståltråde osv.
Produkterne er uorganiske, sterile, ildfaste, helt asbestfri, indeholder ingen giftstoffer eller tungmetaller, og forårsager ikke hudirritation.

"E" GLASFIBER - SAMMENSÆTNING

SiO ₂	53-55 %
Al ₂ O ₃	14-15,5 %
CaO - MgO	20-24 %
B ₂ O ₃	6,5-9 %
Fe ₂ O ₃ - TiO ₂	< 1 %
Na ₂ O-H ₂ O	< 1 %

"E" GLASFIBER - GENERELLE EGENSKABER

Farve:	HVID
Max. temperatur	550 °C
Smeltepunkt	1200 °C
Fiberdiameter	6-9 mikron
Trækstyrke - nyt filament	3400 MPa
Young's modul	74000 MPa
Varmeledningsevne	1,0 W/m °K
Reaktion på ild	ildfast
Glødetab	< 1,5%
Dielektrisk stivhed	60-100 kV/mm
Opløsningsmiddelægthed	god
Basefasthed	god
Syrefasthed	god - bortset fra fluorbrintesyre

"E" GLASFIBERPRODUKTER - GENERELLE EGENSKABER

- stor mekanisk styrke
- gode elektriske egenskaber
- ildfaste
- lav varmeledningsevne
- god modstandsevne over for kemiske stoffer
- høj termisk modstand
- god fleksibilitet

MAX TEMPERATUR..... 550 °C

STEFFCA GLASFIBERPRODUKTER - SORTIMENT

Snoede pakning - omflettede pakning - isolerende bånd - flettede pakninger i runde, firkantede og rektangulære dimensioner - vævet bændl - selvklæbende bændl - bånd - selvklæbende bånd - stigebånd - dielektrisk tape - lodde puder - rå, silikonecoatede, HT-behandlede, aluminiserede, grafitiserede, karamelliserede, teflonbelagte, - glasklæder - afdækninger

VETRO-REF:

GLASFIBERPRODUKTER MED SPECIEL HT-IMPRÆGNERING

Glasfiberprodukter kan imprægneres med speciel ildfast vermiculit for at øge deres resistens over for høje temperaturer og alle slags termisk chok op til 1000°C og for at reducere spild af glasfiber og pulver under håndteringen.

STEFFCA's "VETRO-REF" produkter er meget fleksible og modstandsdygtige over for gnister, svejseprøjt og smeltet metal.

VETRO-REF produkternes farve..... guld

Imprægneringens max termiske fasthed ved kontinuerlig anvendelse..... 700° C

Imprægneringens max termiske fasthed ved kortvarige påvirkninger..... 1000 °C

Fra: Martin Steffensen [Martin@steffca.dk]
Sendt: 25. marts 2004 13:04
Til: kaa@morsoe.com
Emne: Data E-glas Eng.
Hermed data som aftalt.

GLASS FIBER TEXTILE PRODUCTS

The base material of STEFFCA Glass Fiber Textile Products consists of 6 - 9 microns "E" Glass Fiber Filament Yarns that can be voluminized, texturized, plied, reinforced with steel wire etc.

They are inorganic, steril, incombustible, totally Asbestos-Free, do not contain any toxic matter nor heavy metals and do not cause skin irritations.

BASIC COMPOSITIONS OF "E" GLASS FIBER

- SiO₂ 53-55 %
- Al₂O₃ 14-15,5 %
- CaO - MgO 20-24 %
- B₂O₃ 6,5-9 %
- Fe₂O₃-TiO₂ < 1%
- Na₂O-K₂O < 1%

GENERAL PROPERTIES OF "E" GLASS FIBER

- Max. Temperature 550°C
- Melting Point 1200 °C
- Diameter-*filaments* 6-9 micron
- Tensile strength-*virgin filament* 3400 MPa
- Young's modulus 74000 MPa
- Thermal conductivity 1,0 W/m °K
- Fire reaction incombustible
- Loss on ignition < 1,5 %
- Dielectric rigidity-*glass in bulk* 60-100 KV/mm
- Solvent resistance good
- Bases resistance good
- Acid resistance good - except fluoridric acid

GENERAL PROPERTIES OF "E" GLASS FIBER TEXTILE PRODUCTS

- - high mechanical strength - good electrical properties
- - incombustible - good dimensional stability
- - low thermal conductivity - good resistance to chemical agents
- - high thermal resistences - - good flexibility
- - max temperature 550°C

Glass ceramics NEOCERAM N-0

Technical datas

Thermal expansion



Light transmission

Surface character

Flat glasses/Coated glass ceramics/Installation instructions

Technical datas

Expansion coefficient	· 10 ⁻⁷ /K	(30 - 380° C) - 6 (30 - 750° C) - 3
Thermal shock resistance	°C	800
Maximum service temperature	°C	long term 700 short term 800
Thermal conductivity	W/m · K (25° C)	1,51
Specific heat	J/kg · K	712
Density	g/cm ³	2,51
Bending and impact strength	correspondent to the datas of casting glass	



8100 - Reservedelsliste

Revideret: 25.10.05 KDU

Posnr.	Parts:	Beskrivelse:	8140 NA 64810621	8142 NA m. skuffe 64810721
1	Top plate, outside	Topplade udv. 8100	448110xx	448110xx
2	Top frame	Topramme 8100	448107xx	448107xx
3	socle, high	Høj sokkel 8140	348111xx	%
4	Front frame	Forramme 8100	448131xx	448131xx
5	Door	Fyrdør 8100	448103xx	448103xx
6	Side plate, right	Sideplade indv. Højre 8100	44810400	44810400
7	Side plate, left	Sideplade indv. Venstre 8100	44812300	44812300
8	Rear plate, inside	Bagplade indv. 8100	44810500	44810500
9	Base plate, inside	Bundplade indv. 8100	44812200	44810100
10	Top plate, inside	Topplade indv. 8100	44810600	44810600
11	Side plate, outside	Sideplade udv. 8100	448108xx	448108xx
12	Rear plate, outside	Bagplade udv. 8100	448109xx	448109xx
13	Intermediate frame	Mellembund 8100	34811300	34811300
14	Brick, back	Sten bag	79810200	79810200
15	Brick, side, right	Sten side - Højre	79810300	79810300
16	Brick, side, left	Sten side - Venstre	79810400	79810400
17	Flue collar	Røgtud	443441xx	443441xx
19	Stop bar	Kuglespærre 4500	544541	544541
20	Screw	M6x30 Din933 - sort	731630	731630
21	Ceramic glass	Glas 8100	79810100	79810100
22	Cover	Dæksel 1126	442610xx	442610xx
23	Flat bar	Fladjern 3x10mm L=168mm	545006	545006
24	Distance tube	Afstandsør ø10x1 L=8,5	545007	545007
25	Screw	M6x20 Din933 - sort	731620	731620
27	Air canal, rear	Luftkanal bag 8100	44811600	44811600
28	Air adaptor	Airtightstuds 8100	44142600	44142600
29	Air canal, top	Luftkanal top 8100	448117xx	448117xx
30	Washer	6mm Din9021 - fzb	791891	791891
31	Screw	M6x25 Din933 - sort	731625	731625
32	Screw	M6X08 Din933 - sort	731608	731608
33	Glass fitting	Glascips 1124	790743	790743
34	Screw	M5x08 Din7985 - fzb	742508	742508
35	Riddling grate	Rysterist 2100	44182800	44182800
36	Sek. draught control	Sekundær spjæld 8100	71814400	71814400
37	Handle f. sek. draught control	Greb sek. spjæld	71810761	71810761
38	Screw	M5x10 Buttonhead - sort	73851000	73851000
39	Closing plate	Lukkeplade for	71810600	71810600
40	Air canal, front	Luftkanal front 8100	44811500	44811500
41	Tertiary box	Tertiær boks	71810861	71810861
42	Baffle plate, bottom	Sten over tertiærboks	79810500	79810500
43	Cover	Dæksel 8100	448120xx	448120xx
44	Baffle plate, top	Røgvendeplade øverst	79810600	79810600
45	Distance tube	Afst.rør ø12x1,5	71810300	71810300
46	Distance tube	Afstandsstykke ø8x1 L=9mm	71810200	71810200
47	Screw	06x20 Sætskrue Din933 - A2	74162000	74162000
48	Screw	M6x35 Din933 - sort	731635	731635
49	Fitting plate	Befæstigelsesplade	71811161	71811161
50	Screw	M6x45 Din933 - sort	731645	731645
51	Screw	M6X10 Din933 - sort	731610	731610
52	Riddling bar	Rystestang Ø-6	53001500	53001500
53	Bush	Messingbøsning	752621	752621
54	Knob f. riddling bar	Knop f. rystestang 1126	752619	752619
55	Ash tray	Askeskuffe 8100	71811300	71811300
58	Bush	Bøsning f. 1126 håndtag	71813061	71813061
59	Hinge pin	Hængselsstift ø6X35 MM	541808	541808
60	Screw	M6x06 Pinolskrue Din916-45H	739606	739606
61	Screw	M4x05 Pinolskrue Din916-45H	739405	739405
62	Washer	6mm Skive 6,4x12x1,6 Din 125A - fzb	746106	746106
63	Handle	Rustfri dørgræb 1126	75262800	75262800
64	Fitting f. closing plate	Beslag f. lukkepal	71813300	71813300
66	Hinge pin	Hængselsbeslag	71810100	71810100
67	Screw	M5x10 Iso7380	73851100	73851100
68	Screw	M6x10 Din965A - A2	74361000	74361000

8100 - Reservedelsliste

Revideret: 25.10.05 KDU

Posnr.	Parts:	Beskrivelse:	8140 NA	8142 NA
			64810621	m. skuffe 64810721
69	Radiant shielding, bottom	Stråleplade bund	71810400	71810400
70	Distance tube	Afstandsrør ø10x1	542641	541439
71	Washer	06mm Vistop klemskive	746206	746206
72	Radiant shielding, rear	Stråleplade bag	71811400	71811400
73	Distance tube	Afstandsrør ø10x1 L=10	541439	541439
74	Screw	M6X16 Din933 - sort	731616	731616
75	Stop fitting, left	Stopbeslag - venstre	71711200	71711200
76	Stop fitting, right	Stopbeslag - højre	71711300	71711300
77	Fitting f. cover	Lus f. dæksel	71813200	71813200
78	Round plate	Rundel ø 200mm	545010	545010
79	Hinge pin	Hængselsstift ø5x110	54501800	54501800
80	Hinge pin	Hængselsstift ø5x75	545008	545008
82	Screw	M6x20/M6x45 Din933 - sort	731645	731620
83	Bottom plate, outside socle	Bundplade udv. 8142	%	448112xx
84	Bottom plate, outside socle	Bundplade udv. Sokkel 8100	%	448127xx
85	Leg	Ben 8100	%	448118xx
86	Cover plate, rear, for leg	Dækplade bag v. ben 8100	%	348121xx
87	Rubber stop block	Gummistopklods 8100	%	79082007
88	Screw	M6x12 Din7985	%	742612
89	Drawer, front	Skuffefront 8100	%	448119xx
90	Drawer, box	Skuffekasse 8100	%	718127xx
91	Cover plate f. drawer section	Afdækningsplade skuffesektion 8100	%	718128xx
92	Mounting plate, drawer section	Mont.plade skuffesekt. 8100	%	718128xx
93	Ball barrel	Kugleløb 27x310mm - elg.	%	79082006
94	Screw	M6x08 Buttonhead - sort	%	73860800
95	Screw	4,8x9,5 Din7981 pladeskrue - fzb	%	74400600
96	Screw	M4x08 din965A - fzb	%	74241800
97	Side plate, steel	Stålsideplade 8145	%	%
98	Rear plate, steel	Stålbagplade 8145	%	%
99	Socle, high	Sokkel f. 8145	%	%
100	Brace f. steel side plate	Seler f. stålplader 8145	%	%
101	Fitting f. steel side plate	Beslag f. stålsideplade 8145	%	%
102	Fitting f. steel rear plate	Beslag f. stålbagplade 8145	%	%
103	Screw	M6x35 Din933 - Sort	%	%
104	Screw	M6x12 Din933 - Sort	%	%
105	Tightening tape	Glasbånd m. tape 4x8mm sort	79074200	79074200
106	Screw	M5X16 Pinolskrue indiv. 6kt. Din 913	73951600	73951600
107	Washer	6mm Skive Din522C - fzb	736106	736106
108	Screw	M6X50 Maskinbolt Din931 - Sort	731650	731650
109	Screw	6mm Skive 6,4x12x1,6 Din125A - fzb	%	746106
110	Feder	Bladfjeder fyrdør 8100	%	%
111	Feder fitting	Fjederbeslag fyrdør 8100	%	%
112	Screw	M4x6 DIN 912 - sort	%	%
113	Screw	M5x6 ISO7380	%	%
114	Screw	Skruer f. lus	743625	743625
115	Fitting f. airtight	Lus f. airtightstuds 8100	542642	542642
116	Screw	M6x16 ISO 7381 - sort	73861400	73861400
117	Pipe grate	Rørforrist 8100 NA	71814361	71814361
118	Screw	M6x12 Iso 7380 - sort	73861100	73861100

Farvekode: xx

21




Sort

22


Grå


№ проекта	1100-01
№ листа	3
№ чертежа	1100-01/3
Исполнитель	М.И.С.С.
Проверенный	М.И.С.С.
Утвержденный	М.И.С.С.
Дата	11.11.11
Масштаб	1:1
Титул	Чертеж
Исполнитель	М.И.С.С.
Проверенный	М.И.С.С.
Утвержденный	М.И.С.С.
Дата	11.11.11
Масштаб	1:1
Титул	Чертеж

Вид с торца (облиц.) в 1/1







3-13. of 3-103









Proj. No.	1000-016
Proj. Name	Proj. 1000-016
Proj. Date	11/11/52
Proj. Status	Final
Proj. No.	1000-016
Proj. Name	Proj. 1000-016
Proj. Date	11/11/52
Proj. Status	Final
Proj. No.	1000-016
Proj. Name	Proj. 1000-016
Proj. Date	11/11/52
Proj. Status	Final
Proj. No.	1000-016
Proj. Name	Proj. 1000-016
Proj. Date	11/11/52
Proj. Status	Final







3-20 of 3-103


Title		Date	
Description		Drawn by	
Part Name		Checked by	
Part No.		Scale	
Drawing No.		Sheet No.	
Project No.		Job No.	
Customer		Manufacturer	
Drawing Date		Drawing Scale	
Drawing Size		Drawing Orientation	
Drawing Status		Drawing Author	
Drawing Reviewer		Drawing Date	
Drawing Approval		Drawing Date	
Drawing Revision		Drawing Date	
Drawing Change		Drawing Date	
Drawing Issue		Drawing Date	
Drawing Release		Drawing Date	
Drawing Withdrawal		Drawing Date	
Drawing Destruction		Drawing Date	



3-26 of 3-103

Part No.	100-119
Part Name	100-119
Rev.	1
Material	100-119
Quantity	100-119
Unit	100-119
Notes	100-119
Drawn by	100-119
Checked by	100-119
Approved by	100-119
Date	100-119
Scale	100-119
Sheet No.	100-119
Total Sheets	100-119
Project No.	100-119
Project Name	100-119
Customer	100-119
Manufacturer	100-119


















4.4



Rev. No. 1
 Date 10/10/12
 Project No. 100-12-0
 Drawing No. 100-12-0-100
 Scale 1:1
 Author
 Checker
 Designer
 Approver
 Title
 Date
 Project No. 100-12-0
 Drawing No. 100-12-0-100
 Scale 1:1
 Author
 Checker
 Designer
 Approver
 Title
 Date


Project No.	100-13
Sheet No.	3-82 of 3-103
Scale	AS SHOWN
Author	
Checked	
Approved	
Date	
Revision	
Material	
Quantity	
Notes	






Title		3-34 of 3-103	
Author		J. H. ...	
Date		...	
Scale		...	
Material		...	
Drawing No.		...	
Sheet No.		...	
Project No.		...	
Drawing Date		...	
Drawing Scale		...	
Drawing Size		...	
Drawing Weight		...	
Drawing Price		...	
Drawing Cost		...	
Drawing Value		...	
Drawing Status		...	
Drawing Location		...	
Drawing Remarks		...	
Drawing Notes		...	
Drawing Description		...	
Drawing Details		...	
Drawing Specifications		...	
Drawing Standards		...	
Drawing Compliance		...	
Drawing Approval		...	
Drawing Signature		...	
Drawing Stamp		...	
Drawing Markings		...	
Drawing Annotations		...	
Drawing Comments		...	
Drawing History		...	
Drawing Changes		...	
Drawing Revisions		...	
Drawing Updates		...	
Drawing Maintenance		...	
Drawing Archiving		...	
Drawing Retrieval		...	
Drawing Access		...	
Drawing Security		...	
Drawing Confidentiality		...	
Drawing Protection		...	
Drawing Encryption		...	
Drawing Decryption		...	
Drawing Backup		...	
Drawing Restore		...	
Drawing Transfer		...	
Drawing Migration		...	
Drawing Conversion		...	
Drawing Optimization		...	
Drawing Compression		...	
Drawing Decompression		...	
Drawing Extraction		...	
Drawing Insertion		...	
Drawing Deletion		...	
Drawing Renaming		...	
Drawing Moving		...	
Drawing Copying		...	
Drawing Pasting		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	
Drawing Cut		...	
Drawing Paste		...	
Drawing Copy		...	
Drawing Paste		...	
Drawing Undo		...	
Drawing Redo		...	

Part Name	8100-17 G
Quantity	1
Material	Aluminum
Finish	None
Notes	See Drawing for Details
Drawn	J.H. 1/15/52
Checked	J.H. 1/15/52
Approved	J.H. 1/15/52




3-35 of 8-103




MSGS


Part No.	100-18 G
Rev.	1
Quantity	1
Material	ALUMINUM
Finish	ANODIZED
Notes	1. SEE ENGINEERING DRAWING FOR DIMENSIONS AND TOLERANCES.
Drawn By	...
Checked By	...
Approved By	...



B-B




Anviser i. M&M 10mm eller instruksjon: 7.04.02 boreanviser.



Ikke angivne radler = R1

Revisjon	Sign.	Dato:
0	KDU	23.11.04
Tittel:		
Draeksel 8100		
Opprettet av:	Revisjon:	Dato:
Morsø 8100	KDU	07.02.03
Drøyt.no	Skala:	A2
4116	Størrelse:	1:1
Drøyt.no	Drøyt.no	34812000
morsø		
8100-20 a		




434.2

Rev / Revisions		Sign:	Date:
Title:		KDU	29.09.04
Construction:		KDU	08.04.05
Released:			
Format:		A3	
Scale:		1:2	
Item no.:		79810100	
Drawing no.:		8100-24 a	
See Drawing			
Material:	Keramikk glas		
Weight:	1,72 kg		
Model no.:	-		
Drawing type:	Emnelegging		
Location of file:	svs\svs\prosjekter\8100\8100-24.dwg		




This drawing is Morse Jernstøberi A/S' property and must not be sold, loaned or copied without any written authorization from the company.



Rev	Revisions	Sign.	Date:
	Title:	Constitution:	KDU 25.01.05
	Sten bag	Released:	KDU 04.07.05
		Format:	A3
		Scale:	1:2
	Morsø 8100	Item no.:	79810200
		Drawing no.:	8100-26 a
	morsø KEMTEKNIKER		
	General tolerances: +1mm, -2mm.		
	Material: Vermiculite v-1100 MK2		
	Weight: 1,22 kg		
	Model no.:		
	Drawing type: Ermetisering		
	Location of file:		

This drawing is Morsø Jernstøberi A/S property and must not be sold, lent, or copied without any written authorization from the company.


Date of issue: 04.07.05 3-41 of 5-10-05



a	IPSSA1 lewendan lev.	KJU	12.09.03
d	IPSSA1 lewendan lev.	KJU	12.09.03
e	IPSSA1 lewendan lev.	KJU	07.09.03
h	Figur af fremen ved indhøst.	KJU	01.09.03
New revisions			
Blår		Sign.	Dato:
Konstruktion		KJU	25.01.05
Referent		KJU	04.07.05
Formål			A2
Socle			1:2
Morsø 8100		Referent	798 0300
Dokumentation		Drøning anr.	8100-27 e
Løsnings for		www.morsoe.com	

General dimensions ± 1mm, 2mm.
 Material: Venedicula w/100 ml.2
 Weight: 1,25 kg
 Model no.:
 Droningstype: Guldslagning
 Location of file: www.morsoe.com





The drawing is Morse Architect A/P property and must not be sold, rented or copied without any written authorisation from the company.



Titel		KDU	OP 2005
Sten slide - Venstre		Signa	Stak
Morsø 8100		KDU	25.01.05
Morsø 8100		Relevans	0.07.05
Morsø 8100		Format	A2
Morsø 8100		Scale	1:2
Morsø 8100		Item no.	79810400
Morsø 8100		Drawing no.	8100-28 b

General Information	
Material	Venstre 100 ML2
Weight	1.25 kg
Material no.	
Drawing no.	
Location of file	

The drawing is Morsø Armature A/E property and must not be sold, lent or copied without any written authorization from the company.




Date of print: 27-10-2005

Mål uden toleranceangivelse i.h.t. DS/ISO 2768-1 m		Rev. Revisions	Sign.:	Date:
Material:	SPD Plade	Title:	Construction:	KDU 13.01.05
Weight:	0,03 kg	Hængselsbeslag	Released:	KDU 29.09.05
Model no.:	-	Morsø 8100	Format:	A4
Drawingtype:	Emnetegning	morsø <small>Byggeteknik til det nordiske hus</small>	Scale:	2:1
Location of file:	U:\100\A\prøve\8100\8100-30 Hængselsbeslag-8100.R1		Itemno.:	71810100
			Drawing no.:	8100-30 a

This drawing is Morsø Jernstøberi A/S' property and must not be sold, lent or copied without any written authorization from the company.

3-44 of 3-103




Date of print: 27-10-2005

		Rev. Revisions	Sign.:	Date:
Mål uden toleranceangivelse i.h.t. DS/ISO 2768-1 m		Title:	Construction:	KDU 18.01.05
Material:	Galv	Afstandsstykke ø8x1 L=9mm	Drawn:	KDU 29.09.05
Weight:	0, kg	Hydraulikrør galv.	Format:	A4
Model no.		Morsø 3400	Scale:	2:1
Drawingtype:	Emnetegning	morsø	Itemno.:	71810200
Location of file:	U:\UDV\tegnings\standard\Bofek\Afstander\Afstander ø8x1.DWG	<small>Registered to the Royal Danish Court</small>	Drawing no.:	8100-31 a

This drawing is Morsø Jernstøberi A/S' property and must not be sold, lended or copied without any written authorization from the company.

3-45 of 3-103




Date of print: 27-10-2005

Mål uden toleranceangivelse i.h.t. DS/ISO 2768-1 m		Rev. Revisions	Sign.:	Date:
Material:		Title:	Construction:	KDU 18.01.05
Weight:	0, kg	Afst.rør Ø12x1,5	Released:	KDU 29.09.05
Model no.:	-	Morsø 8100	Format:	A4
Drawingtype:	Emnetegning	morsø <small>Byggeri og VVS</small>	Scale:	2:1
Location of file:	\\VDA\legninger\ulendord\2005\afst.rør\afst.rør ø12x1,5.DWG		Itemno.:	71810300
			Drawing no.:	8100-32 a

This drawing is Morsø Jemstøberi A/S' property and must not be sold, lend or copied without any written authorization from the company.


3-46 of 3-103



Rev	Revisions	Sign.	Date:
		KDU	19.01.05
		KDU	29.09.05
			A3
			1:2
			71810400
			8100-33 a

Title:	
Stråleplade bund	
Morsø 8100	
morsø <small>RESEARCH & INNOVATION</small>	
Måluden tolerancangivelse i.h.t. DS/ISO 2768-1 m	
Materiale:	Galvaniseret plade
Vægt:	0,77 kg
Model no.:	-
Drawingtype:	Emnelegning
Location of file:	\\svs01\svs\proj\8100\8100-33\8100-33.dwg

This drawing is Morsø Jernstøberi A/S property and must not be sold, landed or copied without any written authorization from the company.






Date of print: 27-10-2005

		Rev. Revisions	Sign.:	Date:
Mål uden toleranceangivelse i.h.t. DS/ISO 2768-1 m		Title:	Construction:	KDU 18.01.05
Material:	SPD Plade	Lukkeplade for	Released:	KDU 29.09.05
Weight:	0,02 kg	Sekundær spjæld	Format:	A4
Model no.:	-	Morsø 8100	Scale:	1:1
Drawingtype:	Emnetegning	morsø <small>Byggesystem til 3D tryk og 3D print</small>	Itemno.:	71810600
Location of file:	U:\UDP\tegninger\8100\8100-37 Lukkeplade tek. spjæld.DWG		Drawing no.:	8100-37 a

This drawing is Morsø Jernstøberi A/S' property and must not be sold, lend or copied without any written authorization from the company.






3-48 of 3-103



Date of print: 27-10-2005


Ingen grater på kanterne.		Rev. Revisions	Sign.:	Date:
Mål uden toleranceangivelse i.h.t. DS/ISO 2768-1 m		Title:	Construction:	KDU 21.12.04
Material:	Rustfri stål - Børstet	Greb sek. spjæld	Released:	KDU 29.09.05
Weight:	0,08 kg	Morsø 8100	Format:	A4
Model no.	-	morsø	Scale:	1:1
Drawingtype:	Emnetegning	<small>Byggeskema til  the Royal Danish Guard</small>	Itemno.:	71810761
Location of file:	U:\UDV\Lejrings\8100\8100-38 Greb sekundær spjæld.kstprf	Drawing no.:	8100-38 a	

This drawing is Morsø Jernstøberi A/S' property and must not be sold, lent or copied without any written authorization from the company.



c) Utgående leverandörens kopia		UDU	07/09/05
b) Ändra i mål		REV	31/08/05
Rev. Rev. Datum		Signu.	Doteri
Filnamn:		Construction	UDU
Siffror över tecknet		Released	UDU
General Information: 1 item, 2mm.		Formel:	A2
Material: Varmhållsfil v. 1000 mA.2		Skala:	1:2
Weight: 1,51 kg		Item no.:	77810500
Model no.:		Ordering no.:	8100-42 c
Drawing type: Elinstegning		 morsø <small>WORLDWIDE</small>	
Load no.:		<small>This drawing is Morsø Jamnibyl's A2 property and must not be sold, lent, or copied without any written authorization from the company.</small>	


3-51 of 3-105



b. Tegane Ievērojoties lēm.,		ROU	19.02.05
New Revision		Sign.	Date
Line:		100	20.03.05
General Reference: 1mm-2mm.	Construction:	100	04.02.05
Material: Vērtības vā 100 AL2	Reference:		A2
Weight: 1,23 kg	Form:		1:2
Model No.:	Item:		79810400
Drawn by: Enceļņiņš	Blank no.:		8100-43 b

morso
 The drawing is Mass. Any Marking property and must not be sold, leased or copied without any written authorization from the company.

3-52 of 8-105





Rev.	Revisions	Sign.	Date
		KDU	18.01.05
		KDU	29.09.05
			A3
			1:1
			71811161
			8100-50 a

Title:	
Befæstigelsesplade	
røgendeplade	
Morsø 8100	

Måltuden tolerancesangivelse i.h.t. DS/ISO 2768-1 m
Materiale: Rødfri stål
Weight: 0,34 kg
Model no.:
Drawing type: Ermetegning
Location of file:

This drawing is Morsø Jernstøberi A/S property and must not be sold, lent, or copied without any written authorization from the company.

3-53 af 3-103




Date of print: 27-10-2005

Mål uden toleranceangivelse i.h.f. DS/ISO 2768-1 m		Rev. Revisions	Sign.:	Date:
Material:	SPD Plade	Title:	Construction:	KDU
Weight:	0,03 kg	Beslag f. lukkepal	Released:	KDU
Model no.:	-	Morsø 8100	Format:	A4
Drawingtype:	Emnetegning	morsø	Scale:	2:1
Location of file:	U:\020\Vejringer\8100\8100-63 Beslag for Lukkepal 2.1.DWG	<small>Byggeteknik og Design</small>	Itemno.:	71813300
			Drawing no.:	8100-63 a





This drawing is Morsø Jernstøberi A/S' property and must not be sold, lent or copied without any written authorization from the company.

3-56 of 3-103



Rev./Revisions		Sign.:	Date:
Title:		Construction:	KDU 19.01.05
Stråleplade bag		Released:	KDU 22.09.05
Mål uden toleranceangivelse iht. DS/ISO 2768-1 m		Format:	A3
Material: Galvaniseret plade		Scale:	1:2
Weight: 1,01 kg		Item no.:	71811400
Model no.:		Drawing no.:	
Drawing type: Emnelegning		8100-65 a	
Location of file:		morsø	
<small>www.morsoe.com</small> <small>www.morsoe.com</small>		<small>www.morsoe.com</small> <small>www.morsoe.com</small>	

This drawing is Morsø Jernstøberi A/S' property and must not be sold, loaned or copied without any written authorization from the company.








Rev/ Revisions	Sign.: KDU	Date: 21.01.05
Title: Mont.plade f. skuffesektion	Construction: KDU	29.09.05
Mål uden tolerancangivelse LxH, DS/ISO 2768-1 m	Format: A3	
Material: SPD Plade	Scale: 1:2	
Weight: 0,66 kg	Item no.: 71812800	
Model no.:	Drawing no.: 8100-66 a	
Drawing type: Emnelegning		
Location of file: <small>\\server\proj\8100\8100-66 a\skuffesektion\8100-66 a.dwg</small>		

This drawing is Morse Jensen's property and must not be sold, lent, copied or otherwise used without the company's written authorization.

301-3-65-3

Date of print: 27-10-2005

Forbores med $\varnothing 9,6 \times 30 \text{ mm}$




Date of print: 27-10-2005

Rev. Revisions		Sign.:	Date:
Title:		Construction:	KDU 31.01.05
Døraksel 8100		Released:	KDU 29.09.05
Morsø 8100		Format:	A4
morsø		Scale:	1:1
Byggeteknik		Itemno.:	71813061
Drawing no.:		8100-71 a	

Se tegning	
Material:	Rustfri stål
Weight:	0,05 kg
Model no.:	-
Drawingtype:	Emnetegning
Location of file:	U:\MDP\tegringer\8100\8100-71 Døraksel 8100.SLDPR

This drawing is Morsø Jernstøberi A/S' property and must not be sold, lent or copied without any written authorization from the company.


3-60 of 3-103



Rev. / Revisions:		Title:		Construction:		Sign:		Date:	
		Lus f. dækse		KDU		KDU		02.02.05	
		Morsø 8100		Released:		Format:		29.09.05	
		morsø		Released:		Scale:		A3	
		Drawing no.:		Format:		Scale:		1:1	
		Drawing no.:		Item no.:		Scale:		71813200	
		Drawing no.:		Item no.:		Scale:		8100-73 a	

3-61 of 3-103

This drawing is Morse Jernstøberi A/S property and must not be sold, lent, or copied without any written authorization from the company.




Rev	Revident	Blanz	Datum
1		700	14.03.05

Titel:	
Bestandteil:	Fedstiftstop 8100
Material:	A2
Formel:	
Skala:	1:2
Zeichner:	79810739
Gezeichnet:	
Drawing no.:	8100-74





Date of issue: 27/10/2005	
See Drawing	
Material:	
Weight:	
Modell no.:	
Drawing type:	Erstzeichnung
Location:	

This drawing is Morse Intellectual Property and must not be sold, lent, or copied without any written authorization from the company.




3-02 of 3-103



This cut can be rough and in an different shape. This dimension is minimum.





Teil / Part		Date	
Zeichnungs-Nr. / Drawing No.	Rev. / Rev.	Erstellt / Created	Geprüft / Checked
8100-05	01		
Beschreibung / Description		Menge / Qty	
Konkretsteifling 8100		1	
Material / Material		7981083P	
Hersteller / Manufacturer		Morsø	
Zeichner / Drafter		8100-75	
Gezeichnet / Drawn			
Geprüft / Checked			
Freigegeben / Released			



Rev.	Revisions	Sign.	Dato:
		KDU	10.03.05
Title:		Construction:	Released:
Bøjle f. fedisten			A3
Model no.:		Scale:	1:1
Morsø 8100		Item no.:	71813400
Drawing no.:		8100-77	
morsø <small>Fasteners & Hardware</small>			
<small>Mål uden tolerancangivelse iht. DS/ISO 2768-1 m</small>			
<small>Material: SPD Plado</small>			
<small>Weight: 0,03 kg</small>			
<small>Model no.:</small>			
<small>Drawing type: Emnetegning</small>			
<small>Location of file:</small>			



This drawing is Morse Jernstøberi A/S' property and must not be sold, lent, or copied without any written authorization from the company.



Konstruktørtegning
09.06.05


Rev. / Revision	Sign.	Dato:
	ESJ	15.03.05
Title:		
Feststenside 8151		
Contributor	Released	Format
		A2
Material	Weight	Scale
Fyllingsbølger	543 kg	1:2
Modell no.		Item no.
		79810939
Design type	Drawing no.	
Småtagg	8100-78	
Vendor of:	morsø	
	morsø AS	

The drawing is Morsø Anstalt's property and must not be sold, lent, or copied without my written permission from the company.



2 Stk. M5

Konstruktionstegning
04.10.05




Date of print: 27-10-2005

Mål uden toleranceangivelse i.h.t. DS/ISO 2768-1 m		Rev. Revisions		Sign.:	Date:
Material:	Rustfri stål - Børstet	Title:	Construction:	KDU	11.03.05
Weight:	0,07 kg	Greb sek. f. fedtstensovn		Released:	
Model no.:	-	Morsø 8100	Format:	A4	
Drawingtype:	Emnetegning	morsø	Scale:	1:1	
Location of file:	U:\MDV\1-grønner\8100\8100-79 Greb sek. f. fedtstensovn.SLDPR	<small>Byggesystem til The Royal Danish Court</small>	Itemno.:	71813561	
			Drawing no.:	8100-79	

This drawing is Morsø Jernstøberi A/S' property and must not be sold, lent or copied without any written authorization from the company.

3-67 of 3-103



Konstruktionstegning
11.03.05




Date of print: 27-10-2005

		Rev. Revisions	Sign.:	Date:
Mål uden toleranceangivelse i.h.t. DS/ISO 2768-1 m		Title:	Construction:	KDU 11.03.05
Material:	SPD Plade	Released:		
Weight:	0.19 kg	Format:	A4	
Model no.:		Scale:	1:1	
Drawingtype:	Emnetegning	Itemno.:	71813700	
Location of file:	D:\UDV\tegringer\8100-81 Løs profil i fedtstenblok.EDT	Drawing no.:		8100-81
		morsø <small>Byggesystemer</small>		

This drawing is Morsø Jernstøberi A/S' property and must not be sold, lent or copied without any written authorization from the company.

3-69 of 3-103







Konstruktionstegning
10.10.05

Date of print: 27-10-2005

Mål uden toleranceangivelse i.h.t. DS/ISO 2768-1 m		Rev. Revisions	Sign.:	Date:
Material:	Fladstål blanktrukket	Title:	Construction:	KDU 03.10.05
Weight:	0,03 kg	Lus f. airtightstuds 8100	Released:	
Model no.:	-	Morsø 8100	Format:	A4
Drawingtype:	Emnetegning	morsø	Scale:	1:1
Location of file:	U:\IDN\tegringer\8100\8100-126 Lus f. airtightstuds 8100.DPRT	<small>Byggesystemer A/S - The Best of Danish Cast</small>	Itemno.:	542642
			Drawing no.:	8100-126


This drawing is Morsø Jernstøberi A/S' property and must not be sold, lendet or copied without any written authorization from the company.

3-71 of 3-103




Konstruktionstejning
 24.10.05

Rev	Revisions	Sign.	Date:
		KDU	24.10.05
Title:		Construction:	Released:
Rørførest 8100 NA			
Material:		Format:	A3
Weight:		Scale:	1:2
Model no.:		Item no.:	71814361
Drawing type: Erstatning		Drawing no.:	
Location of file:		8100-127	
morsø <small>Partners of the world</small>			



Title		Rev. / Revision	
Air-flow diagram			
Milestone		8140 NA	
Weight		Morse 8100	
Model no.			
Design type		Approved Drawing	
Length of file		8100-129 a	
Drawing no.		8100-129 a	
Scale		1:5	
Format		A2	
Reference		3814007	
Contributor		RIV	
Date		28-10-07	






Date of print: 28-10-2005





		Rev. Revisions	Sign.:	Date:
		Title:	Construction:	KDU 28.10.05
		Glasbånd 8100	Released:	
Material:	8x4mm Glasbånd m. tape	Morsø 8100	Format:	A4
Weight:	0,37 kg	morsø	Scale:	1:2.5
Model no.		<small>Byggeteknik til alle typer tekstiler</small>	Itemno.:	79074200
Drawingtype:	Emnetegning		Drawing no.:	8100-130 a
Location of file:	E:\CDVA\tegringer\8100\8100-130 Glasbånd.SLDPR			

This drawing is Morsø Jernstøberi A/S' property and must not be sold, lent or copied without any written authorization from the company.

3-75 of 3-103



Ash Tray inside dim.:
280x300x50mm








Primary Air:
Min.: 3x105,6mm² = 316,8mm²
Max.: 3x47,5mm² = 1425mm²

Secondary Air max.:
2x314mm²=628mm²

D Added plate and indicated primary air.		CDI	26.10.05
Rev./Revisions	Typic.	Draw.	26.10.05
Mfr.		Construction	CDI
Title: Approval Draw. 8150 NA		Released	A2
Date when indication of strength has to be given in accordance with EN 1052-1:2002		Scale	1:5
Weight		Revised	
Height		Drawing no.	8100-105 b
Material		Morse 8100	
Manufacturer		morse	
Drawing type		Approval Drawing	
Scale of the drawing		1:5	

3-78 of 3-82










b) A design label and reduced primary air		CDU: 24.10.03	CDU: 24.10.03
Revizija	Revizija	Sign: 24.10.03	Sign: 24.10.03
Title: Approval Draw. 8142 NA		Construction: CDU	Design: 24.10.03
Dim. and location of parts see: 100 Formis: 0602.073		Format: A2	Scale: 1:5
Material: -		Series: -	Drawing no.: 8100-103 b
Weight: -		Morso 8100	
Material no.: -		morso	
Drawing type: Approval Drawing		Morso s.p.	
Location of file: -		Morso s.p.	

Primary Air:
 Min.: $3 \times 105,6 \text{ mm}^2 = 316,8 \text{ mm}^2$
 Max.: $3 \times 475 \text{ mm}^2 = 1425 \text{ mm}^2$

Secondary Air max:
 $2 \times 314 \text{ mm}^2 = 628 \text{ mm}^2$

This drawing is Morso's intellectual property. It may not be used, copied or reproduced without any written authorization from the company.

3-77 of 3-103



Primary Air:
Min.: 3x105.6mm² = 316.8mm²
Max.: 3x47.5mm² = 142.5mm²



Secondary Air max.:
2x31.4mm² = 62.8mm²

Rev	Revision	CDU	31.03.05
1	Adopte planer and technical change of	Sign.	Edler
Title:		CDU	24.03.05
Approval Drawing 8151 NA		Released:	
Morsø 8100		Format:	A2
morsø		Scale:	1:5
Drawing no.:		Item no.:	
8100-106 b		Drawing no.:	8100-106 b

Dim. without tolerances of shape see ISO Norm No. ISO 279
 Material:
 Weight:
 Model no.:
 Drawing type: Approval Drawing
 Location of file: www.morsos.com

3-77 of 8-103

Dato | Kg. 10 stk.



NB! Findes som solidworks part
 1124/1124-29 glasclips.prt.
 24/7-00/100.





edbnr. 790743


 LEVERANDØR TIL
 DET KGL. DANSKE HOF
morsø
 AKTIESELSKABET
 N. A. CHRISTENSEN & CO
 7900 NYKØBING MORS
 TLF. 97 72 13 00

GLASKLIPS.
 1,5mm rf.plade
 werkstoff nr.14301

DATO 23-2-93		SIGN. AaGJ
MÅL 5:1	ÆNDRET 5-12-84	
MODELNR.		
TEGNINGSNR. 1124-29-4		

B 7 6 5 4 3 2 1






Solid part

DATE 12 MAY 1987		SRON
MAL 42.1		PROJEKT
TEGNINGSNR. 1126-16-2		MODELNR. 26.10
DAKSEL		
140RSØ 1126		




3-83 + 3-103




2,5:1



Matr.: Automatstål



Rev	Revision	Sign.	Dato	Titel: Knop til rystestang 1126	Sign.:	Dato:
b	Gamdrup TegneTeknik	HCH	April 96		ZZ	XXXXX
c	Tilføjet tegn.nr.	KD	20.12.96	Filnavn:	Tegn.form.:	Målforhold
d	Varenr. ændret fra 752620	KD	01.07.99	1126-26	A4	1:1/2.5:1
e	Længdemål ændret	KDU	10.08.99	morsø <small>Jernløber A/S</small>	Varenummer:	
					752619	Tegningsnummer:
					1126-26 e	







1126-27 messingbøsning - Sheet11

Materiale:	Messing	Titel:		KDU	02.07.01
Vægt:	0,006 kg.	Bearbejdes:	Drejes	Rev. Revisionstekst:	Sign.: Dato:
Overfladebeh.:	Ubehandlet	Bøsning for rystestang		Konstr.:	N.Aa 28.07.87
Måltolerance:	Mål uden toleranceangivelse DS/ISO 2768-1 m			Frigivet:	
Ruhedstolerance:		Morsø 1126		Tegn.format:	A4
Værktøjsnr.:	-			Målforshold:	2.5:1
Tegningstype:	Emnetegning	morsø <small>By Apportørerne til det nye Carlsberg</small>		Varenr.:	752621
				1126-27 a	



Denne tegning tilhører Morsø Jernstøberi A/S og må ikke afhændes, udlånes eller kopieres uden firmaets skriftlige tilladelse

3-85 + 3-103




DAYS	30 JULY	1987	SIGN.	K
	MIL.	REQUISIT 710-3.6 U.S.A.		
MORSE H26			MODEL NR.	
RYSTE-HÅNDTAG			TEKNIKENR.	H26-42-2








Date of print: 27-10-2005

Rev. Revisions		Sign.:	Date:
Title:		Construction:	RSV 21.11.03
Mål uden toleranceangivelse i.h.t. DS/ISO 2768-1 m		Released:	
Material:	galv. hydraulikrør	Format:	A4
Weight:	0,01 kg	Scale:	1:1
Model no.:	-	Itemno.:	542641
Drawingtype:	Emnetegning	Drawing no.:	1126-71 a
Location of file:	 <small>Byggesystemer til Byg og Byg Detik Gør</small>		

This drawing is Morsø Jernstøberi A/S' property and must not be sold, lent or copied without any written authorization from the company.

3-87 of 3-103



A-A

3-88 of 3-103

Date of print: 27-10-2005


2 stk. anvises for M6

Anvise efter instruktion: 7.04.02 Boreanviser
 Mål uden tolerancesngivelse iht. i. DS/ISO 2768-1 m
 Matrikel: Støbejern GG 15
 Weight: 1,04 kg
 Model no.: 1419
 Drawing type: Støbelegning
 Location of file: www.morsø.com \industrial\projekt\2005\27102005

c	Ændret mål for nøkker og anvise	RSV	24.08.04
b	Ændret til SolidWorks.	RSV	15.04.04
Rev/ revisions		Sign.:	Date:
		RSV	15.09.04
Tilleg:		Construction:	
Ragtud DIN		Released:	
Ø121		Format:	A3
Morsø 1400		Scale:	1:1
		Item no.:	341419
Drawing no.:		1400-87 C	


morsø
 Precision Castings

This drawing is Morsø Jernstøberi A/S property and must not be sold, lent, or copied without any written authorization from the company.



Matr:10x1 Hydraulikrør galv. varenr.712602

Titel: Afstandsør ø10x1 L=10	Sign.: RS	Dato: 970113	Revision	Sign.	Dato
	Tegn.form.: A4	Målforshold 2:1			
Tegningsnummer: 1400-300-4	Varenummer: 541439				
morso / <small>Jernstøberi A/S</small>	Filnavn: 1400-300				






Date of print: 27-10-2003

Material:	Automatstål	Hængselsstift ø5x110 Morsø 2040 	Construction:	RSV	17.03.03
Weight:	0.02 kg		Released:	RSV	17.03.03
Model no.:	-		Format:	A4	
Drawingtype:	Emnetegning		Scale:	1:1	
Location of file:	LS\UDV\tegninger\Udendørsarbejde\Udhængselsstift110D\F		Itemno.:	54501800	
		Drawing no.:		2000-186 c	


This drawing is Morsø Jernstøberi A/S' property and must not be sold, lent or copied without any written authorization from the company.

3-90 of 3-103



Ikke angivne radler R 1

Rev.	Revision	Sign.	Dato	Modelnr.: 1828	Målt.: GG15+CH	Vægt: 85 Kg.
b	Erstatning af tidligere udgaver	22.03.99		Titel: Rist		
				2100/4500/4600/	Sign.: A.G.J.	Dato: 09.04.93
				5000/6000	Tegn. form.: A2	Målestok: 1:1
				Rev.: 2100-66	Varemærke: 44182800	
					morsø Jernvarefabrik	Tegningnummer: 2100-66 b





2100-158 Håndtag 2110 USA - Sheet1

Materiale:	Rustfast stål		Titel:		Konstr.:	RSV	22.01.2001
Vægt:	317	Bearbejdes:	Bores	Håndtag 2110 USA	Frigivet:	RSV	22.01.2001
Overfladebeh.:			m ²	Morsø 2100	Tegn.format:	A4	
Måltolerance:	Mål uden toleranceangivelse DS/ISO 2768-1 m			morsø <small>By appointment to the Royal Danish Court</small>	Målforhold:	1:1	
Ruhedstolerance:					Varenr.:	75262400	
Værktøjsnr.:					Tegningsnr.:	2100-158 c	
Tegningstype:	Emnetegning						
				Rev. Ændret mål	RSV	29.05.2001	
				b Ændret mål	RSV	27.02.2001	
				Rev. Revisionstekst:	Sign.:	Dato:	

Denne tegning tilhører Morsø Jernstøberi A/S og må ikke afhændes, udlånes eller kopieres uden firmaets skriftlige tilladelse

3-92 of 3-103





2100-159 Håndtag komplet USA - Sheet1


Materiale:		Rev. Revisionstekst:		Sign.:	Date:
Vægt:	kg.	Bearbejdes:	Titel:		Konstr.:
Overfladebeh.:	m ²		Håndtag komplet USA		RSV
Måltolerance:	Mål uden toleranceangivelse		Morsø 2100		26.01.2001
Ruhedstolerance:			morsø <small>Byggesystem til Høj- og Lavtryk</small>		Frigivet:
Værktøjsnr.:					Tegn.format:
Tegningstype:	Samlingstegning				A4
					Målforhold:
					1:1
					Varenr.:
					Tegningsnr.:
					2100-159 a

Denne tegning tilhører Morsø Jernstøberi A/S og må ikke afhændes, udlånes eller kopieres uden firmaets skriftlige tilladelse

3-93 of 3-103




Date of print: 27-10-2005

Rev. Revisions		Sign.:	Date:
Title:		Construction:	RSV
Mål uden toleranceangivelse i.h.t. DS/ISO 2768-1 m		Released:	26.01.04
Material:	Rustfri stål	Format:	A4
Weight:	0,05 kg	Scale:	2:1
Model no.:	-	Item no.:	541808
Drawingtype:	Emnetegning	Drawing no.:	2100-174 a
Location of file:	M:\ord\Tejninger\Udlandordboks\A4 Hængselsstift\1121.DWG	 <small>By appointed to the Royal Danish Court</small>	
Morsø 2100			

This drawing is Morsø Jernstøberi A/S' property and must not be sold, lent or copied without any written authorization from the company.

3-94 of 3-103.




Date of print: 27-10-2005

Material:	Båndstål sort, varmt valset
Weight:	0,1 kg
Model no.:	-
Drawingtype:	Emnetegning
Location of file:	u:\UDV\tegning\4500\tegning\4500-51 kuglespærre 4500-51.DPRT

c	Materiale ændret.	KDU	16.09.05
b	Kuglespærre ændret udseende.	KDU	18.08.05
Rev.	Revisions	Sign.:	Date:
Title:		Construction:	RS 14.02.97
Kuglespærre 4500		Released:	
Morsø 4500		Format:	A4
morsø		Scale:	1:1
Byggesystemet til den Fysiske Design Center		Itemno.:	544541
		Drawing no.:	4500-51 c

This drawing is Morsø Jernstøberi A/S' property and must not be sold, lended or copied without any written authorization from the company.

3-96 of 3-103




f	Fjernet gevindhuller og bukket begge ender.	RSV	05.09.05
e	Ændret mål.	RSV	14.12.2001
d	Ændret mål.	RSV	05.03.1999
c	Varenr. + mål ændret.	RSV.	14.02.1997
b	-	KAA.	26.09.1995
Rev.	Revisions	Sign.:	Date:

Date of print: 27-10-2005

Mål uden toleranceangivelse i.h.t. DS/ISO 2768-1 m		Title:		Construction:	CHK	21.11.1994
Material:	Båndstål sort, varmt valset	Bøjle til røgdæksel		Released:		
Weight:	0,04 kg	Morsø 5000		Format:	A4	
Model no.		morsø		Scale:	1:1	
Drawingtype:	Emnetegning	<small>Byggesystem til den flyvende dansk</small>		Itemno.:	545006	
Location of file:	U:\ud\A\tegringer\5000\TEGNING\5000-63 bøjle til dæksel.LSPRT			Drawing no.:	5000-63 f	

This drawing is Morsø Jernstøberi A/S' property and must not be sold, lended or copied without any written authorization from the company.



3-17 of 3-103



Ø10x1 Hydraulikrør galv.

Titel: Afstandsør Til bøjle på røgdæksel	Sign.: RS	Dato: 970214	Revision	Sign.	Dato
	Tegn.form.: A4	Målforshold: 5:1			
Tegningsnummer: 5000-64-4	Varenummer: 545007				
morsø <small>Jernløbent A/S</small>	Filnavn: 5000-64				

3-98 of 3-103




Date of print: 27-10-2005

		Rev. Revisions	Sign.:	Date:
Mål uden toleranceangivelse i.h.t. DS/ISO 2768-1 m		Title:	Construction:	RSV
Material:	Automatstål	Hængselsstift $\varnothing 5 \times 75$	Released:	
Weight:	0,01 kg	Morsø 5000	Format:	A4
Model no.:	-	morsø	Scale:	2:1
Drawingtype:	Emnetegning	<small>Byggesystemer til og Regal Systemer</small>	Itemno.:	545008
Location of file:	U:\GDV\Tegninger\Udvalgte\Bib\olek\Hængselsstift\LD1007		Drawing no.:	5000-85 a

This drawing is Morsø Jernstøberi A/S' property and must not be sold, lended or copied without any written authorization from the company.

3-99 + 3-103







Date of print: 27-10-2005

Mål uden toleranceangivelse i.h.t. DS/ISO 2768-1 m		Rev. Revisions	Sign.:	Date:
Material:	SPD Plade	Title:	Construction:	KDU 02.02.05
Weight:	0,25 kg	Rundel ø 200mm	Released:	KDU 02.02.05
Model no.:	-	Morsø 5000	Format:	A4
Drawingtype:	Emnetegning	morsø <small>Byggeteknik til den Rigtige Døds</small>	Scale:	1:1
Location of file:	U:\udv\tegringer\5000\TEGHNOC\5000-91 Rundel ø200 mm31.DWG		Itemno.:	545010
			Drawing no.:	5000-91 a

This drawing is Morsø Jernstøberi A/S' property and must not be sold, lended or copied without any written authorization from the company.





3-100 of 3-103



Date of print: 27-10-2005

Mål uden toleranceangivelse i.h.t. DS/ISO 2768-1 m		b Materiale ændret til rustfri. Hul tilføjet.		KDU	27.01.05
Material:	Rustfri stål	Rev. Revisions		Sign.:	Date:
Weight:	0,06 kg	Title:		Construction:	KDU 14.01.04
Model no.	-	Stopbeslag - venstre for varmeskjold Morsø 7110		Released:	KDU 02.04.04
Drawingtype:	Emnetegning	morsø		Format:	A4
Location of file:	\\AUDV\tegringer\7100\7100-39 stopbeslag varmeskjold - venstre.31.DWG	Byggepartnerne		Scale:	1:1
				Itemno.:	71711200
				Drawing no.:	7100-39 b

This drawing is Morsø Jernstøberi A/S' property and must not be sold, lended or copied without any written authorization from the company.



Date of print: 27-10-2005

Mål uden toleranceangivelse i.h.t. DS/ISO 2768-1 m

Material: Rustfri stål

Weight: 0,06 kg

Model no. -



Drawingtype: Emnetegning

Location of file: G:\100\Tegninger\7100\7100-40\stopbeslag varmeskjold - højre.DWG

b	Materiale ændret til rustfri. Hul tilføjet.	KDU	27.01.05
Rev.	Revisions	Sign.:	Date:
Title:	Stopbeslag - højre for varmeskjold Morsø 7110 morsø <small>By appointment to the Royal Danish Coast</small>	Construction:	KDU 14.01.04
		Released:	KDU 02.04.04
		Format:	A4
		Scale:	1:1
		Itemno.:	71711300
	Drawing no.:	7100-40 b	

This drawing is Morsø Jernstøberi A/S' property and must not be sold, lent or copied without any written authorization from the company.

3-102 of 3-103



Rev. / Revisions	Sign.:	Date:
	RSV	23.09.02
Title:		
Rystestang		
Mål uden toleranceangivelse (h.v. DS/ISO 2768-1 m)	Construction:	RSV
Materiale: Aluminatstål	Released:	RSV
Weight: 0,05 kg	Format:	A3
Model no.	Scale:	1:1
Drawing type: Erneklægning	Item no.:	53001500
Location of file: <small>mountainregion@kvaerner.com</small>	Drawing no.:	Steel-15 a
Side 1 of 1		

This drawing is Morse Jernstøberi A/S property and must not be sold, lent, or copied without any written authorization from the company.

3-103 of 3-103

Date of print: 27-10-2005

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

Section 4


Manufacturer Owner's Manual

morsø

By appointment to  the Royal Danish Court

Installation and Operating Instructions 8100 series

For use in North America



Read this entire manual before you install and use your new room heater. If this room heater is not properly installed, a house fire may result. To reduce the risk of fire, follow the installation instructions. Failure to follow instructions may result in property damage, bodily injury, or even death.

Contact local building officials about restrictions and installation inspection-requirements in your area.

Save these instructions

MORSØ JERNSTØBERI A/S · DK-7900 NYKØBING MORS
E-Mail: stoves@morsoe.com · Website: www.morsoe.com

Distributed by: HEARTHLINK INTERNATIONAL
9 Maple St. - Randolph, Vermont - 05060 - USA

4-2 of 4-12

We congratulate you on your choice of a Morsø stove. Morsø has been producing some of the world's best stoves since 1853. If you follow this installation- and operating instruction carefully, we can assure you many years of warmth and pleasure.

Optional Accessories

A wide range of accessories (such as handling gloves, fireside tools, glass cleaner and heatproof paint) are available for use with your Morsø stove. They help with day-to-day running and maintenance. Contact your Morsø dealer for more information.

The Morsø 8100 series meets the U.S. Environmental Protection Agency's emission limits for wood heaters sold on or after July 1, 1990

The Morsø 8100 series have been tested by OMNI-Test Laboratories, Inc. The test standards are ANSI/UL-1482 for the United States and ULC S627 for Canada.

The stove is listed for burning wood only. Do not burn other fuels.

CONTENTS:

1.0	Installation of your Morsø stove	4
1.1	Checking loose parts in the stove	5
1.2	The chimney / flue system	6
1.3	Flue Connection	7
1.4	Connection to existing chimney	7
1.5	Positioning the stove	9
1.6	Mobile Home Installation	10
2.0	Operation	11
2.1	Before you start firing	11
2.2	Lighting and loading intervals	12
3.0	Maintenance	14
3.1	Exterior maintenance	14
3.2	Internal maintenance	14
3.3	Cleaning the stove and the flue	16
3.4	Leaving the stove for extended periods	17
3.5	Parts diagram	18
3.6	Parts list	19

4-3 of 4-12

1.0 Installation of your Morsø stove

Installation of woodburning stoves must be safe and legal.

If your Morsø stove is not installed correctly, it may cause a house fire. To reduce the risk of fire, the installation instructions must be followed carefully. Contact the local building officials about restrictions and installation inspection in your area.

Before you start installing your stove, make sure that:

- The stove and chimney connection are placed far enough from combustible materials to meet all clearance requirements.
- The floor protection must be adequate and must be made correctly according to the requirements.

All necessary approvals are needed from the local building officials.

The data plate, which is located on the back of the stove, provides information regarding safety testing information, name of certified testing laboratory, and installation requirements.

Installation requirements vary in different districts, and the local building officials have the final authorization to approve your installation. You should discuss the installation with them before beginning. Please ask your dealer for further information.


Do not connect to any air distribution duct or system.

Important: If the installation instructions are not followed carefully, it may cause dangerous situations like chimney - and house fires. Follow the instructions carefully and do not deviate from them as it may cause injuries to people or property.

1.1 Checking loose parts in the stove

After unpacking, check that the fire bricks are firmly in position and have not shifted in transit. Check also that the air control works freely.

Before starting the initial fire, make sure that the baffle is placed correctly, as shown on the images below.



Standard Accessories

A Morsø glove and ceramic flue connection gasket are standard accessories that usually can be found in the ashpan or firebox area.

4-4 of 4-12⁴

1.2 The chimney / flue system

Note that the flue system must be independently secured and must not rely on the stove for support.

The stove must not be connected to a chimney flue serving any other appliance. (Several flues may run up a single chimney stack; use one flue-way per appliance).

Use a residential type masonry or listed type HT factory-built chimney.


High Temperature (H.T.) Chimney Standard UL-103-1985 (2100° F) or a code-approved masonry chimney with flue liner for the USA, and High Temperature (650°C) Standard ULC S-629 for Canada.

The internal dimensions of the chimney connector and chimney must not be less than 6 inches diameter (or equivalent cross section), and should not be significantly larger than this. Too large a section will tend to allow the flue gases to cool excessively, causing sluggishness or unpredictability in the stove's performance.

We recommend the length of the chimney system should be at least 16 feet (not required) above the stove in normal domestic situations, measured from the flue collar to the top of the chimney.

Local conditions like for example - roof constructions, large trees nearby and high altitude, may influence the chimney draft and height. Therefore, contact the local professional chimney sweep or your Morsø dealer.

Typical Factory-Built or Masonry Chimney Installations



1.3 Flue Connection

The stove is supplied from the factory with a round blanking plate blocking off the top and rear flue exit (behind the rear shield plate). A flue collar are placed in the firebox area.

Use a 24 MSG black or blue chimney connector or listed double wall chimney connector. Refer to local codes and the chimney manufacturer's instructions for precautions required for passing a chimney through a combustible wall or ceiling. Remember to secure the chimney connector with a minimum of three screws to the product and to each adjoining section.

The collar can be fitted to the rear outlet. Simply knock out the round panel on the rear heat shield plate to reveal the cast iron plate. Untwist the blanking plate and the flue collar and swap their positions. Re-secure by pushing down and tighten the enclosed screws. Position the stove and connect to the flue system.

Wear gloves and protective eyewear when drilling, cutting or joining sections of chimney connector

1.4 Connection to the existing chimney

A chimney connector is the double-wall or single-wall pipe that connects the stove to the chimney. The chimney itself is the masonry or prefabricated structure that encloses the flue. Chimney connectors are used only to connect the stove to the chimney.

Double-wall connectors must be tested and listed for use with solid-fuel burning appliances. Single-wall connectors should be made of 24 gauge or heavier gauge steel. Do not use galvanized connector; it cannot withstand the high-temperatures that smoke and exhaust gases can reach, and may release toxic fumes under high heat. The connector must be 6 inches (150mm) in diameter.

If possible, do not pass the chimney connector through a combustible wall or ceiling. If passage through a combustible wall is unavoidable, refer to the sections on Wall Pass-Throughs. Do not pass the connector through an attic, a closet or similar concealed space when installing the chimney connectors.

It is important to keep the flue gases moving smoothly in the right direction. Do not vent into a large void at this location; rather form one continuous section all the way up. Use mild bends (e.g. 45° vs. 90°) rather than sharp angles where a change of direction is required. All parts of the venting must be accessible for cleaning purposes.

In horizontal runs of chimney, maintain a distance of 18 inches from the ceiling. Keep it as short and direct as possible, with no more than two 90 degree turns. Slope horizontal runs of connector upward 1/4 per foot (20 mm per metre) going from the stove toward the chimney. The recommended maximum length of a horizontal run is 3 feet (1 metre), and the total length should be no longer than 8 feet (2.5 metres).

Information on assembling and installing connectors is provided by the manufacturer's instructions exactly as you assemble the connector and attach it to the stove and chimney.

Be sure the installed stove and chimney connector are correct distances from near by combustible materials. See the clearance paragraph page 8.

Where passage through a wall or partition of combustible construction is desired, the installation shall conform to CAN/CSA-B365.

4-5 of 4-12

Chimney Connector-Systems and Clearances from Combustible Walls for Residential Heating Appliances

- A** Minimum 3.5-in thick brick masonry all framed into combustible wall with a minimum of 12-in brick separation from clay liner to combustibles. The fireclay liner shall run from outer surfaces of brick wall to, but not beyond, the inner surface of chimney flue liner and shall be firmly cemented in place.
-
- B** Solid-insulated, listed factory-built chimney length of the same inside diameter as the chimney connector and having 1-in. or more of insulation with a minimum 9-in. air space between the outer wall of the chimney length and combustibles.
-
- C** Sheet steel chimney connector, minimum 24 gauge in thickness, with a ventilated thimble, minimum 24 gauge in thickness, having two 1-in. air channels, separated from combustibles by a minimum of 6-in. of glass fiber insulation. Opening shall be covered, and thimble supported with a sheet steel support, minimum 24 gauge in thickness.
-
- D** Solid insulated, listed factory-built chimney length with an inside diameter 2-in. larger than the chimney connector and having 1-in. or more of insulation, serving as a pass-through for a single wall sheet steel chimney connector of minimum 24 gauge thickness, with a minimum 2-in. air space between the outer wall of chimney section and combustibles. Minimum length of chimney section shall be 12-in. chimney section spaced 1-in. away from connector using sheet steel support plates on both ends of chimney section. Opening shall be covered, and chimney section supported on both sides with sheet steel supports securely fastened to wall surfaces of minimum 24 gauge thickness. Fasteners used to secure chimney section shall not penetrate chimney flue liner.
-

1.5 Positioning the stove

Distance to walls and lintel


When the stove is positioned near *combustible* materials, observe all current local and national building regulations with regards to clearances. Whatever regulations apply to your area, do not in any case install the stove within 8 inches of combustible materials around the sides or 16 inches above the top of the stove (fireplace installations require greater clearances above the stove - see below in the clearance chart). These distances may need to be increased if the materials are sensitive to heat. Note also that wall paper and other decorative materials may become detached with the effects of heat and care should be taken to ensure that they do not fall towards the stove in such an event.

When the stove is positioned near *non-combustible* materials, a gap of 4 inches or more is recommended for cleaning purposes and to ensure that heat circulates around the stove and out into the room.

If using rear exit, the floor protection must extend beneath the chimney connector and 2-in beyond each side.


CLEARANCE REQUIREMENTS:	STANDARD RESIDENTIAL INSTALLATION (SINGLEWALL & DOUBLEWALL CONNECTOR):	
A. SIDEWALL TO UNIT	USA	Canada
B. BACKWALL TO UNIT		
C. CORNERWALL TO UNIT		
D. SIDEWALL TO CONNECTOR		
E. BACKWALL TO CONNECTOR		
F. CORNERWALL TO CONNECTOR		
G. UNIT TO CEILING		
H. FLOOR TO CEILING		

MINIMUM CLEARANCES TO COMBUSTIBLES:



CLEARANCE REQUIREMENTS:	ALCOVE INSTALLATION WITH (DOUBLE WALL CONNECTOR):
A. SIDEWALL TO UNIT	
B. BACKWALL TO UNIT	
C. CORNERWALL TO UNIT	
D. SIDEWALL TO CONNECTOR	
E. BACKWALL TO CONNECTOR	
F. CORNERWALL TO CONNECTOR	
G. UNIT TO CEILING	
H. FLOOR TO CEILING	

NON-COMBUSTIBLE FLOOR PROTECTOR



FLOOR PROTECTOR MUST BE NON-COMBUSTIBLE MATERIAL. IT MUST EXTEND BENEATH HEATER, AND TO THE FRONT/SIDEREAR AS INDICATED.

CLEARANCES IN () IN MM FOR CANADA FOR NON-COMBUSTIBLE FLOOR PROTECTOR

Distance to furniture

The recommended minimum distance from stove to furniture is 30 inches. Note that some furniture is more easily affected by heat and may need to be moved to a greater distance. This is your responsibility.

In addition other combustible materials, away from the stove. In general, a distance of 30 inches must be maintained between the stove and moveable combustible item such as drying clothes, newspapers, firewood etc.

1.6 Mobile Home Installation


The Morse 7110 can be installed in a mobile home if equipped with an outside combustion air kit, a terminal cap with a spark arrester, and if it meets the following installation requirements:

- The stove must be secured to the mobile home structure by bolting through the hearth pad and into flooring.
- The stove must be installed with a listed Type HT chimney connector, HT Chimney, and terminal cap with spark arrester. Never use a single wall connector (stovepipe) in a mobile home installation.
- Floor protection requirements in section 1.5 must be followed precisely.
- In Canada, this appliance must be connected to a 6" (152 mm) factory-built chimney conforming to CAN/ULC-629M, STANDARD FOR FACTORY BUILT CHIMNEYS. Floor protection as referenced in section 1.5 must be followed, as well as use of Canadian Floor Protector.
- Follow the chimney and chimney connector manufacturer's instructions when installing the flue system for use in a mobile home.
- Outside air kit should be installed according to installation guide in the kit.
- Intake air piping can be installed through the floor into a vented crawl space or through the wall of the residence to obtain outside air.
- Install in accordance with 24 CFR, Part 3280 (HUD).
- NOTE: Top sections of chimney must be removable to allow maximum clearance of 13.5' from ground level for transportation purposes.

Warning:

Never draw combustion air from a wall, floor or ceiling cavity or from any enclosed space such as an attic or garage.
Do not install in a sleeping room.


ALCOVE INSTALLATION



*Maximum alcove depth must be no more than 48" (1220mm):

Caution:

The structural integrity of the mobile home floor, wall, and ceiling/roof must be maintained (i.e., do not cut through floor joist, wall stud, ceiling truss, etc.)



Note:

Acid Protection

if acid-washing the masonry around the stove, protect the stove surface with an acid-proof cover

Fresh Air Inlet

Unless there is deemed to be sufficient ambient leakage of air into the room via doorways, windows and the like, a dedicated fresh air inlet will be needed. This inlet should have 2 square inches (1250 square mm) of free air space. This is particularly important where the room is well sealed, or where an extractor hood or ventilation system disturbs the natural air pressure. Such an inlet should not be on a wall that is usually subject to negative pressure from normal wind pattern. Avoid placing the inlet directly across the room from the stove, thus causing a cold air draft.

2.0 Operation

2.1 Before you start firing

For Use with Solid Wood Fuel Only. Do Not Overfire, if Heater or Chimney Connector Glows You Are Overfiring. Inspect and Clean Chimney Frequently. Under Certain Conditions of use creosote buildup may occur rapidly. Because of risk of smoke and flame spillage, operate only with door fully closed.

Caution:

Hot while in operation. Keep children, clothing and furniture away. Contact may cause skin burns.

Do not use chemicals or fluids to start the fire.

Do not burn garbage or flammable fluids.

Do not use gasoline, gasoline-type lantern fuel, kerosene, charcoal lighter or fluid or similar liquids to start or freshen up a fire in this heater. Keep all such liquids away from the heater while it is in use.

Choosing your fuel

All types of natural wood can be burned on your stove, but they must be well-seasoned and dry. Once the wood is cut to length, it should be split down middle - to suit the dimensions given below - to allow moisture to evaporate.

4-7 of 4-12

Cut the wood to a length of max 15 inches (38 cm) and approx. 3 to 3.5 inches (7-8 cm) in section. If you can weigh your wood, aim for around 2 Lbs. The maximum moisture content of the wood should be around 20%.

Store the logs under cover in a location where fresh air can move through the stack. Some soft woods may take as little as one good summer to season whereas harder woods such as oak, maple, and elm may require seasoning up to 18 months. Avoid overly dry wood that is gray in color as it can cause performance problems, such as backpuffing and sluggishness, under certain conditions. Well seasoned wood will be remarkably light to hold and will probably have radial cracking at the ends. If your wood splits or sizzles when burnt, and your stove's door glass persistently mists up, your wood is not properly seasoned. Never use drift wood (from the sea), whose salt content may cause corrosion, nor construction wood that may have been impregnated with chemicals.

Caution: Do not place fuel within the installation clearances for the stove or within the space required for loading fuel and ash removal.

Starting the First Fire

The initial fire should be small, so that the stove paint can cure and the main plates of the stove can settle into position. Some fumes will be given off by the paint. Ventilate the room during this phase.

The setting of the air control, lighting techniques and loading intervals will depend on chimney draft, the fuel used, the heat required and so on. Some basic techniques are outlined below.

In principle

Your stove is fitted with Primary and Secondary air inlets.

Primary Air is controlled using the lever situated over the door. Moving the control lever to right position will open the air inlet and will allow a supply of preheated air to enter the firebox via the 'airwash' system situated inside the stove and above the glass.

The secondary air is injected into the flue gases above the fire resulting in a cleaner, more efficient combustion process. The supply of secondary air is fixed open and is not adjustable. For extra safety, your stove has been fitted with a removable handle.

2.2 Lighting and loading intervals

When first lighting the stove, a large volume of air is needed. When the stove is cold, you should leave the door open an inch or two for the first few minutes and open the primary air supply completely. While the door is open, do not leave the stove unattended.

To form a reasonable bed of ash on the floor of the stove, you should use 2-4 pounds of dry kindling at the initial lighting. If possible, maintain a 1-1.5 inch (2-3 cm) layer of ash on the floor of the combustion chamber for added insulation.

Step-by-step procedure



1. The air supply must be fully open.
2. Light the fire. An ember bed will quickly be formed by lighting with firelighters, morsø kindling bags or 7-10 pieces of twisted paper under the dry kindling wood (see below).
3. After lighting, partially close the door, leaving it open an inch or two to allow in plenty of combustion air.
4. When the chimney is warm after about 5-10 minutes, the door should be closed. A suitable layer of ember will be formed after a about 15-20 minutes.

5. When ready to reload, use a poker to spread the ember across the firebox floor, bringing plenty towards the front of the stove.
6. Lay three pieces of wood onto the embers. Leave half an inch (1 cm) or more between each piece. When using 10 inch (25 cm) logs, place the ends of your logs towards the opening, but not too close to the front.

7. Close the door. Leave the primary air supply fully open.

8. After a few minutes, adjust the primary air supply to suit your heating requirements.

9. For refueling, add a layer of wood while there are still plenty of live embers. Repeat steps 5-8.



Do not for any reason attempt to increase the firing of your heater by altering the air control adjustment range outlined in these directions.

Warning: Fireplace stoves must never be left unattended with the door open.

If the door are left partly open, gas and flame may be drawn out of the fireplace stove opening, creating risks from both fire and smoke. We recommend you to fit a smoke detector in the room where the stove is installed.

DO NOT OVERFIRE THIS HEATER. Overfiring may cause a house fire, or can result in permanent damage to the stove. If any part of the stove glows, you are overfiring.

Draft conditions

If smoke or fumes come out of your stove when lightning up and reloading, or if the fire simply will not respond, a poor draft is almost certainly to blame. (In a very few cases, there may be insufficient fresh air getting into the room - see installation advice above). Take advice from your stove supplier on how best to upgrade your flue system to improve draft.

Rules of woodburning

If you want less heat, put fewer logs on the stove and reduce the amount of air. It is still important to maintain a good layer of embers.

Less heat - less wood - less air

Greater heat - more wood - more air

Soot deposits will settle on the glass if the stove is run too slowly or if your wood is not well seasoned.

3.0 MAINTENANCE

When performing maintenance on your stove, always protect yourself, using safety goggles or gloves

3.1 Exterior Maintenance

The stove surface is painted with heat-resistant Senotherm paint. It is best kept clean by vacuuming with a soft brush attachment or by wiping with a lint-free cloth. Over a period of time, the painted surface may become slightly grey. A can of Morsø touch-up spray paint should be available from your stove supplier. This can be applied - in accordance with the instructions - in just a few minutes. When first firing after touching up, the stove will give off a slight smell as the paint cures. Make sure to ventilate the room well during this phase.

3.2 Internal maintenance

Glass

If the stove is generally run at the correct temperatures, there should be little or no dirt on the glass. If dirt does settle during lighting, most will burn off as temperatures increase. For heavier deposits that will not burn off, use morsø glass cleaner, applied when the glass is cold, in accordance with the instructions. Never use abrasive cleaners on the glass surface.

Reasons for dirty glass

- Fuel too wet
- Logs too large or not split
- Combustion temperatures too low


Replace broken glass immediately.

Do not operate your stove if the glass in the door is damaged.

If you need to replace the glass, it should be replaced with the high temperature ceramic glass supplied by Morsø, contact your Morsø dealer.

Installing the glass

Never install the glass when the stove is in function.



1. When you open the door, you will find two small M4 unbraco screws, one in each hinge. Unscrew the two screws, lift the door off the hinges and place it face down on a sheet of cardboard or other nonabrasive fabric.

2. Unscrew the 4 bolts that secure the glass. (In the event that a bolt sheers off when being unscrewed, remove the remaining body of the bolt by drilling down its centre with 1/8 inch high speed steel drill bit. Smaller drill bits may be successful, but do not use a larger bit. Make sure the bit stays away from the edges of the bolt - this may damage the thread in the cast iron).

3. Remove the old ceramic gaskets and clean up the surface underneath with wire wool or emery paper to remove loose particles.

4. Place the new gasket material in position around the perimeter of the window area, making sure to pinch them to the length in such a way that they make a continuous seal. Leave no gaps.

5. Place the new glass in position on the strips and screw home the fresh bolts and fitting by hand.

6. Finally, give each of the bolts an extra half turn or so. The glass should held tight enough that cleaning will not dislodge it. Do not over-tighten the bolts as this may put excessive pressure on the glass, resulting in cracking - important!

To reduce the risk of breaking the glass, avoid striking the glass or slamming the door.

Internal service parts

The flame-path equipment - consisting of the ashpan, grate, firebricks, Cast iron fire plates, glass, baffle and flue collar - are subject to the extremes of heat produced by the fire. From time to time, one or other of these parts may need replacing as a matter of routine maintenance.

NOTE: The flame-path equipment, the ceramic rope and the paint finish are not covered by guarantee.

All of these service parts can be bought from your morsø dealer, and we recommend that damaged parts are replaced as soon as possible to avoid collateral damage. Should the baffle be distorted by an overfire, the stove will still function, although its efficiency may be compromised. Replace it as soon as possible.

Reasons for fast internal wear and tear

Persistent heavy firing
Soot and ashes left to accumulate

Gasket

The gasket around the perimeter of the door may harden over a period of time. It should be replaced if it becomes difficult to close the doors or if air starts to leak in around the perimeter of the doors, causing the fire to become a little less controllable. A morsø rope gasket kit is available from your stove supplier.

3.3 Cleaning the Stove and the Flue

Check for soot above the baffle plate and around the flue outlet every month or so to start with. If the stove suddenly becomes sluggish, check for a soot fall around the flue collar or in the flue/chimney.

The chimney and chimney connector should be inspected at least once every two months during the heating season to determine if a creosote buildup has occurred. If creosote has accumulated, it should be removed to reduce the risk of a chimney fire.

Clean the flue/chimney - all the way from the stove to the flue terminal point above the house. A good routine is to clean the flue after each heating season in any case, and inspect prior to the season to ensure that bird's nests or other blockages have not occurred during the off season.

Ash disposal

Empty the ashpan on a daily basis or as needed. Ash allowed to build up towards the underside of the grate will trap heat and could cause premature failure of the grate.

Empty the ashpan according to this procedure:

Open the front door, and use a shovel or poker to stir excess ash through the ash slots in the grate down into the ash pan. Take out the ash pan, making sure to keep it level to avoid spilling ash.

Dispose the ash in a metal container with a tight fitting lid.

The closed container of ashes should be placed on a noncombustible floor or on the ground, well away from all combustible materials, pending final disposal. If the ashes are disposed of by burial in soil or otherwise locally dispersed, they should be retained in the closed container until all cinders have thoroughly cooled.

Return the ash pan to its original position in the stove, and close the door.

Caution:

**Never empty a stove in operation.
Never use your household or shop vacuum cleaner to remove ash from the stove;
always remove and dispose of the ash properly.**

Creosote - formation and need for removal

When wood is burned slowly, it produces tar and other organic vapors, which combine with expelled moisture to form creosote. The creosote vapors condense in the relatively cool chimney flue of a slow-burning fire. As a result, creosote residue accumulates on the flue lining. When ignited this creosote makes an extremely hot fire. When burning wood, the chimney and chimney connector should be inspected at least once every two months during the heating season to determine if a creosote buildup has occurred. If creosote has accumulated, it should be removed to reduce the risk of a chimney fire.

Chimney sweeping

Inspect the system regularly during the heating season as part of a regular maintenance schedule. To inspect the chimney, let the stove cool completely. Then, using a mirror, sight up through the flue collar into the chimney flue. If you cannot inspect the flue system in this fashion, the stove must be disconnected to provide better viewing access.

Clean the chimney using a brush the same size and shape as the flue liner. Run the brush up and down the liner, causing any deposits to fall to the bottom of the chimney where they can be removed through the clean-out door.

Clean the chimney connector disconnecting the sections, taking them outside, and removing any deposits with a stiff wire brush. Reinstall the connector sections after cleaning, being sure to secure the joints between individual sections with sheet metal screws.

If you cannot inspect or clean the chimney yourself, contact your local Morsø Dealer or a professional chimney sweep.

If you do experience a chimney fire, act promptly and:

Close the air control.

Get everyone out of the house.

Call the Fire Department.

Annual maintenance

Before the heating season, perform a thorough cleaning, inspection and repair:

Thoroughly clean the chimney and chimney connector.

Inspect the chimney for damage and deterioration. Replace weak sections of prefabricated chimney. Have a mason make repairs to a masonry chimney.

Inspect the chimney connector and replace any damaged sections.

Check gasketing for wear or compression, and replace if necessary.

Check the glass for cracking; replace if needed.

Check door and handle for tightness. Adjust if needed.

3.4 Leaving the stove for extended periods

Important:

If the stove is to be left unused for any period of time, clean it out thoroughly and leave the air control slightly open to allow airflow. Make sure that the flue does not allow rainwater to come anywhere near the stove; install a chimney cap, but do not block off the flue completely.

These measures should ensure there is a slight movement of air through the stove, and that the body of the stove remains dry, right into the corners.

Any ash left within an unfired stove can attract moisture like blotting paper. If moisture is allowed to settle within the stove, rust will form. Rust expands as it takes a grip. This can lead to undue pressure on the stove joints, and this in turn may result in damage to the stove.


NOTE: It is best to thoroughly clean the stove after the heating season has concluded. Adding a desiccant, such as kitty litter, into the ash pan helps absorb moisture during the summer months. Be sure to remove this prior to the heating season.

Thank you for buying a morsø stove.

We hope you have many years of carefree warmth in its company. Some initial experimentation with loading and running techniques will decide your normal routine. If you have any problems after this short learning phase, please refer to your stove dealer. Should they be unable to help for any reason, please contact us in writing at the address on the front of this publication.


410 of 412

3.5 Parts diagram for model Morsø 8100



3.6 Parts list for model Morsø 8100

Pos.No.	Parts	8140	8142
1	Top plate, outside	448110XX	448110XX
2	Top frame	448107XX	448107XX
3	Socle, high	348111XX	-
4	Front frame	448131XX	448131XX
5	Door	448103XX	448103XX
6	Side plate, right	44810400	44810400
7	Side plate, left	44812300	44812300
8	Rear plate, inside	44810500	44810500
9	Base plate, inside	44812200	44810100
10	Top plate, inside	44810600	44810600
11	Side plate, outside	448108XX	448108XX
12	Rear plate, outside	448109XX	448109XX
13	Intermediate frame	34811300	34811300
14	Brick, back	79810200	79810200
15	Brick, side, right	79810300	79810300
16	Brick, side, left	79810400	79810400
17	Flue collar	443441XX	443441XX
19	Stop bar	544541	544541
20	Screw	-	-
21	Ceramic glass	79810100	79810100
22	Cover	442610XX	442610XX
23	Flat bar	545006	545006
24	Distance tube	545007	545007
25	Screw	-	-
27	Air canal, rear	44811600	44811600
28	Air adaptor	44142600	44142600
29	Air canal, top	448117XX	448117XX
30	Washer	-	-
31	Screw	-	-
32	Screw	-	-
33	Glass fitting	790743	790743
34	Screw	-	-
35	Riddling grate	44182800	44182800
36	Sek. draught control	71814400	71814400
37	Handle f. sek. draught control	71810761	71810761
38	Screw	-	-
39	Closing plate	71810600	71810600
40	Air canal, front	44811500	44811500
41	Tertiary box	71810861	71810861
42	Baffle plate, bottom	79810500	79810500
43	Cover	448120XX	448120XX
44	Baffle plate, top	79810600	79810600
45	Distance tube	71810300	71810300
46	Distance tube	71810200	71810200
47	Screw	-	-
48	Screw	-	-
49	Fitting plate	71811161	71811161
50	Screw	-	-



4-11 of 4-12

Pos.No.	Parts	8140	8142
51	Screw	-	-
52	Riddling bar	53001500	53001500
53	Bush	752621	752621
54	Knob f. riddling bar	752619	752619
55	Ash tray	71811300	71811300
58	Bush	71813061	71813061
59	Hinge pin	541808	541808
60	Screw	-	-
61	Screw	-	-
62	Washer	-	-
63	Handle	75262800	75262800
64	Fitting f. closing plate	71813300	71813300
66	Hinge pin	71810100	71810100
67	Screw	-	-
68	Screw	-	-
69	Radiant shielding, bottom	71810400	71810400
70	Distance tube	542641	541439
71	Washer	-	-
72	Radiant shielding, rear	71811400	71811400
73	Distance tube	541439	541439
74	Screw	-	-
75	Stop fitting, left	71711200	71711200
76	Stop fitting, right	71711300	71711300
77	Fitting f. cover	71813200	71813200
78	Round plate	545010	545010
79	Hinge pin	54501800	54501800
80	Hinge pin	545008	545008
82	Screw	-	-
83	Bottom plate, outside socle	-	448112xx
84	Bottom plate, outside socle	-	448127xx
85	Leg	-	448118xx
86	Cover plate, rear, for leg	-	348121xx
87	Rubber stop block	-	79082007
88	Screw	-	-
89	Drawer, front	-	448119xx
90	Drawer, box	-	718127xx
91	Cover plate f. drawer section	-	718126xx
92	Mounting plate, drawer section	-	718128xx
93	Ball barrel	-	79082006
94	Screw	-	-
95	Screw	-	-
96	Screw	-	-
105	Tightening tape	79074200	79074200
106	Screw	-	-
107	Washer	-	-
108	Screw	-	-
109	Screw	-	-
114	Screw	-	-

4-12 of 4-12

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

Section 5

Quality Assurance/Quality Control

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

QUALITY ASSURANCE/QUALITY CONTROL

O-TL follows the guidelines of ISO/IEC 17025, "General Requirements for the Competence of Testing and Calibration Laboratories," and the quality assurance/quality control (QA/QC) procedures found in O-TL's Quality Assurance Manual.

O-TL's scope of accreditation includes, but is not limited to, the following:

- ANSI (American National Standards Institute) for certification of product to safety standards.
- to perform product safety testing by the International Approval Service (formerly ICBO ES) under accreditation as a testing laboratory designated TL-130.
- to perform product safety testing as a "Certification Organization" by the Standards Council of Canada (SCC).
- as a testing laboratory for the certification of wood heaters by the U.S. Environmental Protection Agency.

This report is issued within the scope of O-TL's accreditation. Accreditation certificates are available upon request.

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

Sample Analysis
Analysis Worksheets
Tared Filter and Beaker Data
Solvent Blank Data

Dilution Tunnel (Method 5G) Analysis Worksheet

Client: Morso
 Model: 8100
 Project #: 192-S-07-3 Tracking #: 786
 Date: 10-6-05 Test Crew: BR Run #: 1
 Sample Train #: A Train assembled by: BR
 Balance ID #: OMNI - 00023 Thermo/Hygro meter ID #: OMNI - 291
 Audit weight ID #: OMNI - 00131 (Balance audit mfr. std: 500 ± 0.72 mg)

Train Part	Weighing Record						
	Date	Time	Weight (grams)	Audit (grams)	R/H %	Temp. (F)	Initials
Front Filter							
Lab ID # _____	<u>10-7-05</u>	<u>1705</u>	<u>.5667</u>	<u>.5001</u>	<u>8</u>	<u>70</u>	<u>BR</u>
ID # <u>M 832</u>	<u>10-10-05</u>	<u>0835</u>	<u>.5653</u>	<u>.5001</u>	<u>11</u>	<u>69</u>	<u>BR</u>
Tare wt. <u>.5479</u>							
D/T in desiccator <u>10-6-05 16:45</u>	<u>10-11-05</u>	<u>0846</u>	<u>.5652</u>	<u>.5001</u>	<u>10</u>	<u>69</u>	<u>BR</u>
Preliminary wt.: <u>.5679</u>							
Rear Filter							
Lab ID # <u>M 831</u>	<u>10-7-05</u>	<u>1705</u>	<u>.5489</u>	<u>.5001</u>	<u>8</u>	<u>70</u>	<u>BR</u>
ID # <u>.5476</u>	<u>10-10-05</u>	<u>0835</u>	<u>.5488</u>	<u>.5001</u>	<u>11</u>	<u>69</u>	<u>BR</u>
Tare wt. _____							
D/T in desiccator: <u>10-6-05 16:45</u>							
Preliminary wt.: <u>.5476</u>							
Acetone Rinse							
Lab ID # _____	<u>10-11-05</u>	<u>0840</u>	<u>109.9198</u>	<u>.5001</u>	<u>10</u>	<u>68</u>	<u>BR</u>
Beaker # <u>2108</u>							
Tare wt. <u>109.9144</u>	<u>10-12-05</u>	<u>0750</u>	<u>109.9198</u>	<u>.5001</u>	<u>8</u>	<u>69</u>	<u>BR</u>
Volume <u>95</u> ml							
Cleaned by: <u>BR</u>							
Solvent #: <u>SA 075</u>							
D/T in desiccator: <u>10-10-05 0835</u>							
Preliminary wt.: <u>109.9211</u>							

Technician signature: BR Date: 10-12-05

Dilution Tunnel (Method 5G) Analysis Worksheet

Client: Morso
 Model: 8100
 Project #: 192-S-07-3 Tracking #: 786
 Date: 10-6-05 Test Crew: B Davis Run #: 2
 Sample Train #: A Train assembled by: BD
 Balance ID #: OMNI - 00023 Thermo/Hygro meter ID #: OMNI - 291
 Audit weight ID #: OMNI - 00131 (Balance audit mfr. std: 500 ± 0.72 mg)

Train Part	Weighing Record						
	Date	Time	Weight (grams)	Audit (grams)	R/H %	Temp. (F)	Initials
Front Filter							
Lab ID # _____	<u>10-8-05</u>	<u>0940</u>	<u>.5807</u>	<u>.5001</u>	<u>11</u>	<u>69</u>	<u>BD</u>
ID # <u>M534</u>	<u>10-10-05</u>	<u>0835</u>	<u>.5802</u>	<u>.5001</u>	<u>11</u>	<u>69</u>	<u>BD</u>
Tare wt. <u>.5507</u>							
D/T in desiccator <u>10-7-05 0755</u>							
Preliminary wt.: <u>.5810</u>							
Rear Filter							
Lab ID # _____	<u>10-8-05</u>	<u>0940</u>	<u>.5530</u>	<u>.5001</u>	<u>11</u>	<u>69</u>	<u>BD</u>
ID # <u>M833</u>	<u>10-10-05</u>	<u>0835</u>	<u>.5520</u>	<u>.5001</u>	<u>11</u>	<u>69</u>	<u>BD</u>
Tare wt. <u>.5526</u>	<u>10-11-05</u>	<u>0840</u>	<u>.5516</u>	<u>.5001</u>	<u>10</u>	<u>69</u>	<u>BD</u>
D/T in desiccator: <u>10-7-05 0755</u>							
Preliminary wt.: <u>.5532</u>							
Acetone Rinse							
Lab ID # _____	<u>10-11-05</u>	<u>0840</u>	<u>102.8383</u>	<u>.5001</u>	<u>10</u>	<u>69</u>	<u>BD</u>
Beaker # <u>2206</u>	<u>10-12-05</u>	<u>0755</u>	<u>102.8382</u>	<u>.5001</u>	<u>8</u>	<u>69</u>	<u>BD</u>
Tare wt. <u>102.8320</u>							
Volume <u>85 ml</u>							
Cleaned by: <u>BD</u>							
Solvent #: <u>SA075</u>							
D/T in desiccator: <u>10-10-05 0835</u>							
Preliminary wt.: <u>102.8391</u>							

Technician signature: BD Date: 10-12-05

Dilution Tunnel (Method 5G) Analysis Worksheet

Client: Morso
 Model: 8100
 Project #: 192-S-07-3 Tracking #: 786
 Date: 10-7-05 Test Crew: BR Run #: 3
 Sample Train #: A Train assembled by: BR
 Balance ID #: OMNI - 00023 Thermo/Hygro meter ID #: OMNI - 291
 Audit weight ID #: OMNI - 00131 (Balance audit mfr. std: 500 ± 0.72 mg)

Train Part	Weighing Record						
	Date	Time	Weight (grams)	Audit (grams)	R/H %	Temp. (F)	Initials
Front Filter							
Lab ID # _____	<u>10-8-05</u>	<u>18:40</u>	<u>.5633</u>	<u>.5001</u>	<u>9</u>	<u>68</u>	<u>BR</u>
ID # <u>M886</u>	<u>10-11-05</u>	<u>08:40</u>	<u>.5631</u>	<u>.5001</u>	<u>10</u>	<u>69</u>	<u>BR</u>
Tare wt. <u>.5528</u>							
D/T in desiccator <u>10-7-05 12:50</u>							
Preliminary wt.: <u>.5639</u>							
Rear Filter							
Lab ID # _____	<u>10-8-05</u>	<u>18:40</u>	<u>.5487</u>	<u>.5001</u>	<u>9</u>	<u>68</u>	<u>BR</u>
ID # <u>M835</u>	<u>10-11-05</u>	<u>08:40</u>	<u>.5487</u>	<u>.5001</u>	<u>10</u>	<u>69</u>	<u>BR</u>
Tare wt. <u>.5489</u>							
D/T in desiccator: <u>10-7-05 12:50</u>							
Preliminary wt.: <u>.5494</u>							
Acetone Rinse							
Lab ID # _____	<u>10-11-05</u>	<u>08:40</u>	<u>116.4722</u>	<u>.5001</u>	<u>10</u>	<u>67</u>	<u>BR</u>
Beaker # <u>2271</u>	<u>10-12-05</u>	<u>07:05</u>	<u>116.4721</u>	<u>.5001</u>	<u>8</u>	<u>69</u>	<u>BR</u>
Tare wt. <u>116.4653</u>							
Volume <u>75</u> ml							
Cleaned by: <u>BR</u>							
Solvent #: <u>SA075</u>							
D/T in desiccator: <u>10-10-05 08:35</u>							
Preliminary wt.: <u>116.4734</u>							

Technician signature: BR Date: 10-12-05

Dilution Tunnel (Method 5G) Analysis Worksheet

Client: Morso
 Model: 8100
 Project #: 192-S-07-3 Tracking #: 786
 Date: 10-7-05 Test Crew: B. Adams Run #: 4
 Sample Train #: A Train assembled by: BA
 Balance ID #: OMNI - 00023 Thermo/Hygro meter ID #: OMNI - 291
 Audit weight ID #: OMNI - 00131 (Balance audit mfr. std: 500 ± 0.72 mg)

Train Part	Weighing Record						
	Date	Time	Weight (grams)	Audit (grams)	R/H %	Temp. (F)	Initials
Front Filter							
Lab ID # _____	<u>10-8-05</u>	<u>18:40</u>	<u>.5524</u>	<u>.5001</u>	<u>9</u>	<u>68</u>	<u>BA</u>
ID # <u>M838</u>	<u>10-11-05</u>	<u>0840</u>	<u>.5523</u>	<u>.5001</u>	<u>10</u>	<u>69</u>	<u>BA</u>
Tare wt. <u>.5455</u>							
D/T in desiccator <u>10-7-05 18:15</u>							
Preliminary wt.: <u>.5526</u>							
Rear Filter							
Lab ID # _____	<u>10-8-05</u>	<u>18:40</u>	<u>.5423</u>	<u>.5001</u>	<u>9</u>	<u>68</u>	<u>BA</u>
ID # <u>M837</u>	<u>10-11-05</u>	<u>0840</u>	<u>.5423</u>	<u>.5001</u>	<u>10</u>	<u>69</u>	<u>BA</u>
Tare wt. <u>.5438</u>							
D/T in desiccator: <u>10-7-05 18:15</u>							
Preliminary wt.: <u>.5431</u>							
Acetone Rinse							
Lab ID # _____	<u>10-11-05</u>	<u>0840</u>	<u>104.4001</u>	<u>.5001</u>	<u>10</u>	<u>68</u>	<u>BA</u>
Beaker # <u>912</u>							
Tare wt. <u>104.3940</u>	<u>10-12-05</u>	<u>0755</u>	<u>104.4000</u>	<u>.5001</u>	<u>8</u>	<u>69</u>	<u>BA</u>
Volume <u>100</u> ml							
Cleaned by: <u>BA</u>							
Solvent #: <u>SA025</u>							
D/T in desiccator: <u>10-10-05 0835</u>							
Preliminary wt.: <u>104.4015</u>							

Technician signature: B. Adams Date: 10-12-05

Date Placed in Desiccator 29-Sep-05
 Time Placed in Desiccator 8:25 AM
 Technician Davis

Balance ID Number OMNI-00023
 Audit Weight ID Number OMNI-00131
 Thermometer/Hygrometer ID Number _____

250 ml Beaker Tares
OMNI-Test Laboratories, Inc

Date: 9/30/2005 10/3/2005
 Time: 9:15 AM 8:00 AM
 RH %: 12 10
 T (F): 69 68
 Beakers Tech.: Davis
 ID Number Audit: 0.5001 0.5001

ID Number	Manufacturer	Appliance	Project No.	Run	Train
2241	Morso	8100	192-S-07-3	3	A
2206	Morso	8100	192-S-07-3	2	A
912	Morso	8100	192-S-07-3	4	A
2108	Morso	8100	192-S-07-3	1	A

Date Placed in Desiccator

18-Aug-05

Balance ID Number OMNI-00023

Time Placed in Desiccator

8:10 AM

Audit Weight ID Number OMNI-00131

Technician Morgan

Thermometer/Hygrometer ID Number

Date: 8/25/2005
Time: 7:50 AM
RH %: 4
T (F): 74
Tech.: Morgan
Filters
ID Number Audit: 0.5001

8/26/2005
9:50 AM
6
80
Davis
0.5001

AE Glass 102 mm Filter Tares OMNI-Test Laboratories, Inc

ID Number	Manufacturer	Appliance	Project No.	Run	Train
M831	Morso	8100	192-S-07-3	1	A
M832	Morso	8100	192-S-07-3	1	A
M833	Morso	8100	192-S-07-3	2	A
M834	Morso	8100	192-S-07-3	2	A
M835	Morso	8100	192-S-07-3	3	A
M836	Morso	8100	192-S-07-3	3	A
M837	Morso	8100	192-S-07-3	4	A
M838	Morso	8100	192-S-07-3	4	A

Model: 8140
 Morsø Jernstøberi A/S
 Furvej 6 DK-7900
 Nykøbing Mors
 DENMARK

Calibrations

Method 28 and 5G

Method 28 and 5G:

ID #	Lab Name/Purpose	Log Name	Attachment Type
1	Calibrator Dry Gas Meter	Standard Test Meter – Rockwell Int'l	Calibration Log
21	Dry Gas Meter	Dry Gas Meter – Sierra-Misco	Post-Test Calibration Log
32	Vaneometer	Vaneometer, Air Velocity Meter – Dwyer	Calibration Log
33	Manometer	Microtector – Dwyer	Manual
112	Thermometer	Temperature Controller Meter – Omega	Calibration Log
126	Draft Gauge	Magnehelic, 0-0.25" H2O – Dwyer	Calibration Log
131	500 mg Weight	Weight Standard, 500 mg – Ohaus	Calibration Log
132	10 lb Weight	Weight Standard, 10 lb.	Calibration Log
156	Incline Manometer	Incline Manometer 0-10" – Dwyer	Calibration Log
185	Platform Scale	Platform Scale – Weight-Tronix	Calibration Log
209	Barometer	Barometer – Princo	Manual Cover
262	Moisture Meter	Moisture Meter – Delmhorst	Manual
291	Relative Humidity Gauge	Digital Hygrometer/Thermometer-VWR	Calibration Log
300	Stopwatch	Stopwatch – Sportline	Calibration Log

Thermal Metering System Calibration Y and dH@

Manufacturer: Sierra-Misco
 Model: 7200
 Serial Number: NA
 OMNI Tracking No.: 21

**Average Orifice
Meter dH@
1.640**

**Average Gas
Meter y Factor
0.999**

Calibration Date: 10/12/05
 Calibrated by: B. Davis
 Calibration Frequency: 8100 Post test
 Next Calibration Due: 04/12/06
 Instrument Range: 1.000 cfm
 Standard Temp.: 68 oF
 Standard Press.: 29.92 "Hg
 Barometric Press.: 30.01 "Hg
 Signature/Date: *B. Davis - 10-12-05*

Previous Calibration Comparison

Date	5/3/05	Acceptable	
dH@ Value	1.624	Deviation (5%)	Deviation
y Factor	0.988	0.0494	0.011
Acceptance	Acceptable		

Current Calibration

Acceptable y Deviation	0.020
Maximum y Deviation	0.006
Acceptable dH@ Deviation	0.200
Maximum dH@ Deviation	0.026
Acceptance	Acceptable

Reference Standard *

Standard Calibrator	Model	Standard Test Meter
	S/N	1
	Calib. Date	20-Apr-05
	Calib. Value	0.9823 y factor (ref)

Calibration Parameters	Run 1	Run 2	Run 3
Vacuum ("Hg)	0.00	0.00	0.00
dH ("H2O)	0.75	0.75	0.75
Initial Reference Meter	131.919	136.934	141.985
Final Reference Meter	136.934	141.927	147.019
Initial DGM	849.8	854.915	860.1
Final DGM	854.915	860.025	865.263
Temp. Ref. Meter (°F), Tr	65.0	63.0	62.0
Temperature DGM (°F), Td	82.0	87.0	87.0
Time (Minutes)	10.0	10.0	10.0
Net Volume Ref. Meter, Vr	5.015	4.993	5.034
Net Volume DGM, Vd	5.115	5.11	5.163
Gas Meter y Factor =	0.992	1.002	1.002
Gas Meter y Factor Deviation (from avg.)	0.006	0.003	0.003
Orifice dH@	1.66	1.65	1.61
Orifice dH@ Deviation (from avg.)	0.020	0.007	0.026

where:

1. Deviation = |Average value for all runs - current run value|
2. $y = [Vr \times (y \text{ factor (ref)}) \times (Pb) \times (Td + 460) / [Vd \times (Pb + (dH / 13.6)) \times (Tr + 460)]$
3. $dH@ = 0.0317 \times dH / (Pb (Td + 460)) \times [(Tr + 460) \times \text{time}] / Vr]^2$

* Reference calibration is traceable to NIST through NIST Test # 40674, Kimble ASTM E1272

Standard Gas Test Meter Calibration vs. Bubble Flowmeter

Date: 4/20/05
 Calibrated by: K. Morgan
 Standard Test Meter S/N: OMNI 00001
 Bubble Flow Meter S/N: OMNI 00134
 Barometric Pressure: 29.94 "Hg

Average Y Factor: 0.9823

(Volume: 1.000 liters = 0.035336 ft3, NIST traceable)

Signature/Date: *K. Morgan* 4-20-05

Flow Rate #1			
dH(pressure across meter, "H2O): 0.1			
	Run #1	Run #2	Run #3
Standard Test Meter			
Initial Volume (ft3):	941.687	942.593	943.237
Final Volume (ft3):	942.56	943.237	944.003
Initial Temperature (oF):	78	78	79
Final Temperature (oF):	79	79	79
Elapsed Time (minutes):	4	3	3
(seconds):	0	0	30
Flow rate, Q (cfm):	0.2182	0.2147	0.2189
Bubble Flowmeter			
Time 1:	9.91	9.87	9.83
Time 2:	9.83	9.92	9.83
Time 3:	9.9	9.92	9.83
Time 4:	9.84	10	9.91
Time 5:	9.94	9.88	9.9
Initial Temperature (oF):	78	79	79
Final Temperature (oF):	78	79	79
Vacuum ("H2O):	1	1	1
Flow rate, Q (cfm):	0.2145	0.2138	0.2150
Y factor:	0.9835	0.9946	0.9823
Deviation of Y factor is acceptable			

Flow Rate #2			
dH(pressure across meter, "H2O): 0.23			
	Run #1	Run #2	Run #3
Standard Test Meter			
Initial Volume (ft3):	944.414	946.058	946.713
Final Volume (ft3):	946.058	946.713	947.52
Initial Temperature (oF):	79	81	81
Final Temperature (oF):	81	81	81
Elapsed Time (minutes):	5	2	2
(seconds):	0	0	30
Flow rate, Q (cfm):	0.3288	0.3275	0.3228
Bubble Flowmeter			
Time 1:	6.72	6.53	6.59
Time 2:	6.56	6.62	6.63
Time 3:	6.64	6.59	6.59
Time 4:	6.54	6.63	6.61
Time 5:	6.65	6.59	6.67
Initial Temperature (oF):	79	81	81
Final Temperature (oF):	81	81	81
Vacuum ("H2O):	1	1	1
Flow rate, Q (cfm):	0.3202	0.3216	0.3204
Y factor:	0.9735	0.9818	0.9922
Deviation of Y factor is acceptable			

Flow Rate #3			
dH(pressure across meter, "H2O): 0.3			
	Run #1	Run #2	Run #3
Standard Test Meter			
Initial Volume (ft3):	948.092	949.054	950.2
Final Volume (ft3):	949.054	950.2	951.143
Initial Temperature (oF):	81	81	82
Final Temperature (oF):	81	82	83
Elapsed Time (minutes):	2	3	2
(seconds):	30	0	30
Flow rate, Q (cfm):	0.3848	0.3820	0.3772
Bubble Flowmeter			
Time 1:	5.66	5.66	5.74
Time 2:	5.74	5.56	5.74
Time 3:	5.6	5.64	5.72
Time 4:	5.56	5.74	5.66
Time 5:	5.61	5.72	5.7
Initial Temperature (oF):	81	82	83
Final Temperature (oF):	81	82	83
Vacuum ("H2O):	1	1	1
Flow rate, Q (cfm):	0.3763	0.3743	0.3712
Y factor:	0.9777	0.9788	0.9829
Deviation of Y factor is acceptable			

Flow Rate #4			
dH(pressure across meter, "H2O): 0.38			
	Run #1	Run #2	Run #3
Standard Test Meter			
Initial Volume (ft3):	951.791	952.636	953.487
Final Volume (ft3):	952.636	953.487	954.335
Initial Temperature (oF):	82	82	82
Final Temperature (oF):	82	82	83
Elapsed Time (minutes):	2	2	2
(seconds):	0	0	0
Flow rate, Q (cfm):	0.4225	0.4255	0.4240
Bubble Flowmeter			
Time 1:	5	5.08	4.86
Time 2:	5.1	5.06	4.94
Time 3:	5.1	4.98	5
Time 4:	5.11	5	4.99
Time 5:	5	5.02	4.96
Initial Temperature (oF):	82	82	82
Final Temperature (oF):	82	82	83
Vacuum ("H2O):	1	1	1
Flow rate, Q (cfm):	0.4188	0.4217	0.4283
Y factor:	0.9911	0.9908	1.0099
Deviation of Y factor is acceptable			

Standard Gas Test Meter Calibration vs. Bubble Flowmeter

Date: 4/20/05
 Calibrated by: K. Morgan
 Standard Test Meter S/N: OMNI 00001
 Bubble Flow Meter S/N: OMNI 00134
 Barometric Pressure: 29.94 "Hg

Average Y Factor: 0.9823

(Volume: 1.000 liters = 0.035336 ft3, NIST traceable)

Signature/Date: _____

Flow Rate #5			
dH(pressure across meter, "H2O):		0.58	
	Run #1	Run #2	Run #3
Standard Test Meter			
Initial Volume (ft3):	956.397	957.689	958.711
Final Volume (ft3):	957.689	958.711	959.725
Initial Temperature (oF):	83	83	84
Final Temperature (oF):	84	84	85
Elapsed Time (minutes):	2	2	2
(seconds):	30	0	0
Flow rate, Q (cfm):	0.5168	0.5110	0.5070
Bubble Flowmeter			
Time 1:	4.34	4.26	4.34
Time 2:	4.26	4.26	4.36
Time 3:	4.34	4.29	4.26
Time 4:	4.3	4.28	4.26
Time 5:	4.34	4.28	4.24
Initial Temperature (oF):	83	83	84
Final Temperature (oF):	84	84	85
Vacuum ("H2O):	1	1	1
Flow rate, Q (cfm):	0.4912	0.4961	0.4940
Y factor:	0.9503	0.9705	0.9741

Deviation of Y factor is acceptable

Acceptance criteria, Method 5 section 16.1.1.5

- The difference between the maximum and minimum values at each flow rate should be no greater than 0.030.
- The meter coefficients (Y) should be between 0.95 and 1.05.

CALIBRATION RECORD

Vaneometer Air Velocity Meter – OMNI-00032

CALIBRATION/SERVICE RECORD			
DATE	BY	RESULTS	DATE OF NEXT CALIBRATION
3/10/98	BD	Installed new vane from factory	9/10/98
9/3/98	BD	Installed new vane from factory	3/3/99
3/8/99	JS	Installed new vane from factory	9/8/99
9/10/99	BD	Installed new vane from factory	3/10/00
3/10/00	BD	Installed new vane from factory	9/10/00
9/13/00	BD	Installed new vane from factory	3/13/01
5/4/01	BD	Installed new vane from factory	11/4/01
11/30/01	BD	Installed new vane from factory	5/30/02
3/20/02	BD	Installed new vane from factory	9/20/02
9/14/02	BD	Installed new vane from factory	3/14/03 ✓
3/14/03	BD	Installed new vane from factory	9/14/03
1-19-04	BD	Installed new vane from factory	7-19-04
7-16-04	BD	Installed new vane from factory	1-16-05
1-16-05	BD	Installed new vane from factory	7-16-05
7-14-05	BD	Installed new vane from factory	1-14-06
		Installed new vane from factory	
		Installed new vane from factory	
		Installed new vane from factory	
		Installed new vane from factory	
		Installed new vane from factory	
		Installed new vane from factory	
		Installed new vane from factory	
		Installed new vane from factory	

Operating & Maintenance Instructions

Negative Pressure or Vacuum Measurement

Zero the gage. Connect the source of vacuum or negative pressure to the right side gage connection (5) and proceed as described under Positive Pressure Measurement Section above. Remember that the pressure measured in this way is negative.

Differential Pressure Measurement

Differential pressures may be measured by connecting the higher (more positive) pressure to the left connection (2) and the lower pressure to the right connection (5).

Storage

Turn meter circuit switch to "off" position and withdraw the point well clear of fluid (by turning Micrometer counter-clockwise) when gage is not in use. This will conserve the batteries and minimize build-up of oxides, etc., on the point. Keep the unit covered and in an area free of strong solvent fumes.

Maintenance

When the meter reading becomes reduced or the pointer movement gets sluggish (with the circuit on and point in fluid), the following should be done:

1. Remove the point (by unscrewing) and clean the tip lightly using fine crocus cloth. Wipe off all grit and dirt with a clean rag, reassemble and recheck meter operation.
2. If the meter operation continues to be sluggish, replace the size AA, 1½ volt battery. (Replace the battery at least once a year to avoid deterioration of battery and damage to gage. Leakproof alkaline battery is recommended.)


To replace the battery, remove center screw (10) located in the back of the

Copyright 1965, Dwyer Instruments, Inc.



DWYER INSTRUMENTS, INC.
P. O. Box 373, Michigan City, Indiana 46360, U.S.A.
Phone: 219/872-8141

Operating and Maintenance Instructions



MICROTECTOR®

Specifications and Features*

Time Proven Hook Gage Manometer Combined with Modern Electronics For Easier, Faster, More Accurate Precision Measurements.

Accurate and Repeatable to ± .00025 inches water column.

Pressure Range 0-2" w.c. Positive, Negative or Differential Pressures.

Non Toxic and Inexpensive Gage Fluid Consists of Distilled Water Mixed with a Small amount of Fluorescein Green Color Concentrate.

Convenient, Portable, Light Weight, and Self-Contained, the Unit Requires No External Power Connections and is Operated by a 1½ Volt Penlight Cell.

A.C. Detector Current Eliminates Point Plating, Fouling and Erosion.

Micrometer Complies with Federal Specification GGG-C-105A and is Traceable to a Master at the National Bureau of Standards.

Three Point Mounting with Dual Leveling Adjustment and Circular Level Vial Assure Rapid Set Up.

Durablock™ Precision Machined Acrylic Plastic Gage Body.

Sensitive 0-50 Microamp D.C. Meter Acts as Detector and Also Indicates Battery and Probe Condition.

Heavy One Half Inch Thick Steel Base Plate Provides Steady Mounting.

Top Quality Glass Epoxy Circuit Board and Solid State-Integrated Circuit Electronics.

Electronic Enclosure of Tough Molded Styrene Acrylonitrile Provides Maximum Protection to Components Yet Allows Easy Access to Battery Compartment.

Rugged Sheet Steel Cover and Carrying Case Protects the Entire Unit-When Not In Use.

Accessories Included are (2) 3 Foot Lengths Tygon Tubing, (2) 1/8" Pipe Thread Adapters and 3/4 oz. bottle of Fluorescein Green Color Concentrate with Wetting Agent.

Maximum Pressure 1(X) PSIG (With optional Pipe Thread Connections).
* Patent No. 3,726,142


DWYER INSTRUMENTS, INC.
P. O. BOX 373 • MICHIGAN CITY, INDIANA 46360, U.S.A.

Telephone 219/872-8141

Form No. 36-440190-00
Litho in U.S.A. 1/65

"Microtector"
A Product From
Dwyer Instruments, Inc.
"The Low Pressure People"

5-15 of 5-40



MICROTECTOR® GAGE

Precision Pressure Measurement
The Dwyer Microtector® combines the time proven principles of the Hook Gage type manometer and modern solid state integrated circuit electronics. It provides an inexpensive means of achieving accuracy and repeatability within $\pm .00025$ inches water column throughout its 0 to 2 inches w.c. range. It is truly a new standard in precision pressure measuring devices.

Principles of Operation

A pressure to be measured is applied to the manometer fluid which is displaced in each leg of the manometer by an amount equal to $1/2$ the applied pressure. A micrometer mounted point is then lowered until contacts the manometer gage fluid. The instant of contact is detected by completion of a low power A.C. circuit. Current for this circuit is supplied by a $1\frac{1}{2}$ volt penlight cell feeding two semi-conductor amplifiers which act as a free-running multivibrator operating at a frequency of approximately two kilohertz.

Completion of the A.C. circuit activates a bridge rectifier which provides the signal for indication on a sensitive (0 to 50 microamps) D.C. microammeter.

On indication of contact the operator stops lowering the point and reads the micrometer which indicates one half the applied pressure. By interpolating eight divisions, (each being .000125" w.c.) between .001 micrometer graduations, a total accuracy of .00025 can easily be achieved. The micrometer complies with Federal Specification GGG-C-105A and is traceable to a master at the National Bureau of Standards.

Locating and Opening

Stand the Microtector® and ease on a firm flat level surface. Remove the cover by releasing the latches and lifting straight up. If it is necessary to move the gage without case, handle only the base plate or clear acrylic block. (CAUTION: Do not handle gage by grasping meter-electronic package housing Item 7 on drawing.)

Fluid Level
Level the gage by adjusting the two front leveling screws (Item 8 on drawing) until the bubble in the spirit level is centered in the small circle. After leveling the gage, open both rapid shut off valve tube connectors (2 and 5). Back off the Micrometer (4), if necessary, to make sure that the point is not immersed in the gage fluid. The fluid level in the gage should now coincide with the mark on the right hand bore plus or minus approximately $1/32$ inch (6). If the level of fluid is too high, fluid can be removed with an eye dropper pipette or carefully poured out of the right connection (5). If the level is too low, remove the top left rapid shut off valve tube connector (2), and add distilled water pre-mixed with the proper amount of Dwyer green concentrate. (See maintenance instruction for proportions.) After correcting the fluid level, reinstall the rapid shut off connectors and with them in the open position, relevel the Microtector. The gage is now ready to be zeroed.

Zeroing

Turn the Micrometer barrel (4) until its lower end just coincides with the zero mark on the internal vertical scale and the zero on the barrel scale coincides with the vertical line on the internal scale. Note that the internal scale is graduated every .025" from 0 to 1.00 inch and the barrel scale is graduated in one thousandths from 0 to .025." Turn the meter circuit switch at the top of gage to the "on" position. While holding the barrel at the zero position (and with the gage level), raise or lower the point by turning the top knurled knob (3) until the point is above, but near the fluid. Check to be sure that the meter (1) registers zero. Watch the meter, hold the barrel (4) and lower the point slowly by turning the top knurled knob (3). As the knob is turned, the point will contact the fluid and the meter pointer will move from zero to some upscale position. After making contact, turn the point out of the fluid by turning the Micrometer barrel counter-clockwise to a reading of .010 or more. Again watch the meter and, this time, lower the point by turning the Micrometer barrel. The point position where the meter pointer begins to move up scale is the zero position. This position

should correspond to zero reading on the Micrometer. Adjust the point in relation to the Micrometer barrel by turning the top knob while holding the barrel steady. Repeat lowering the point, watching the meter for contact, and adjusting the point until the zero position and zero reading exactly coincide. The gage is now zeroed and should not be moved.

An alternate method of zeroing and reading can be used wherein, instead of zeroing the gage completely, a zero correction reading is taken and record then subtracted from the final reading. Comparable results can be obtained with either method.

Positive Pressure Measurement

With the fluid at its proper level, a pressure of 2.0" water column maximum can be measured. Positive pressure should be applied to the top left connection (2) with the Micrometer zeroed as described above. This will permit simple direct reading to be taken.

After an unknown pressure has been applied at the top left connection, the fluid level will drop in the left bore and rise over the point in the right bore. Note the indicating meter point has moved upscale because the point is immersed in the fluid; Turn the Micrometer counter-clockwise until the point leaves the fluid as indicated by the meter pointer dropping to zero on scale. Then slowly turn the Micrometer down until its point just touches the fluid surface causing movement of the meter pointer. Withdraw the point and repeat several times noting each time the Micrometer reading where the meter pointer movement begins. The average of these readings multiplied by two is the pressure applied to the gage. (Avg. reading $\times 2 =$ pressure applied in inches w.c. The degree of uncertainty for the operator and instrument is indicated by the difference in these readings.)

When the readings are complete the pressure should be removed and the zero setting of the Microtector® rechecked. Any change in the zero position will indicate inaccurate readings. Should this happen the zero-set and pressure measurement procedure should be repeated.

Negative Pressure or Vacuum Measurement

Zero the gage. Connect the source of vacuum or negative pressure to the right side gage connection (5) and proceed as described under Positive Pressure Measurement Section above. Remember that the pressure measured in this way is negative.

Differential Pressure Measurement

Differential pressures may be measured by connecting the higher (more positive) pressure to the left connection (2) and the lower pressure to the right connection (5).

Storage

Turn meter circuit switch to "off" position and withdraw "hook" point well clear of fluid (by turning Micrometer counter-clockwise) when gage is not in use. This will conserve the batteries and minimize build-up of oxides, etc., on the "hook." Keep the unit covered and in an area free of strong solvent fumes.

Maintenance

When the meter reading becomes reduced or the pointer movement gets sluggish (with circuit on and "hook" point in fluid), the following should be done:

1. Remove the hook point (by unscrewing) and clean the tip lightly using fine crepus cloth. Wipe off all grit and dirt with a clean rag, reassemble and recheck meter operation.
2. If the meter operation continues to be sluggish, replace the size AA, 1½ volt battery. (Replace the battery at least once a year to avoid deterioration of battery and damage to gage. Leakproof alkaline battery is recommended.)

To replace the battery, remove center screw (10) located in the back of the

electronic enclosure. Cover (9) will come off exposing the battery. Pull the old battery out and push a new battery into the battery holder with the positive (center) terminal to the right (to the end marked with a + on the holder).

If the fluid becomes contaminated and requires replacement; empty old fluid from gage; flush out with clear water and replace with distilled water and Dwyer A126 Fluorescein Green Color Concentrate mixed 3/4 oz. concentrate to each quart of water. (CAUTION: Do not substitute other gage fluids as proper gage operation depends on use of the specified gage fluid to provide proper surface tension, wetting ability and electrolyte capability with unity specific gravity.)

If the gage bore is very dirty, a mild soap solution may be used to aid in cleaning prior to flushing with clear water. (CAUTION: Do not clean with liquid soaps, special solvents, degreasers, aromatic hydrocarbons, etc. Such cleaners and solvents frequently contain chlorine, fluorine, acetone and related compounds which will permanently damage the gage, and prevent proper operation.)

If meter becomes inoperative and cannot be made to operate properly by cleaning "hook" tip or replacing battery, return the entire gage to Dwyer Instruments, Inc., for service.

"Microtector"®

A Product From

Dwyer Instruments, Inc.


"The Low Pressure People"

38-440190-00

Dwyer

ICRL...TOF.

Operating and Maintenance Instructions

**MICROTECTOR®****Specifications and Features***

Time Proven Hook Gage Manometer Combined with Modern Electronics For Easier, Faster, more Accurate Precision Pressure Measurements.

Accurate and Repeatable to ±0.0002 inches water column (0.00009 P.S.F.). Pressure Range 0-2" w.c. Positive, Negative or Differential Pressures.

Non Toxic and Inexpensive Gage Fluid Consists of Distilled Water Mixed with a Small Amount of Dwyer Color and Wetting Agent Concentrate.

Convenient, Portable, Light Weight, and Self-Contained, the Unit Requires No External Power Connections and is Operated by a 1½ Volt Penlight Cell.

A.C. Detector Current Eliminates Hook Plating, Fouling and Erosion. Micrometer Complies with Federal Specification GGG-C-105A and is Traceable to a Master at the National Bureau of Standards.

Three Point Mounting with Dual Leveling Adjustment and Circular Level Assure Rapid Set Up.

Durablock® Precision Machined Acrylic Plastic Gage Body.

Sensitive 0-50 Microamp D.C. Meter Acts as Detector and Also Indicates Battery and Hook Probe Condition.

Heavy One Half Inch Thick Steel Base Plate Provides Steady Mounting. Top Quality Glass Epoxy Circuit Board and Solid State-Integrated Circuit Electronics.

Electronic Enclosure of Tough Molded Styrene Acrylonitrile Provides Maximum Protection to Components Yet Allows Easy Access to Battery Compartment. Rugged Sheet Steel Cover and Carrying Case Protects the Entire Unit When Not in Use.

Accessories Included are (2) 3 Foot Lengths Tygon Tubing, (2) 1/8" Pipe Thread Adapters and 3/4 oz. bottle of Fluorescein Green Color Concentrate with Wetting Agent.

*Patent Applied For

Dwyer

DWYER INSTRUMENTS, INC.

P. O. Box 373, Michigan City, Indiana 46360, U.S.A.

Phone: Area 219/872-9141


Direct Chicago Line: Area 312/733-7883

DWYER INSTRUMENTS, INC.

Telephone 219/872-9141

Fluid Level

Level the gage by adjusting the two front leveling screws (Item 8 on drawing) until the bubble in the spirit level is centered in the small circle. After leveling the gage, open both rapid shut off valve tube connectors (2 and 5). Back off the Micrometer (4), if necessary, to make sure that the point or "Hook" is not immersed in the gage fluid. The fluid level in the gage should now coincide with the mark on the right hand bore plus or minus approximately 1/32 inch (6). If the level of fluid is too high, fluid can be removed with an eye dropper, pipette or carefully poured out of the right connection (5). If the level is too low, remove the top left rapid shut off valve tube connector (2), and add distilled water pre-mixed with the proper amount of Dwyer green concentrate. (See maintenance instruction for proportions.) After correcting the fluid level, reinstall the rapid shut off connectors and with them in the open position, relevel the Microtector. The gage is now ready to be zeroed.



MICROTECTOR® GAGE

Precision Pressure Measurement
The Dwyer Microtector® combines the time proven principles of the Hook Gage type manometer, and modern solid state integrated circuit electronics. It provides an inexpensive means of achieving accuracy and repeatability within $\pm .00025$ inches water column throughout its 0 to 2 inches w.c. range. It is truly a new standard in precision pressure measuring devices.

Principles of Operation
A pressure to be measured is applied to the manometer fluid which is displaced in each leg of the manometer by an amount equal to 1/2 the applied pressure. A micrometer mounted hook is then lowered until it contacts the manometer gage fluid. The instant of contact is detected on completion of a low power A.C. circuit. Current for this circuit is supplied by a 1 1/2 volt penlight cell feeding two semi-conductor amplifiers which act as a free-running multivibrator operating at a frequency of approximately two kilo-

hertz. Completion of the A.C. circuit activates a bridge rectifier which provides the signal for indication on a sensitive (0 to 50 microamps) D.C. microammeter.
On indication of contact the operator stops lowering the hook and reads the micrometer which indicates one half the applied pressure. By reading the micrometer to the closest .000125 inches a total accuracy of .00025 inches w.c. is easily achieved. The micrometer complies with Federal Specification GGG-C-105A and is traceable to a master at the National Bureau of Standards.

Locating and Opening
Stand the Microtector and case on a firm flat level surface. Remove the cover by releasing the latches and lifting straight up. If it is necessary to move the gage without case, handle only the base plate or clear acrylic block. (CAUTION: Do not handle gage by grasping meter-electronic package housing Item 7 on drawing.)

"hook" position where the meter pointer begins to move up scale is the zero position. This position should correspond to the zero reading on the Micrometer. Adjust the hook in relation to the Micrometer barrel by turning the top knob while holding the barrel steady. Repeat lowering the hook, watching the meter for contact, and adjusting the hook until the zero position and zero reading exactly coincide. The gage is now zeroed and should not be moved.
An alternate method of zeroing and reading can be used wherein, instead of zeroing the gage completely, a zero correction reading is taken and recorded then subtracted from the final reading. Comparable results can be obtained either method.

Positive Pressure Measurement

With the fluid at its proper level, a pressure of 2.0" water column maximum can be measured. Positive pressure should be applied to the top left connection (2) with the Micrometer zeroed as described above. This will permit simple direct readings to be taken.

After an unknown pressure has been applied at the top left connection, the fluid level will drop in the left bore and rise over the "hook" point in the right bore. Note the indicating meter pointer has moved upscale because the "hook" is immersed in the fluid. Turn the Micrometer counter-clockwise until the "hook" point leaves the fluid as indicated by the meter pointer dropping to zero on scale. Then slowly turn the Micrometer down until its point or "hook" just touches the fluid surface causing movement of the meter pointer. Withdraw the hook and repeat several times noting each time the Micrometer reading where the meter pointer movement begins. The average of these readings multiplied by two is the pressure applied to the gage. (Avg. reading $\times 2 =$ pressure applied in inches w.c.)

When the readings are complete the pressure should be removed and the zero-setting of the Microtector® rechecked. Any change in the zero position will indicate inaccurate readings. Should this happen the zero-set and pressure measurement procedure should be repeated.


AIR VELOCITIES WITH THE DWYER PITOT TUBE

AIR VELOCITY

The total pressure of an air stream flowing in a duct is the sum of the static or bursting pressure exerted upon the sidewalls of the duct and the impact or velocity pressure of the moving air. Through the use of a pitot tube connected differentially to a manometer, the velocity pressure alone is indicated and the corresponding air velocity determined.

For accuracy of plus or minus 2%, as in laboratory applications, extreme care is required and the following precautions should be observed:

1. Duct diameter 4" or greater.
2. Make an accurate traverse per sketch at right, calculate the velocities and average the readings.
3. Provide smooth, straight duct sections a minimum of 8½ diameters in length upstream and 1½ diameters downstream from the pitot tube.
4. Provide an egg crate type straightener upstream from the pitot tube.



In making an air velocity check select a location as suggested above, connect tubing leads from both pitot tube connections to the manometer and insert in the duct with the tip directed into the air stream. If the manometer shows a minus indication reverse the tubes. With a direct reading manometer, air velocities will now be shown in feet per minute. In other types, the manometer will read velocity pressure in inches of water and the corresponding velocity will be found from the curves in this bulletin. If circumstances do not permit an accurate traverse, center the pitot tube in the duct, determine the center velocity and multiply by a factor of .9 for the approximate average velocity. Field tests run in this manner should be accurate within plus or minus 5%.

The velocity indicated is for dry air at 70°F., 29.9" Barometric Pressure and a resulting density of .075#/cu. ft. For air at a temperature other than 70°F. refer to the curves in this bulletin. For other variations from these conditions, corrections may be based upon the following data:

$$\text{Air Velocity} = 1096.2 \sqrt{\frac{Pv}{D}}$$

where Pv = velocity pressure in inches of water
D = Air density in #/cu. ft.

$$\text{Air Density} = 1.325 \times \frac{Pb}{T}$$


where Pb = Barometric Pressure in inches of mercury
T = Absolute Temperature (indicated temperature °F plus 460)

Flow in cu. ft. per min. = Duct area in square feet x air velocity in ft. per min.



AIR VELOCITY CALCULATOR

Computes velocity based on air density corrected for conditions of temperature and pressure. Eliminates tedious calculations. Ranges from .01 to 10" water corresponding to 400 to 20,000 FPM. Furnished with each pitot tube.



STAINLESS STEEL PITOT TUBES

Test confirmed unity coefficient and lifetime construction of No. 304 stainless steel. Inch graduations show depth of insertion for traversing. Complies with AMCA and ASHRAE specifications. Sizes 12" to 60" long. Hand or fixed mounting types.

CALIBRATION INSTRUCTIONS
Microtector and Standard Type Pitot Tube

Calibration Description: Microtector and Standard Type Pitot Tube

Instrument Name: Hook Gage Liquid Manometer with Micrometer Gage in Inches.

Manufacturer: Dwyer Instruments, Inc.
P. O. Box 373
Michigan City, Indiana 46360
(219)872-9141

Style/Model: 1430
Serial Number: N/A (OMSE 33)
OMNI Tag #: OMNI-00033

Sample Flow Range: N/A
Resolution: N/A
Sensitivity: N/A
Accuracy: $\pm .00025$ inches water column
Range: 0-2" w.c. Positive, Negative, or Differential Pressures

Frequency of Calibration: Instrument is zeroed before each use. Recalibrated by service company after repairs.

Calibrator: Emissions testing technicians

Reference Standard:

Comments: Battery replaced when necessary

Temperature Calibration EPA Method 28 and 5G						
BOOTH:		TEMPERATURE MONITOR TYPE:			IDENTIFICATION NUMBER:	
Emissions		Type K digital readout			112	
REFERENCE TEMPERATURE MONITOR TYPE:				IDENTIFICATION NUMBER:		
OMEGA Calibrator Model CL300				Serial Number 506		
CALIBRATION PERFORMED BY:		DATE:	AMBIENT TEMPERATURE:		BAROMETRIC PRESSURE:	
B. Davis		5-3-05	69		29.88	
Reference Point Source	Temperature Monitor (°F)					
	Method 28 Room	Method 5G Dilution Tunnel				DB
Meter (Tm)		Filters (Tf)	Tunnel (Tt)	Dryer (Ts)		
OMEGA Thermocouple Simulator Serial #506						
0	001	000	000	000	000	000
100	100	100	100	100	99	100
300	303	303	303	303	303	303
500	501	501	501	502	500	501
700	701	701	701	701	702	701

Technician signature: B. Davis Date: 5-11-05

DIFFERENTIAL PRESSURE GAUGE CALIBRATION DATA SHEET Magnehelic Gauge

Instrument to be calibrated: Magnehelic

Range: 0 - .25" ID Number: 126

Calibration Instrument: ^{digital} Liquid Manometer ID Number: 315

Date: 7-6-05 By: B. Davis

^{Digital}

Liquid Manometer (A) (inches of H ₂ O)	Magnehelic Gauge (B) (inches of H ₂ O)	Difference (A - B)	% Error of Full Span*
.237	.24	.003	1.2
.143	.15	.007	2.8
.059	.06	.001	0.4
.011	.015	.004	1.6

*Acceptable tolerance is 4%.

This calibration is traceable to NIST through the Dwyer Liquid Manometer, NIST Test #MAS 822/254143-94.

Technician signature: B. Davis Date: 7-6-05

Certificate of Calibration

Certificate # 286629

Page # 1 of 1

Order Date: 13Nov2003

For: OMNI-TEST LABORATORIES

56

Department: NO

PO#: PAM BLACKBURN



JJ Calibrations, Inc.



#0723.01

Instrument Identification

Property #: OMNI-00131

Serial #: 27503

Make: OHAUS

User:

Model: 500mg

Noun: 500mg WEIGHT

Accuracy: CLASS F

Certification Information

As Found: Within Tolerance

Calibration Date: 19Nov2003

As Left: Within Tolerance

*Client Specified Due Date: 19Nov2004

Adjustments: None

Repairs: None

Seals: N/A

Environment: 20°C 33% RH

Procedure: CP 16

Technician: 34

Remarks

SEE DATA SHEET FOR MEASUREMENT RESULTS.

*Any number of factors may cause this item to drift out of calibration before the recommended due date has expired.

Standards Used


ID#	Manufacturer	Model#	Nomenclature	Due Date	Trace ID
432	SARTORIUS	C-44	MICROBALANCE 5.1g	19Nov2004	285515

JJ Calibrations, Inc., certifies that this instrument has been compared in accordance with the above referenced procedure using standards with accuracies traceable to the National Institute of Standards and Technology, derived from accepted values of physical constants, derived from ratio measurements, or compared to consensus standards. The results contained herein relate only to the item calibrated. This certificate is in compliance with the applicable requirements of ISO 17025, ANSI/NCSL Z540-1, MIL-STD-45662A, ISO 10012-1, ISO-9002 and QS-9000.

A Test Accuracy Ratio (TAR) of at least 4:1, if achievable, is maintained unless otherwise stated.

This uncertainty expression is expanded at approximately the 95% confidence level, coverage factor (k=2).


Technical Reviewer


Quality Assurance

This certificate shall not be reproduced except in full, without the written approval of JJ Calibrations, Inc.

Issued 19Nov2003
Rev # 11

Certificate of Calibration



Certificate # **232180** Page # 1 of 1 Order Date: 28Sep2001
For: OMNI-TEST LABORATORIES
Department: NO PO#: OTL-01-137

56

JJ Calibrations, Inc.

Instrument Identification

Property #: 27502 Serial #: 27502
Make: UNKNOWN User:
Model: 101b
Noun: 101b WEIGHT
Accuracy: ASTM E617

Certification Information

As Found: Within Tolerance Cal Date: 03Oct2001
As Left: Within Tolerance *Due Date: 03Oct2002
Adjustments: None Repairs: None Seals: N/A Environment: 21°C 44% RH
Procedure: CP 16 Technician: 49

Remarks

*Any number of factors may cause this item to drift out of calibration before the recommended due date has expired.

Standards Used

ID#	Manufacturer	Model#	Nomenclature	Due Date	Trace ID
550	AND	HP-30K	30k GRAM BALANCE	06Feb2002	210998

JJ Calibrations, Inc., certifies that this instrument has been compared in accordance with the above referenced procedure using standards with accuracies traceable to the National Institute of Standards and Technology, derived from accepted values of physical constants, derived from ratio measurements, or compared to consensus standards. The results contained herein relate only to the item calibrated. This certificate is in compliance with the applicable requirements of; MIL-STD-45662A and ISO-9002.

A Test Accuracy Ratio (TAR) of at least 4:1, if achievable, is maintained unless otherwise stated.

Tom Moody

Tom Moody
Manager

Opde L Martine

Quality Assurance

This certificate shall not be reproduced except in full, without the written approval of JJ Calibrations, Inc.

Issued 04Oct2001

Rev # 11

DIFFERENTIAL PRESSURE GAUGE CALIBRATION DATA SHEET Liquid Manometer Gauge

Instrument to be calibrated: Incline Manometer oil

Range: 0-10" H₂O ID Number: 156

Calibration Instrument: Liquid Manometer ID Number: 275

Date: 5-3-05 By: B. O. AUS

digital

Liquid Manometer (A) REF. (inches of H ₂ O)	Liquid Manometer (B) (inches of H ₂ O)	Difference (A - B)	% Error of Full Span*
1.99	2.0	0.01	0.1
0.99	1.0	0.01	0.1
0.63	0.65	0.02	0.2
0.34	0.35	0.01	0.1

*Acceptable tolerance is 4%.

This calibration is traceable to NIST through the Dwyer Liquid Manometer, NIST Test #MAS 822/254143-94.

Technician signature: *B. O. AUS* Date: 5-11-05

Weigh-Tronix, Inc.
 7933-SW Nimbus Ave. #28
 Beaverton, OR 97005
 503-626-3008
 1-800-878-3008

WEIGH-TRONIX
SERVICE WORK ORDER

SHIP TO	NAME OMNI ENVIRONMENTAL SERVICES	JOB No. 7111991
	ADDRESS 5465 SW WESTERN AVE	CUSTOMER No. / /
	CITY BEAVERTON	Order Date / /
	PHONE 503 - 643-3788 STATE OR ZIP 97075	Start Date / /
	FAX	Complete Date 1 / 11 / 99
CONTACT Bruce or Richard		
BILL TO	NAME	P.O. No. 99-007
	ADDRESS PO BOX 743	
	CITY	
	STATE	
	ATTN:	ZIP

EQUIPMENT

S/N	Location	Type	Cap.	Recommendations and Remarks
5547		WI-127	1K	10,000 DIV
21676		3030	1K	

COMMENTS

Rental 1 Month
 set up calibrated 1000 x 0.1 LB pan. load tested. good.

PARTS

2.5

Qty.	Description	Price	Total

SERVICE SUMMARY

Reg.	Agree.	Pref.	Inst.
Hrs. @			
Mileage			
Parts			
Shop Supplies			
Other			
TOTAL			

ZONE _____ **VEHICLE** _____
TECHNICIAN LD

THIS IS NOT AN INVOICE

acknowledge all service has been performed satisfactorily, as stated above. All parts installed are warranted for thirty days from this date.

WEIGH-TRONIX
 Rental / Sales / Service

Authorized Signature Bruce Davis
Print Name Bruce Davis

DAMAGE TO RENTAL/DEMO EQUIPMENT IS SOLELY THE RESPONSIBILITY OF THE USER WHILE IN THEIR POSSESSION!

DISTRIBUTION: WHITE - OFFICE YELLOW - FILE PINK - CUSTOMER

OMNI 00209

Instruction Booklet

for use with

PRINCO

Fortin type mercurial

Barometers

Manufactured by

PRINCO INSTRUMENTS, INC.
1020 Industrial Blvd.
Southampton, Pa. 18966-4095
U.S.A.


Phone: 215 355-1500
Fax: 215 355-7766

453
National
Weather
Service
Type


469
NOVA[™]
Economy
Model

5-28 + 5-40

OWNER'S MANUAL



MOISTURE DETECTORS FOR WOOD



DELMHORST INSTRUMENT COMPANY
BOONTON, N.J. 07005

DELMHORST INSTRUMENT COMPANY

5074-578

INDEX

Accuracy	3
Species Correction	5
Temperature Correction	5
Selection of Electrodes	6
Effects of Preservatives	7
Testing Plywood	7
Calibration Moisture Standards	8
Tests on Lumber with Wet Surface	8
Decay of Wood	9
Readings Above Fibre Saturation Point	9
Testing Wood Flooring	9
Maintenance	10
Effect of High Relative Humidity	10
Comments on Possible Malfunctions	11
Electrodes	12
Batteries	13

MOISTURE DETECTORS

HOW TO MAKE THE BEST USE OF THEM

The Moisture Detector models of the RC, G-2 and J Series (Pocket Tester) are portable, battery powered instruments designed to measure the moisture content in wood. Meters are calibrated so that wood moisture content is read directly on the meter dial. The standard calibration is made on Douglas Fir at a temperature of 70°F. Contact between meter and wood is made by means of an Electrode. Electrode(s) should be selected primarily on the basis of wood thickness to be tested.

ACCURACY OF MOISTURE DETECTORS

Moisture Detectors will give most satisfactory service if properly kept, and used in accordance with operating instructions.

The Delmhorst Moisture Meters utilize the principle that a definite relation exists between moisture content and electric resistance in wood. A "resistance" moisture meter actually measures the electric resistance in wood as a function of the moisture content. In order to measure the electric resistance of a board we drive two pins into the wood (or 2 sets of pins in the case of multiple-pins electrode), and have a current flow between them. The higher the moisture content, the lower the resistance. The meter "reads" moisture in that area of the board which is in contact with the electrode pins, and it tends to read the highest moisture content in that area.

Significant differences in moisture content may exist in the same board, especially during drying. Such differences largely depend on the species of the wood and on the range of moisture present in it. Generally, the lower the moisture content the more uniform is the moisture distribution; the higher the moisture content, greater are the variations in moisture from one point to the other. When the oven test is used for determining the moisture content of a board, the result is the average moisture content of the sample tested, which may or may not be equal to the average moisture content of the rest of the board, because of the differences that frequently occur, especially during the drying process.

On the other hand, if measurements are made with a moisture meter on the same sample, various tests may yield different readings and

even an average of these readings may not agree with the average obtained in the oven test.

Moisture meter readings and oven tests are in closest agreement if moisture content in a board has a very uniform distribution. Since it is well known that distribution of moisture content becomes more uniform at lower moisture range, meter readings may be expected to fall within the following tolerances:

0.5% on range of	5 - 12%
1.0% "	12 - 20%
2.0% "	20 - Saturation point.

AVERAGE MOISTURE CONTENT

When wood is in the process of drying and all of it has been dried below the fibre saturation point, the fibres located at 1/5th of the thickness from the surface have the same moisture content as the average of the section. Therefore, driving the contact pins of the electrode to a depth of 1/5th of the thickness of the wood will indicate a moisture content close to the average of the section.

Tests should be made at least one-foot from the end and 1 inch from the edge and at three diagonal points across the width of the board. The average of the various readings should be the correct answer.

As it has been stated before, the average moisture content as determined by an oven test and the average moisture content as measured by the moisture meter may not agree, unless the wood is well seasoned and has a uniform moisture distribution.

The question often asked is "which one of the two is the more reliable method for accurate measurements?" The two methods are not actually exclusive of each other. Oven tests, properly run by expert personnel with efficient and accurate equipment, are very accurate, but their results can be safely applied only to the specific sample(s) tested. Furthermore, the oven method is not practical if a considerable number of tests are to be made — it is time consuming and is a "destructive" test (in order to obtain a sample, a board has to be cut).

Electric meters' tests are also very accurate, if we consider the moisture content in the area which is in contact with the electrode pins. In addition many "non-destructive" tests can be made in a very short time so that not only an "average" moisture content can be determined, but also variations of moisture are detected.

4

When measuring moisture content it is not only important to measure the average but also the range of moisture content. A few high moisture content pieces may have only a small effect on the average moisture content but will result in rejections when associated with wood having a lower average moisture content. Both determinations and their accuracy, must be considered in relation to the ultimate use of the wood. For example, wood to be used indoors will generally attain its equilibrium moisture content between 4 and 10% with a usual average of 6 to 7% in most parts of the U.S.A. The amount of variation that can be tolerated depends on the product to be manufactured from it.

Lumber used in the production of fine furniture must not only be dried to an average of 6 to 7% but there must be little difference (usually less than 2%) among the pieces, and between the shell and core.

The meter is calibrated for use with a 4-pin electrode. When using an electrode with two insulated pins slightly lower readings are obtained. A correction of .5% to 1.5% should be added, according to the range of moisture content (See pg. 12).

EFFECT OF WOOD SPECIES ON METER READINGS

Different species of wood have different electrical properties and, as a result read differently for the same moisture content. The Moisture Detector is calibrated so as to read the moisture content of Douglas fir directly. See species corrections table, for other species of wood. The correction below 10% for many species, is so small that it can be disregarded and the meter read directly.

EFFECTS OF TEMPERATURE

As the temperature of wood increases, the electrical resistance decreases and vice-versa. The rate of change is not constant and, for accurate correction factor the temperature correction tables must be consulted. In the range 7 to 12%, the correction is approximately 1% for every 20°, which is subtracted from the meter reading if the temperature of the wood is higher than 70°F. and added if it is lower than 70°F. Most accurate tests are made when the temperature of the wood is approximately the same as the surroundings as it is difficult to measure the temperature of wood whose temperature is changing; as for example, wood just removed from a dry kiln and tested outside.

5

5-31 of 5-40

NUMBER OF MEASUREMENTS

Whatever the method used in measuring moisture content of lumber they are all intended to provide the most accurate information regarding the moisture condition of an entire board. Such accuracy does not only depend on the accuracy of the procedure or of the equipment used, but also on how "representative" the samples are in relation to the load. Theoretically, if one can be certain that all the boards of a load have the same moisture content, and that the moisture distribution is quite uniform in each board, one meter reading only, or 1 only oven test should be sufficient.

Such "ideal" condition does not occur very frequently. On the contrary, variations do occur in almost every board. If the lumber is properly seasoned the variations are contained within "safe" limits. However, it should be clear that the greater the number of tests the more accurate the final-determination.

The end use of the lumber should indicate how accurate an evaluation of the moisture content is required. For critical use, 5% or even 10% of the load should be tested. It is advisable that a large percentage of pieces be tested when starting to test for moisture. If it is apparent that the lumber is well dried, because of the small difference between readings, the number of tests can be reduced. However, it is important that some tests be made on boards that come from all parts of a load.

SELECTION OF THE ELECTRODE

A standard 4 pin Electrode (Delmhorst Type 4-E) having a 5/16" penetration can be used on most lumber up to 1 1/2" thick. Satisfactory tests can be made with the 4-E Electrode even on wood 2" thick provided the lumber has a low moisture content, normally associated with uniform moisture distribution. Thicker lumber should be tested with electrodes having deeper penetration, such as the Delmhorst Type 26-E and 18-E.

The 26-E has a penetration of 1", the 18-E a penetration of 3". The contact pins of these electrodes are insulated except for approximately 1/8" at their points so that they measure only the moisture of the wood in contact with the uncoated points. These electrodes are generally used for making shell and core tests without cutting the sample.

Thin wood, such as veneer, is tested by using contact pins with very shallow penetration, such as Delmhorst Type 16-E.

When making tests, contact pins should be driven into sound wood. If poor contact is made the moisture content will be underestimated. Uncoated pins should be driven into the wood to their full length, coated pins to the desired depth.

GRAIN DIRECTION

As the resistance of wood is greater across the grain than with the grain, the electrode should be applied so that current flows parallel to the grain. The effect due to the current flowing across the grain is very small when the moisture content is less than 10% and can be disregarded. At 20% the meter will read about 2% lower when the electrode is placed so that the current flows across the grain.

EFFECTS OF PRESERVATIVES

Organic treatments, such as creosote and pentachlorophenol, have little effect on the accuracy of moisture meter readings. On the other hand, inorganic salts such as zinc chloride and fire retardant compounds evaporate rapidly and affect the readings by indicating a higher moisture content than is actually present.

TESTING PLYWOOD

Most of the animal and vegetable glues have no effect on moisture meter readings. Therefore, when the contact pins penetrate a glue line, if it is dry the moisture content of the wood is accurately measured. In fact, the moisture meter is frequently used to determine when a glue joint is dry.

Many of the resin glues do affect the meter readings because they have a lower electrical resistance than the wood. The effect will be greater at a high moisture content than at a low moisture content.

The moisture meter can be used to show whether or not the glue affects the accuracy of the meter. Drive the contact pins through not more than one half the thickness of the first ply and read the meter.

Then, drive the pins so that they just pass through the first glue line. If there is no appreciable increase in moisture meter reading as the pins make contact with the glue line, the glue may be considered to have no effect and the readings will be correct. The pins should then be driven to their full length and the moisture content read on the meter.


CALIBRATION MOISTURE STANDARDS

Moisture Detectors are accurately calibrated at the factory and they generally hold the calibration indefinitely. If there is doubt as to the accuracy of the Moisture Detector, the calibration is easily checked by use of the Moisture Content Standards which are available for 12% and 22% moisture content.

HOW TO USE MOISTURE STANDARDS

The Moisture Meter (with the electrode not connected to it) should be adjusted in accordance with the operating instructions. After the electrode is connected to the Detector, there should be no appreciable change in the meter reading.

The electrode pins are then applied against the plates on the face of the standard: one pin to the center point, the other pin to one of the plates. The meter is considered to be in calibration if the reading is within one half of 1 percent of the standard (12% or 22%).



TESTS ON LUMBER THAT IS WET ON THE SURFACE

Lumber exposed to rain, fog or high relative humidity, is likely to have a higher surface moisture than the core. When the surface moisture is only a very thin film, it will dissipate quickly, without affecting the soundness of the lumber.

However, if it must be tested when surface moisture is present, insulated pins should be used (Electrode 26E with #496 pins).

DECAY OF WOOD

When wood has a moisture content in excess of 20% and is exposed to air it will support fungus growth, cause of decay and rot. The Delmhorst Moisture Detector is very useful in determining whether or not a wood structure or part thereof is subject to decay while it is still in good condition. For instance, a joint between two wood members may collect storm water and hold it there for considerable periods of time, thus causing decay. The Delmhorst Moisture Detector will reveal this condition and show that treated wood should be used or some metal protection or waterproofing be provided to prevent the retention of water in joints of this nature.

READINGS ABOVE FIBER SATURATION POINT

The meter scale features readings above 30%, (fiber saturation point). They are marked in green to indicate that the lumber still has free water, and should not be taken as an accurate, quantitative measurement of the moisture content. They lag far behind the actual moisture content and should only be used for the following purposes:

1. to indicate that the wood still has free water,
2. to allow dry kiln operators to make "Hot" board readings as the boards are removed from the kiln, when the temperature effect causes the meter readings to rise.

A reading of 40% on a board with a temperature of 160oF. indicates that, after the appropriate temperature correction is applied, the actual moisture content is 24%, which is a reliable indication, since the moisture content is below fiber saturation point.

TESTING WOOD FLOORING AND SUB-FLOORING

Moisture detectors are indispensable for the proper installation of wood flooring. For best results wood should have, at the time of installation, a moisture content close to the average between the high and low moisture content value it will attain in use. If wood is too wet when it is put in place, it will eventually dry to a moisture content in equilibrium with the environment conditions of prevailing relative humidity. The drying will obviously result in shrinkage, and cracks will develop.

On the other hand, if flooring with a very low moisture content were laid in an area when high relative humidity prevails, it will pick up

moisture and swell. The recommended moisture content for wood flooring as follows (based on information shown in Forest Products Laboratory Bulletin No. 1655 entitled "Moisture Content of Wood in Use");

	Average	Indiv. Pieces
Dry Southwestern States	6%	8-8%
Damp Southern Coastal States	10%	9-12%
Remainder of the United States	7%	8-9%

When flooring is installed on concrete slabs, it is important that the concrete be thoroughly dry at the time of installation. If it is not, the floor will pick up moisture from the slab and, even though it had absorb the recommended moisture content at the time of installation, will be followed by shrinkage when the wood finally dries to the normal moisture content.

MAINTENANCE OF MOISTURE DETECTOR

Your Delmhorst Moisture Detector is a fine quality precision instrument. Given reasonably good care it will last indefinitely with only an occasional replacement of batteries.

When it is necessary to replace the batteries, the screws holding the panel in the case must be removed in order to remove the panel. In more recent models, the battery compartment is easily accessible through its own door or cover, thus eliminating the need to remove the panel.

THE EFFECT OF HIGH RELATIVE HUMIDITY

If a moisture detector is used in areas of high relative humidity, moisture may set on some of the components or on parts of the electrode, creating an electrical leakage. This will cause the meter to "read" as soon as it is turned on. In such areas, the instrument should be stored in a dry office or warehouse, when not in use. If a dry office is not available, it may be stored in a small closed cabinet, heated with a 40-watt bulb. This will raise the temperature sufficiently to lower the level of humidity in the cabinet. Normally, moisture by condensation will collect on the meter or on the electrode and it will affect the meter readings when the instrument is brought from a cool storage area into a warm, humid environment. For this reason, operating a moisture meter inside a kiln is a practice to be discouraged.

Following are some comments concerning the possible malfunctions:

1. The meter cannot be adjusted. In such case, the batteries are usually weak or they are not making good contacts with battery terminals in the holders.
2. The meter pointer moves to the right as soon as the meter is turned on, even though the electrode is not in contact with any material. This is due to a current leakage, generally caused by dirt or moisture between the two poles of the electrode. The electrode insulation should be cleaned.
3. The meter gives no readings after the pins are driven into the wood and the meter is turned on. This is normally due to a broken wire in the electrode cable. The Moisture Detector and its electrode are in good working order if, upon placing the fingers across the contact pins, the meter reads between 20 and 30. If it had been possible to adjust the meter according to instructions, a failure to obtain a reading when touching the contact pins would indicate that the trouble is in the electrode and not in the instrument.
4. Whenever it appears necessary that a panel meter or a vacuum tube is to be replaced, the instrument should be returned to the factory for repair.
5. Such Models as the J-1, J-2, and RC-1C and RC-2, feature printed circuits on boards which can be easily unplugged and returned to the factory for repair, replacement or recalibration.

USING THE MOISTURE METER ON MATERIAL OTHER THAN WOOD

It is possible that the moisture detectors may find a useful application to indicate the moisture content of material other than wood. In such cases, after an initial evaluation, a calibration should be developed for the material in question. Ask for Bulletin "Procedure for Moisture Meter Calibration", PIB #87.

TYPE 26E ELECTRODE

The 26E electrode is an original Delmhorst design for

- non-destructive shell and core tests,
- detection of moisture gradient,
- testing lumber with wet surface.

The contact pins of this electrode are insulated except for the tip so that the depth at which measurements are taken is clearly identified. Readings taken with the 26E electrode are slightly lower than those taken with the 4-pin (4E) electrode which is used in the basic calibration of the instrument.

When using the 26E Electrode with insulated pins, the meter readings should be corrected according to the following table:

		Meter Reading							
7	8	10	12	14	16	18	20	22	24
7.3	8.4	10.6	12.8	14.9	17.0	19.2	21.4	23.7	26.0

The above correction should be disregarded when the insulation of the pins has worn off, or the uninsulated pins (A-111) are used.

TYPE 4E - To test boards, ¼" to 1½" thick. Pins penetration is 5/16". A hammer extractor for driving and extracting pins from lumber is available as optional equipment. Weight 2½ lbs.

TYPE 4E-H - Hammer style version of the 4E. To be used on softwoods only. Excellent for measuring moisture content on "dry chain". Weight 1½ lbs.

TYPE 18E - Similar to the 26E electrode. Pins penetration up to 3¼". Weight 2½ lbs.

TYPE 15E - Eight-pin electrode for veneer. Pins penetration is 1/8". Electrode can be used for checking veneer m.c. at end of dryer, at time of gluing and for incoming inspection. Weight ½ lb.

BATTERIES USED IN VARIOUS DELMHORST MOISTURE DETECTORS

INSTRUMENT MODEL	NO. BATTERIES	BATTERY TYPES
RC-1	3	1.5V "D" Flashlight Eveready #950
	4	22.5V Burgess K-15 or Eveready #420
RC-1B with Serial Nos. up to #6444	1	1.5V "D" Flashlight Eveready #950
	4	22.5V Burgess Y-15 or Eveready #505
RC-1B with Serial Nos. 6445 to #6699	1	1.5V Alkaline Energizer Ever.
	4	22.5V Burgess Y-15 or Eveready #505
RC-1B with Serial Nos. 6700 & up	1	1.5V Alk. Energizer Eveready #E-91
	3	22.5V Burgess Y-15 or Eveready #505
RC-1C	3	9V Eveready #216
RC-2	2	9V Eveready #216
G-2	1	45V Eveready #455
	1	1.5V "D" Flashlight Eveready #950
G-2B	1	1.5V "D" Flashlight Eveready #950
	2	22.5V Burgess Y-15 or Eveready #505
G-2C & G-2D	1	1.5V Alk. Energizer Eveready #E-91
	1	22.5V Burgess Y-15 or Eveready #505
G-2E/G-2Z	2	9V Eveready #216
J & J (A)	1	1.5V Alk. Energizer Eveready #E-91
	1	22.5V Burgess Y-15 or Eveready #505
J-1 & J-2	2	9V Eveready #216



OTHER INSTRUMENTS AVAILABLE

Electronic THERMOMETER Model TM-2


The TM-2 is a solid-state, portable battery operated instrument.

Remote sensing is possible up to 1000' or more. Probe extensions available in 3' rigid sections.

RANGES

- TM-2 (30°-150°F / 0-65°C.)
- TM-3 (-20°-110°F)
- TM-4 (100°-250°F)
- TM-5 (-20°-200°F)

The TS-2 Sensor is used to measure the temperature of liquids, gases or solids.



THE DELMHORST KIL-MO-TROL

The kiln keeps operating — you stay outside and measure moisture content of lumber while it is drying. There is no need to enter a hot kiln or to shut it down.

Saves Lumber — No need for sample boards. Tests are made on the lumber in the charge.

Saves Time — Shows exactly when lumber is dry.

Saves Labor — Twenty moisture tests, shell and core, in all parts of the charge can be made in less than two minutes.

Send sketch showing your kilns and control panel for a free Kil-Mo-Trol layout and cost of installation.

Appendix 2

MOISTURE CONTENT SCALES

There are two common ways of reporting moisture content in wood. In this book, and in most technical writings, moisture content is always based upon the oven-dry weight of the wood:

$$\text{Moisture content (oven-dry wood basis)} = \frac{\text{weight of moisture removed in oven drying}}{\text{weight of oven-dry wood}}$$

Using this scale, wood which is half water by weight has a moisture content of 100 percent.

A second way to report moisture contents is based on

the weight of the moist wood:

$$\text{Moisture content (moist wood basis)} = \frac{\text{weight of moisture removed in oven drying}}{\text{initial weight of wood, including its moisture}}$$

Using this scale, wood which is half water by weight has a moisture content of 50 percent.

These different scales for reporting moisture contents are another possible cause for discrepancies among lists of energy contents. 20 percent moisture content on an oven-dry wood basis is the same as 25 percent moisture content on a moist wood basis. To facilitate comparisons between writings using the two conventions, Table A2-1 gives conversions.

MOISTURE CONTENT ON AN OVEN-DRY-WOOD BASIS PERCENT	MOISTURE CONTENT IN EITHER SCALE PERCENT	MOISTURE CONTENT ON A MOIST-WOOD BASIS PERCENT
0%	0%	0%
5.3	5	4.8
11.1	10	9.1
17.6	15	13.0
25.0	20	16.7
33.3	25	20.0
42.9	30	23.1
53.8	35	26.9
66.7	40	28.6
100.0	50	33.3
150.0	60	37.5
233.0	70	41.2
Infinite	100	50.0
--	150	60.0
--	200	66.7
--	250	71.4

TABLE A2-1. Conversions between moisture contents as expressed in the moist wood and oven-dry wood scales. To use the table for either conversion, find the value to be converted in the center column. Then to convert from dry to moist basis read to adjacent number in the right column. To convert from moist to dry, read the adjacent number in the left column. If m and d represent the moisture contents on the moist-wood and dry-wood bases respectively, then $m = d/(1 + d)$, and $d = m/(1 - m)$.

Certificate of Calibration

Certificate # **315146**

Page # 1 of 1

Order Date: 27Jan2005

For: OMNI-TEST LABORATORIES

56

Department: NO

PO#: OTL-05-007



JJ Calibrations, Inc.

Instrument Identification

Property #: OMNI-00291

Serial #: 9190156

Make: OMEGA

User:

Model: RH82

Noun: THERMO HYGROMETER

Accuracy: Refer to Specifications



#0723.01

Certification Information

As Found: Within Tolerance

Calibration Date: 31Jan2005

As Left: Within Tolerance

*Client Specified Due Date: 31Jan2006

Adjustments: None

Repairs: None

Seals: Intact

Environment: 23°C 35% RH

Procedure: CP 11

Technician: 40

Remarks

Refer data sheet.

*Any number of factors may cause this item to drift out of calibration before the recommended due date has expired.

Standards Used

ID#	Manufacturer	Model#	Nomenclature	Due Date	Trace ID
464A	GENERAL EASTERN	M4-RH/D2	HUMIDITY STANDARD	10Dec2005	312016
497A	HART SCIENTIFIC	1502A	TWEENER THERMOMETER	09Aug2005	302848
498A	BURNS ENGR.	200G05B085	INDUSTRIAL PRT	29Dec2005	312022

JJ Calibrations, Inc., certifies that this instrument has been compared in accordance with the above referenced procedure using standards with accuracies traceable to the National Institute of Standards and Technology, derived from accepted values of physical constants, derived from ratio measurements, or compared to consensus standards. The results contained herein relate only to the item calibrated. This certificate is in compliance with the applicable requirements of ISO 17025, ANSI/NCSL Z540-1, MIL-STD-45662A, ISO 10012-1, ISO-9002 and QS-9000.

A Test Accuracy Ratio (TAR) of at least 4:1, if achievable, is maintained unless otherwise stated.

This uncertainty expression is expanded at approximately the 95% confidence level, coverage factor (k=2).

Technical Reviewer

Quality Assurance

This certificate shall not be reproduced except in full, without the written approval of JJ Calibrations, Inc.

Issued 01Feb2005

Rev # 11

NIST Stopwatch Calibration, Time Proficiency Testing Procedure and Data Sheet

Date: 10/3/05 User/Technician: B. Davis Pass Fail

NIST traceable stop watch OMNI Tracking Number: 292 Last Cal: JAN 31 2005

Stopwatch to be tested for time proficiency OMNI Tracking Number: 300

1. Start the NIST traceable stopwatch; at a predetermined time (i.e., 1.00 minutes), the technician shall start the watch being tested. When 15.00 seconds have passed (i.e., the NIST traceable stopwatch reads 1 minute, 15 seconds), the technician shall stop the watch being tested. Record the target time interval (i.e., 15.00 seconds). Repeat this step twice and record the data.
2. Repeat step #1 for each of the following target time intervals: 30.00 seconds, 10.00 minutes, and 30 minutes.
3. If the delta between the target time and measured time is less than 5% of the target time interval or 2.00 seconds (whichever is less), then the technician has demonstrated proficiency with the specific instrument utilized in the proficiency test. The proficiency is valid for a period of twelve months.
4. Archive the proficiency test data and information, including the effective date and expiration date of the proficiency, in the equipment record for the instrument involved.

Target time: 15.00 seconds #1 Measured time: 15:00 #2 Measured time: 15:03 #3 Measured time: 14:97
Target time: 30.00 seconds #1 Measured time: 30:03 #2 Measured time: 30:12 #3 Measured time: 30:00
Target time: 10.00 minutes #1 Measured time: 10:00.03 #2 Measured time: 10:00.16 #3 Measured time: 10:00.25
Target time: 30.00 minutes #1 Measured time: 30:00 #2 Measured time: 29:59.97 #3 Measured time: 29:59.94

Technician Signature: B. Davis Date: 10-3-05

Model: 8140
Morsø Jernstøberi A/S
Furvej 6 DK-7900
Nykøbing Mors
DENMARK

Section 6

Example Calculations

Note: OMNI-Test Laboratories, Inc. uses the Excel computer program for all Method 5G and 5H calculations. The program automatically carries 14 decimal points in all calculations. The numbers on the printouts have been rounded for display only.

Equations and Sample Calculations - Method 5G

Equations used to calculate the parameters listed below are described in this appendix. Sample calculations are provided for each equation. The raw data and printout results from a sample run are also provided for comparison to the sample calculations.

- BR Dry burn rate, kg/hr
- m_n Total particulate matter collected, mg
- $V_{m(std)}$ Volume of gas sampled corrected to standard conditions, dscf
- v_s Average dilution tunnel gas velocity, ft/sec
- C_s Particulate concentration, g/dscf
- Q_{sd} Average dilution tunnel gas flow rate, dscf/min
- E Particulate emission rate, lbs/hr
- PR Proportional rate variation, %

Dry Burn Rate

Using equation 28-3:

$$BR = \frac{60 \times W_{wd}}{\theta} \times \frac{100 - \%M_w}{100}$$

Where,

- BR = Dry burn rate, lb/hr
- W_{wd} = Mass of wood burned (wet basis) during test run, lb
- θ = Total time of test run, minutes
- $\%M_w$ = Average moisture content of test fuel charge, wet basis percent

Sample Calculation:

Dry basis moisture of fuel = 20.03%

Using the equation 28-2 for converting dry basis moisture to wet basis moisture,

$$\%M_w = \frac{20.03 \times 100}{20.03 + 100}$$

$$\%M_w = 16.69\%$$

The wet weight of the fuel charge was 7.8 pounds. Converting pounds to kilograms yields a weight of 3.538 kg. The run time for this run was 180 minutes. Therefore, the burn rate equation appears thus:

$$BR = \frac{60 \times 3.538 \times (100 - 16.69)}{180 \times 100}$$

$$BR = 0.98 \text{ kg/hr} = 2.17 \text{ lb/hr}$$

Total Particulate Matter Collected

$$m_n = F_1 + F_2 + R - (V_a \times B_a)$$

Where:

- m_n = Total particulate matter collected, mg
- F_1 = Particulate matter collected on front filter, mg
- F_2 = Particulate matter collected on rear filter, mg
- R = Residue from evaporated probe and filter holder acetone rinse, mg
- V_a = Volume of acetone evaporated probe and filter holder acetone rinse, ml
- B_a = Acetone blank value, mg/ml

Sample Calculation:

$$m_n = 12.6 - 0.4 + 4.7 - (180 \times 0.0040)$$

$$m_n = 16.2 \text{ mg}$$

Volume of Gas Sample Corrected to Dry Standard Conditions

Using equation 5-1:

$$V_{m(std)} = V_m \times Y \times \left(\frac{T_{std}}{P_{std}} \right) \times \frac{(P_b + \frac{\Delta H}{13.6})}{T_m}$$

Where:

- K = 17.64 °R/in. Hg
- T_{std} = 528 °R
- P_{std} = 29.92 in. Hg
- V_m = Volume of gas sample measured at the dry gas meter, dcf
- Y = Dry gas meter calibration factor, dimensionless
- P_b = Barometric pressure at the testing site, in. Hg
- ΔH = Average pressure differential across the orifice meter, in. H₂O
- T_m = Absolute average dry gas meter temperature, °R

Sample Calculation:

$$V_{m(std)} = 98.434 \times 1.01 \times \left(\frac{528}{29.92} \right) \times \frac{30.03 + \frac{0.7}{13.6}}{532.5}$$

$$V_{m(std)} = 99.116 \text{ ft}^3$$

Dilution Tunnel Gas Velocity

Using equations 2-7 and 2-6, calculated at each recorded interval:

$$v_s = k_p \times C_p \times \sqrt{\Delta P} \times \sqrt{\frac{T_{s(avg)}}{P_s \times M_s}}$$

$$M_s = M_d \times (1 - B_{ws}) + 18.0 \times B_{ws}$$

Where:

- v_s = Average dilution tunnel gas velocity, ft/sec
- k_p = Pitot tube constant: $85.49 \frac{ft}{sec} \left[\frac{(lb/lb-mole) \times (inches\ Hg)}{(^{\circ}R) \times (inches\ H_2O)} \right]^{\frac{1}{2}}$
- C_p = Pitot tube coefficient (0.99 for standard pitot tube; 0.84 may be used for S-type pitot tubes constructed according to Method 2 procedures), unitless
- ΔP = ΔP measured during the pre-test flow traverse of the dilution tunnel; the square root of the ΔP values are averaged for this calculation, in. H_2O
- P_b = Barometric pressure at test site, in. Hg
- P_g = Static Pressure of tunnel, in. Hg
- P_s = Absolute tunnel pressure, = $P_b + P_g$
- M_s = Molecular weight of tunnel gas; assume $M_d = 29$ lb/lb-mole (per method 5G)
- B_{ws} = Moisture content of dilution tunnel gas, ratio; assume 4% (per method 5G)
- T_s = Dilution tunnel temperature, $^{\circ}R$; ($^{\circ}R = ^{\circ}F + 460$)

Sample calculation:

$$M_s = 29 \times (1 - 0.04) + 18.0 \times 0.04 = 28.56$$

$$v_s = 85.49 \times 0.99 \times \sqrt{0.0351} \times \sqrt{\frac{(548)}{(30.03 + \frac{-0.45}{13.6}) \times (28.56)}}$$

$$v_s = 12.69 \frac{ft}{sec}$$

Average Dilution Tunnel Gas Flow Rate

Using equation 2-8, calculated at each recorded interval:

$$Q_{sd} = 3600 \times (1 - B_{ws}) \times v_s \times A \times \frac{T_{std}}{T_{s(avg)}} \times \frac{P_s}{P_{std}}$$

Where:

- Q_{sd} = Gas flow rate corrected to dry, standard conditions, dscf/hr
- 3600 = Conversion from seconds to hours
- B_{ws} = Moisture content of dilution tunnel gas, ratio; assume 4% (per method 5G)
- v_s = Average dilution tunnel gas velocity, ft/sec
- A = Cross sectional area of dilution tunnel, ft²
- T_{std} = Standard absolute temperature, 538°R
- $T_{s(avg)}$ = Average absolute dilution tunnel temperature, °R, (°R = °F + 460)
- P_b = Barometric pressure at test site, in. Hg
- P_g = Dilution tunnel static pressure, in. Hg
- P_s = Absolute dilution tunnel gas pressure, in Hg, (Hg = $P_b + P_g$)
- P_{std} = Standard absolute pressure, 29.92 in Hg

Sample calculation:

$$Q_{sd} = 3600 \times (1 - 0.04) \times 12.69 \times \frac{(\pi \times 3^2)}{144} \times \frac{528}{548} \times \frac{30.03 + \frac{-0.45}{13.6}}{29.92}$$

$$Q_{sd} = 8313.36 \text{ dscf/hr} = 138.56 \text{ dscf/min}$$

Particulate Emission Rate

Using equation 5G-3 and 5G-4:

$$E = C_s \times Q_{sd}$$

$$E_{adj} = K_3 \times E^{0.83}$$

Where:

- E = Particulate emission rate, g/hr
- E_{adj} = Particulate emission rate, adjusted, g/hr
- C_s = Concentration of particulate matter in the stack, corrected to dry, standard conditions, g/dscf
- Q_{sd} = Average dilution tunnel gas flow rate, dscf/hr
- K_3 = Constant, 1.82 for metric units, 0.643 for English units

Sample calculation:

$$E = 0.000163 \times 8313.36 \times 60$$

$$E = 1.36 \text{ g/hr}$$

$$E_{adj} = 1.82 \times 1.36^{0.83}$$

$$E = 2.35 \text{ g/hr}$$

Proportional Rate Variation

Using equation 5H-9, calculated at each recorded interval:

$$PR = \frac{\theta \times (V_{mi} \times V_s \times T_m \times T_{si})}{10 \times (V_m \times V_{si} \times T_s \times T_{mi})} \times 100$$

Where:

- PR = Percent proportional rate
- θ = Time of test, min
- S_i = Measured tracer gas concentration for the "ith" interval, in this case, the inverse of the calculated flow in the stack based on CO₂ concentrations in the stack and in the dilution tunnel
- $V_{mi(\text{std})}$ = Volume of gas sample measured by the dry gas meter during the "ith" 10 minute interval, dscf
- V_m = Volume of gas sample as measured by dry gas meter, dscf
- V_{si} = Average gas velocity in the dilution tunnel during each 10 minute interval, i, of the test run, m/sec
- V_s = Average gas velocity in the dilution tunnel, m/sec
- T_{mi} = Absolute average dry gas meter temperature during each 10 minute interval, i, of the test run, °R
- T_m = Absolute average dry gas meter temperature, °R
- T_{si} = Absolute average gas temperature in the dilution tunnel during each 10 minute interval, i, of the test run, °R
- T_s = Absolute average gas temperature in the dilution tunnel, °R

Sample calculation (for the reading at 50 minutes into test run 1):

$$PR = \frac{180 \times 5.6 \times 12.69 \times 533 \times 552}{10 \times 98.434 \times 12.63 \times 548 \times 532} \times 100$$

$$PR = 103.8\%$$

